

**Transmission Lines (220 kV and above) Commissioned/Ready for commissioning
During January-2024**

As on 31 Jan-2024

Sl. No.	Voltage Level (kV)	Name of Transmission Lines	Circuit Type	Executing Agency	Line Length (cKM)
1.	2.	3.	4.	5.	6.
CENTRAL SECTOR					
1	220	LILO of MTPS-A to Durgapur line at Barjora S/S	S/C	DVC	9
2	400	Ckt-2 of Re-conductoring of Siliguri – Bongaigaon 400kV D/c line with Twin HTLS conductor under North Eastern Region Strengthening Scheme-XII (NERSS-XII)	S/C	PGCIL	218
Total of CENTRAL SECTOR					227
STATE SECTOR					
3	400	LILO of Krishnapatnam - Manubolu (Ckt - I) Quad Moose line at Sembcorp (M/s SEIL- Plant 2) 400KV GIS Substation	D/C	APTRANSCO	7
4	220	220KV DC/SC line from 220KV SWS Inaparajupalli to M/s Shree Cement Ltd.	S/C	APTRANSCO	2
5	220	Rachaganneri-Racherla	D/C	APTRANSCO	107
6	220	Sullurpeta-Racherla	D/C	APTRANSCO	39
7	220	220 kV D/C Vadavi - Sanand DFCC Line	D/C	GETCO	62
8	220	220 kV Double Circuit Transmission Line from 220/132 kV GIS Sub-Station Mazra to 220/33 GIS Sub-Station Karian.	D/C	HPPTCL	36
9	220	LILO of Both ckt of 220kV D/C Sohna Road-Rangala Rajpur at 220kV s/stn. RojKaMeo	M/C	HVPNL	9
10	220	220kV SCDC line from 220kV Phaltan MIDC to 220kV Mol- Manjarwadi Solar Project of M/s. T.S.Wind Farm Developer.	S/C	MSETCL	20
11	400	LILO of one ckt of 400 KV Jalandhar Kurukshetra DC line at 400 KV Dhanansu.	D/C	PSTCL	8
12	220	LILO of 220 KV Rajpura Mohali at 220 KV Switching Station for release of connction to M/s Ultratech.	D/C	PSTCL	2
13	230	230KV, 1X1200 sq mm XLPE Aluminium UG cable from new joint bay in Royapettah high road masilamani road to 230kv Mylapore GIS SS for a route length of 1.149 kms for the deviation of existing 230KV TNEB HQ GIS SS to Mylapore feeder	SC	TANTRANSCO	1
14	220	220 kV Jehata(400)-Mallawan DC line	D/C	UPPTCL	158
15	220	LILO of 220kV R.C. Green (Gr. Noida)- Sector-148 (Noida) line at Knowledge Park-5 Noida	D/C	UPPTCL	14
16	220	LILO of 220kV R.C. Green (Gr. Noida)- Gr. Noida(400kV Pali) line at Jalpura	D/C	UPPTCL	28
Total of STATE SECTOR					493
PRIVATE SECTOR					
17	765	Khavda PS GIS – Bhuj PS 765 kV D/C Line	D/C	ADANI	218
Total of PRIVATE SECTOR					218
Grand Total					938