



भारत सरकार / Government of India
विद्युत मंत्रालय / Ministry of Power
केन्द्रीय विद्युत प्राधिकरण / Central Electricity Authority
विद्युत प्रणाली योजना एवं परियोजना मूल्यांकन प्रभाग - I
Power System Planning & Project Appraisal Division-I
सेवा भवन आर के पुरम नई दिल्ली-110066
Sewa Bhawan, R. K. Puram, New Delhi-110066
वेबसाइट / Website: www.cea.nic.in



[ISO: 9001:2008]

F. No 26/3/2016/ PSP & PA-I/ 393-395

Dated: 04.04.2016

06.04.2016

To
✓ Chairman and Managing Director,
PGCIL, Saudamini Plot No. 2, Sector - 29,
Gurgaon -122001, Haryana.

Subject: Prior approval of the Government under section 68 of the Electricity Act, 2003 for "Western Region System Strengthening Scheme - XVI" – Reg.

Reference: PGCIL's letter no. C/CP/WRSS- 16 dated 31.03.2016

Sir / Madam,


Reference is invited to the above mentioned letter of PGCIL, seeking prior approval of CEA, MoP, Government of India under Section 68 (1) of Electricity Act, 2003, hereinafter "the Act", in favor of M/s PGCIL for the scheme – "Western Region System Strengthening Scheme - XVI", with following scope of works:

- (i) Installation of 2 X 500 MVA, 400/220 kV ICTs with associated bays at Parli (PG) switching station along with provision of 6 no. of 220 kV bays (for LILO of 220 kV Parli – Harnagul D/C line at Parli (PG) S/s and LILO of Parli – Osmanabad 220 kV S/C at Parli (PG))
 - (ii) Provision of 2 no. of 220 kV bays at 400/220 kV Mapusa (Colvale) S/s for termination of the proposed Mapusa (Colvale) – Teum 220 kV D/C line
 - (iii) Installation of 1 X 500 MVA, 400/220 kV 3rd ICT with associated bays at Satna (PG) S/s with provision of 2 no. of 220 kV line bays
 - (iv) Provision of 2 no. of 400 kV bays at 765/400 kV Indore (PG) substation for termination of Indore (PG) – Ujjain 400 kV D/C line
2. The scope of works mentioned at above, have been agreed in 38th / 39th Standing Committee Meetings (SCM) on Power System Planning of Western Region held on 17.07.2015 and 30.11.2015 respectively.

3. CEA conveys the prior approval of Government under Section 68 (1) of Electricity Act, 2003 to M/s PGCIL for the scheme 'Western Region System Strengthening Scheme – XVI' with above scope of works.
4. This approval is subject to compliance of
 - a) The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
 - b) CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
5. The approval is also subject to the following conditions:
 - (i) The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
 - (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one month notice.
 - (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

Provided that "nothing contained in this rule shall effect the powers conferred upon any licensee under section 164 of the Act".

Yours' faithfully,



614116

(P.D Siwal)
Secretary, CEA.

Copy to: -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, Rafi Marg, New Delhi.
- (ii) PPS of Secretary, CEA