

I/4531/2019

1/1838-1839



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली योजना एवं मूल्यांकन - I प्रभाग
Power System Planning & Appraisal - I Division

सेवा में / To

Sh. Ujjwal Surana
Srijan Energy Systems Private Limited
102, El Tara , Hiranandani Gardens
Powai, Mumbai (Maharashtra) - 400 076

विषय : विद्युत अधिनियम, 2003 की धारा 68(1) के तहत M/s Srijan Energy Systems Private Limited (SESPL) को परीक्षण योजना "Connectivity system of M/s Srijan Energy Systems Private Limited for its 600 MW (300 MW + 300 MW) wind farms in Kutch, Gujarat" के लिये भारत सरकार का पूर्व अनुमोदन - सम्बंधित

Subject: Prior approval under Section 68(1) of Electricity Act, 2003 to M/s Srijan Energy Systems Private Limited (SESPL) for the transmission scheme "Connectivity system of M/s Srijan Energy Systems Private Limited for its 600 MW (300 MW + 300 MW) wind farms in Kutch, Gujarat" - regd.

संदर्भ /Reference: SESPL letter SESPL/US/CEA/18-19/292 dated 12.03.2019

Sir,

Reference is invited to the above mentioned letter, seeking prior approval of Government of India under Section 68(1) of Electricity Act, 2003, in favor of M/s Srijan Energy Systems Private Limited (SESPL) for the transmission scheme "Connectivity system of M/s Srijan Energy Systems Private Limited for its 600 MW (300 MW + 300 MW) wind farms in Kutch, Gujarat" with following scope of work:

- (i) SESPL switchyard - Bhuj PS 220 kV D/c line along with line bays at both ends* - to be developed by SESPL

* The line from SESPL switchyard upto Bhuj PS would be implemented in sections as follows:

- a) section 1(a): 22 km S/c line on D/c tower by M/s SESPL (Srijan-1 to Common Point)
section 1(b): 12 km S/c line on D/c tower by M/s SESPL (Srijan-2 to Common Point)
b) section 2: 30 km D/c line on D/c towers by M/s SESPL (Common Point to M/c tower starting point)
c) section 3: 2 km D/c line would be strung on M/c towers of M/s INOX Wind Ltd (M/c tower point to Bhuj PS)

I/4531/2019

2. The above transmission scheme with its specified scope of work, has been agreed in the 40th meeting of Standing Committee on Power System Planning for Western Region held on 01.06.2016 and in the 1st meeting of Western Region Standing Committee on Transmission (WRSCT) held on 05.09.2018.
3. CEA conveys the prior approval of Government under Section 68(1) of Electricity Act, 2003 to M/s Srijan Energy Systems Private Limited for the following overhead line under the transmission scheme "Connectivity system of M/s Srijan Energy Systems Private Limited for its 600 MW (300 MW + 300 MW) wind farms in Kutch, Gujarat":
- (i) SESPL switchyard - Bhuj PS 220 kV D/c line *
- * The line from SESPL switchyard upto Bhuj PS would be implemented in sections as mentioned above.
4. This approval is subject to compliance of
- a) The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
- b) CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
5. The approval is also subject to the following conditions:
- (i) The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
- (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
- (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,

Signature Not Verified
Digitally signed by P. C. KUREEL
Date: 2019.04.08 12:29:06 IST

(पी. सी. कुरील / P.C. Kureel)
सचिव / Secretary, के.वि.प्रा / CEA

प्रति लिपि / Copy to -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi