



भारत सरकार / Government of India
विद्युत मंत्रालय / Ministry of Power
केन्द्रीय विद्युत प्राधिकरण / Central Electricity Authority
विद्युत प्रणाली योजना एवं परियोजना मूल्यांकन- I प्रभाग
Power System Planning & Project Appraisal -I Division
सेवा भवन, आर.के.पुरम, नई दिल्ली - 110066
Sewa Bhawan, R. K. Puram, New Delhi-110066



सं / No.26/3/PSPA-I/2017/ 260-261

दिनांक / Date: 14.04.2017

सेवा में / To

24.04.2017

Chairman & Managing Director
POWERGRID Corporation of India Ltd.
Plot No.2, Sector-29
Near IFFCO Chowk
Gurgaon - 122001.

विषय : पावरग्रिड कॉर्पोरेशन इंडिया लिमिटेड (पीजीसीआईएल) की योजना " POWERGRID Works associated with Additional 400 kV feed to Goa" के विद्युत अधिनियम, 2003 की धारा 68 (1) के अन्तर्गत भारत सरकार के पूर्व अनुमोदन के लिए - संशोधन से सम्बंधित

Subject: Prior approval of the Government of India under section 68 (1) of the Electricity Act, 2003 to M/s POWERGRID Corporation of India Ltd. (PGCIL) for "POWERGRID Works associated with Additional 400 kV feed to Goa" - Modification reg.

संदर्भ / Reference:

- i. PGCIL's letter no. C/CP/Addl.Goa dated 09.03.2017
- ii. CEA's letter no. 26/3/PSP&PA-I/2016/529-30 dated 17.10.2016

महोदय / Sir,

Reference is invited to PGCIL's letter dated 09.03.2017, seeking modification in prior approval of Government of India under Section 68 (1) of Electricity Act, 2003, which has already been granted to M/s PGCIL vide letter under reference 'ii'.

2. The modification requested by M/s PGCIL is to include 1x80 MVAR fixed line reactor at Narendra(New) S/s in the scope of works. The modified scope of work for which revised prior approval of Government u/s 68 (1) of the Electricity Act, 2003 is sought by M/s PGCIL for the transmission scheme "POWERGRID Works associated with Additional 400 kV feed to Goa" is given below:
 - i. 2 nos. of 400 kV line bays at Mapusa for termination of Xeldem - Mapusa 400 kV D/C (Quad) line. (This line is to be implemented under TBCB)

- ii. 1x80 MVAR, 420 kV fixed line reactor along with 500 Ohms NGR and its auxiliaries at Narendra (New) S/s for Narendra (New) – Xeldem 400 kV (Quad) line [formed after LILO of one ckt. Of Narendra(existing) – Narendra(New) 400 kV D/C at Xeldem]
3. CEA vide its letter under reference 'ii' has already granted the prior approval of Government of India under Section 68 (1) of Electricity Act, 2003 to M/s PGCIL, for implementation of "POWERGRID Works associated with Additional 400 kV feed to Goa" with following scope of work:
 - i. 2 nos. of 400 kV Line bays at Mapusa 400 kV S/s for termination of Xeldem – Mapusa 400 kV D/C (Quad) line. (This line is to be implemented under TBCB)
4. Two nos. of 400 kV line bays at Mapusa 400 kV S/s has been agreed in 39th meeting of Standing Committee on Power System Planning of Western Region held on 30.11.2015 and 1x80 MVAR fixed line reactor at Narendra(New) S/s for Narendra(New) – Xeldem 400 kV (Quad) line [formed after LILO of one ckt of Narendra(existing) – Narendra(New) 400 kV D/C line at Xeldem] has been agreed in the 41st meeting of Standing Committee on Power System Planning of Western Region held on 21.12.2016.
5. CEA conveys the prior approval of Government of India under Section 68 (1) of Electricity Act, 2003 to M/s PGCIL for implementation of 'POWERGRID Works associated with Additional 400 kV feed to Goa' with the following modified scope of work:
 - i. 2 nos. of 400 kV line bays at Mapusa for termination of Xeldem – Mapusa 400 kV D/C (Quad) line. (This line is to be implemented under TBCB)
 - ii. 1x80 MVAR, 420 kV fixed line reactor along with 500 Ohms NGR and its auxiliaries at Narendra (New) S/s for Narendra (New) – Xeldem 400 kV (Quad) line [formed after LILO of one ckt. Of Narendra(existing) – Narendra(New) 400 kV D/C at Xeldem]
6. This approval supersedes the prior approval of Government under Section 68 (1) of Electricity Act, 2003 which has already been granted to M/s PGCIL vide letter under reference 'ii'.
7. This approval is subject to compliance of
 - a) The relevant provisions of the Electricity Act, 2003, as amended from time to time and the rules and regulations made there under, and
 - b) CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.

8. The approval is also subject to the following conditions:

- (i) The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
- (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
- (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

Provided that "nothing contained in this rule shall effect the powers conferred upon any licensee under section 164 of the Electricity Act, 2003".

भवदीय / Yours faithfully,



(पी डी सिवाल / P.D. Siwal)

सचिव / Secretary, के.वि.प्रा / CEA

प्रति लिपि / Copy to: -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi.