

I/12053/2020



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत प्रणाली योजना एवं मूल्यांकन-I प्रभाग

Power System Planning & Appraisal-I Division

सेवा में / To,

Shri Ujjwal Surana, Senior Manager – Regulatory & Sales
 102, “EI Tara” Orchard Avenue,
 Hiranandani Garden, Powai,
 Mumbai, Maharashtra - 400076
 Email Id: ujjwal.surana@continuumenergy.in

विषय : विद्युत अधिनियम, 2003 की धारा 68(1) के तहत M/s Srijan Energy Systems Private Limited (SESPL) को पारेषण योजना “Connectivity system to Srijan Energy Systems Private Limited for its proposed 150 MW wind farms in Kutch, Gujarat” के लिये भारत सरकार का पूर्व अनुमोदन – सम्बंधित

Sub: Prior approval of the Government of India under section 68(1) of the Electricity Act, 2003 to M/s Srijan Energy Systems Private Limited (SESPL) for the transmission scheme “Connectivity system to Srijan Energy Systems Private Limited for its proposed 150 MW wind farms in Kutch, Gujarat” - reg.

संदर्भ /Reference:

- (i) SESPL’s letter no. SESPL/US/CEA/19-20/33 dated 09.07.2020
- (ii) SESPL’s letter no. SESPL/US/CEA/20-21/36dated 21.10.2020

Sir,

M/s Srijan Energy Systems Private Limited (SESPL) vide its letter under reference (i) has sought prior approval of the Government of India under section 68 (1) of the Electricity Act, 2003 for the transmission scheme “Connectivity system to Srijan Energy Systems Private Limited for its proposed 150 MW wind farms in Kutch, Gujarat” with the following scope of work:

- i. SESPL – Bhuj-II PS 220 kV S/c line along with associated bays at generation end (under the scope of applicant)

Bays at ISTS substation end shall be under the scope of ISTS.

Further, M/s SESPL vide letter under reference ‘ii’ has submitted clarifications on the comments/observations of CEA.

I/12053/2020

2. The above transmission scheme with its specified scope of work has been discussed and agreed in 44th meeting of WR Constituents regarding Connectivity and LTA applications held on 28.01.2020.
3. CEA conveys the prior approval of Government under Section 68(1) of Electricity Act, 2003 to M/s Srijan Energy Systems Private Limited for the following overhead line under the transmission scheme "Connectivity system to Srijan Energy Systems Private Limited for its proposed 150 MW wind farms in Kutch, Gujarat":
 - i. SESPL – Bhuj-II PS 220 kV S/c line along with associated bays at generation end
Line length is approx. 25 km, which would be implemented in two sections from SESPL switchyard to Bhuj-II PS:
 - (a) Section 1: 25 km 220 kV S/c line on D/c towers from SESPL switchyard to M/c tower starting point
 - (b) Section 2: 2 km 220 kV S/c line on M/c towers from M/c tower starting point to Bhuj-II PS
4. This approval is subject to compliance of
 - a) The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
 - b) CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
5. The approval is also subject to the following conditions:
 - (i) The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
 - (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
 - (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,

(पी. सी. कुरील / P.C. Kureel)
सचिव / Secretary, के.वि.प्रा / CEA

प्रति लिपि / Copy to -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi