



भारत सरकार
Government of India
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
भार प्रेषण एवं दूर संचार प्रभाग
Load Despatch & Telecommunication Division
उत्तर क्षेत्रीय विद्युत समिति परिसर,
18-ए, शहीद जीत सिंह मार्ग
NRPC Complex, 18-A, Shaheed Jeet Singh Marg
कटवारिया सराय, नई दिल्ली - 110 016
Katwaria Sarai, New Delhi - 110 016



ISO: 9001:2008

CEA/LD&T/1/2013-PTCC/

Dated 4.10.2013

To,


All the members of Central PTCC

Subject: Additional Agenda for 97th Central PTCC meeting to be held on 21st October, 2013.

Sir,

The agenda for the 97th Central PTCC meeting to be held on 21st October, 2013 has already been uploaded on CEA's website (www.cea.nic.in) on 27th September, 2013. Subsequently, additional agenda items from BSNL (North), Powergrid (WR) and PSTCL have been received and the same have also been uploaded on CEA's website for your ready reference.

Kindly make it convenient to attend the meeting.


04.10.2013

(Naresh Bhandari)
Director (PTCC) & Secretary CLPTCC

011-26859952

M-9899061449

Email: directorptccc.cea@gmail.com
nbnareshbhandari@gmail.com

Encl. As above.

पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड
(भारत सरकार का उद्यम)
POWER GRID CORPORATION OF INDIA LIMITED
(A Government of India Enterprise)



"आय.एस.ओ. 9001 : 2000 प्रमाणित कंपनी" - "I.S.O. 9001 : 2000 Certified Company"

पांचवां व छठा तल, वुडा भवन, करेलीबाग, वडोदरा - 390018(गुजरात)
5th & 6th Floor, VUDA Bhavan, Karelibaug, Vadodara - 390018(Gujarat)
दूरभाष:/Phone: (O) 0265-2481416, फैक्स:/Fax: 0265-2480952

पश्चिम क्षेत्र पारेषण प्रणाली-II, क्षेत्रीय मुख्यालय
Western Region Transmission System - II, Regional Headquarters

Ref.: WRHQ-II: Engg: PTCC: 2106: CEA-97TH Central PTCC:2013: 8809
Date: 01ST October 2013

To,

Director (PTCC), Grid Operation & Distribution Wing, Kind Attn.: Sh. NARESH BHANDARI
Central Electricity Authority, Load Dispatch & Telecommunication Division,
NREB Complex, 18A - Saheed Jeet Singh Marg, New Delhi - 110 016

**Sub: REQUEST FOR INCLUSION OF POWERGRID, WRTS-II PTCC CASES AGENDA POINTS IN THE
97TH CENTRAL PTCC MEETING TO BE HELD ON 21/10/2013 AT CEA-NEW DELHI**

Dear Sir,

Reference is invited to the above subject matter. Please find enclosed herewith Agenda Points pertaining to WRTS#2 transmission lines projects which is requested to be included in the 97th Central PTCC Meeting.

Your kind co-operation is highly solicited please.

Thanking you,

Yours faithfully,

S. Balakumar
(S. Balakumar) 01/10/13

Chief Manager (Engg.)
POWERGRID, WRTS-II, Vadodara

Encl: As above

Copy to:-

- 01) The Divisional Engineer (Telecom), Kind Attn. : Sh. R.B. FEGADE
Bharat Sanchar Nigam Limited, PTCC, Western Region,
Juhudanda Administrative Building, 3rd Floor, 'D' Wing,
Juhutara Road, Santacruz (W), Mumbai - 400 054, Maharashtra.
For kind information and further needful please
- 02) Chief Signal & Telecom Engineer, Sh. Anil Jain
Office of General Manager (S&T),
West Central Railway, Second Floor,
DRM Office Building, Jabalpur - 482 001
For kind information and further needful please
- 03) Chief Signal & Telecommunication Engineer, Kind Attn.: Sh. O.P. Bajpai
Office of General Manager (S&T), **Western Railway**,
DRM Building, Third Floor, **Church Gate, Mumbai - 400 020**
- 04) Chief Signal Telecom Engineer (Telecommunication)
Office of the Chief Signal & Telecom Engineer,
North Central Railway, T.T. Line, 10th Marg,
Nawab Yusuf Road, **Allahabad - 211 001**

Copy to :- (N.O.O.)

- 01) GM (Projects-I) - For kind information please.

**Agenda points from PGCIL, WR-II, Vadodara for the 97th
Central PTCC Meeting to be held on 21.10.2013 at NEW DELHI**

1. MUNDRA UMPP :-

(A) 400kV D/C Mundra – Jetpur, Mundra-Limbdi Tr. Line

PTCC case submitted on 03.07.2009 (Commissioning by December 2012)

(DET PTCC Case File no. GUJ-619, CEA File Case No. GUJ-616 & Western Rly. File Case no. 1079)

During the last 95th & 96th CLPTCC meeting, it was deliberated towards conducting meeting at Director-PTCC-CEA-New Delhi office to sort out the issues and accordingly, CEA has intervened for technical solutions.

After protracted follow-up, WR-Mumbai has issued NOC for 400kv D/c for the above line and condition PTCC route approval is made available. POWERGRID has commissioned part of Surajbari – Jetpur line in the month of August-2012 and Mundra-Surajbari in the month of January-2013.

POWERGRID is requesting frequently to WR-Ahmedabad and Mumbai offices for completing the re-engineering works and issue permanent NOC and requesting for furnishing the completion of reengineering works.

2. VSTPP STAGE#IV AND RIHAND#III TR. SYSTEM :-

(A) 765kV S/C Satna – Gwalior Ckt#2 Transmission line under VSTPP #4 & Rihand –III.

PTCC case submitted on 17.08.2012 (Commissioning by Dec-2013)

All details are available in the office of DET-PTCC-Mumbai.

PTCC Route approval is to be issued from DET-PTCC-Mumbai

3. The detailed status of PTCC cases is appended at **ANN-A**



STATUS OF PTCC CASES FOR TR. LINES IN WESTERN REGIONS

DURING 2013-14 (AS ON 01.10.2013)

Sl. No.	Name of Transmission Line / DET-PTCC & CEA-New Delhi File Case No.	Length (Ckt. KMS.)	Date of Submission to DET-PTCC / Director-PTCC-CEA/Concerned Railways	Date of receipt of BSNL details at CEA for IV Calculations	Date of receipt of Railway details at CEA for IV Calculations	STATUS OF PTCC ROUTE APPROVAL	REMARKS
Establishment of 400/220kV GIS SS at MAGARWADA (UT of DD - T/L)							
1	LILO of 400 KV D/C Navsari-Boisar Transmission Lines at Magarwada (UT of DD) <u>BSNL CASE NO. G.UJ-2023</u> <u>CEA CASE NO. MRA-1021</u> <u>W.rly case No. 251</u>	15.862	A) Railways and BSNL Authorities on 11 th January 2013 B) Western Railway has given letter for marking for 8kMs Boundary line on 11.01.2013 and resubmitted on 10.03.2013.	DET-PTCC sent the details to CEA office vide letter ref no. IC/MBI/PTCC/GUJ-2023 DTD.21.05.2013	<u>FORWARDED TO CEA-NEW DELHI ON 19.08.2013</u>	Induced Voltage calculation pending in the office of Director-PTCC-CEA-New Delhi	The line length is very less of LILO portion only, CEA is to be expedite for furnishing the IV calculations
IPP Generation projects in Madhya Pradesh & Chhattisgarh							
2	765kV S/C Indore-Vadodara transmission line under IPP Generation projects in Madhya Pradesh & Chhattisgarh <u>BSNL CASE NO. G.UJ-W.Rly Case No. 242</u> <u>CEA CASE NO. G.UJ-665</u>	315	PTCC Route approval is under process 1) Western Railway telecom details forwarded to CEA on 12.08.2013. 2) DET-PTCC-Mumbai has forwarded the BSNL portion of MP & Gujarat on 20/09/2013				The line is targeted for commissioning under interim contingency bypassing Vadodara Pooling SS by Jan-2014. Request to CEA for furnishing IV by Nov-2013.
VSTPP #4 & RIHAND#3 TRANSMISSION SYSTEM							
4	765kv S/C (Quad) Vindhyachal Pooling Station To Satmact#1 (P219-Tw03 &04) Under Vstpp #4 & Rihand#3 Transmission System	247	1) PTCC CASE SUBMITTED ON 7 TH JUNE 2013 TO DET(PTCC), MUMBAI AND WCR, JABALPUR ON 7 TH JUNE 2013 AND IS UNDER PROCES. 2) WCR-JPUR has raised certain query regarding the incomplete Route map and other details, which were taken up with Vchal and Satna office for submission				The query is being sorted out for furnishing the legible copy route map and additional map to DET-PTCC-Mumbai and WCR-Jpur
5	765kV S/C Vindhyachal Pooling Substation- Satna Ckt#2 (P219-TW05 &TW06) Transmission line under VSTPP #4 & Rihand -III transmission system.	255	1) PTCC CASE SUBMITTED ON 7 TH JUNE 2013 TO DET(PTCC), MUMBAI AND WCR, JABALPUR ON 7 TH JUNE 2013 AND IS UNDER PROCES 2) WCR-JPUR has raised certain query regarding the incomplete Route map and other details, which were taken up with Vchal and Satna office for submission				To be further follow up with NCR-Allahabad for furnishing the details
6	765kV S/C Gwalior - Jaipur Ckt#1 transmission line (part-I) <u>BSNL CASE NO. G.UJ-382</u> <u>CEA CASE NO.:-MP-379& RAJ-504</u>		PTCC case for WR#2 portion (MP) submitted on 06 th June-2012. SDE-PTCC has forwarded to SDOT for marking of telecom details and is being followed up to furnished to Director-PTCC-CEA-New Delhi by Oct-2013. NCR-Allahabad is requested for sending Railway telecom details				

S. Balaram

4

Phase - I generation projects in Orissa Part-C

7	765kV D/C Jabalpur pool - Bina Transmission line under Phase - I generation projects in Orissa Part-C <u>BSNL Case No. 361</u> <u>CEA CASE NO. MP-370</u> <u>WCR Jabalpur Case No.103</u>	233	1) <u>SDE-PTCC / DET-PTCC and West Central Railway Authorities</u> on 6 th November 2012. 2) Western Central Railway Telecom details sent to CEA New Delhi 3) BSNL details to be forwarded to CEA on 14 th August 2013	WCR-Jabalpur has forwarded Performa A & B vide letter ref. no. WCR-N-HQ/120/PTCC/COR R-T-50-Pt-III CASE-103 DTD.28.06.2013	<u>EPR Zone Calculation, Single phase to ground fault current and other details submitted.</u>	The line is targeted for commissioning by Nov-2013 (Forest clearance and other statutory already available). Request to CEA for furnishing IV by <u>10/10/2013</u>
8	765kV S/C Bina -Gwalior Ckt#III <u>BSNL Case No. 358</u> <u>CEA CASE NO. MP-366</u> <u>WCR Jabalpur Case No.95</u>	231	1) WCR,Jabalpur & BSNL on Dt.04.09.2012 2) BSNL details to be forwarded to CEA by 30/07/2013 3) Rly details under process	WCR-Jabalpur has forwarded Performa A & B vide letter ref. no.WCR-N-HQ/120/PTCC/COR R-T-50-Pt-III CASE-95 DTD.28.06.2013	<u>SDE-PTCC-Bhopal has forwarded the details to DET-PTCC-Mumbai.</u> Request made to SDE-PTCC-Mumbai for forwarding the proposal to Director-PTCC-CEA-New Delhi by 1 st Week of Oct-2013 NCR-Allahabad requested for sending Railway telecom details	The line is targeted for commissioning by Jan-2014. (Forest clearance and other statutory already available). Request to CEA for furnishing IV by <u>10/10/2013</u>
9	765kV S/C Gwalior - Jaipur transmission line (Ckt-II) (part-I) (Tower Pkg P238-TW05 by M/s KPTL) associated with Phase-I Generation Projects in Orissa (Part-C) <u>CEA CASE NO:-MP-380& RAJ-504</u>		PTCC case for WR#2 portion (MP) submitted on 06 th June-2012. SDE-PTCC has forwarded to SDOT for marking of telecom details and is being followed up to furnished to Director-PTCC-CEA-New Delhi by Oct-2013. NCR-Allahabad is requested for sending Railway telecom details			To be further follow up with NCR-Allahabad for furnishing the details

Phase - I generation projects in Orissa Part-B

10	765kV D/C Dharamjaygarh Jabalpur pooling Substation <u>BSNL Case No. 362</u> <u>CEA CASE NO.MP-371</u>	273	1) <u>SDE-PTCC / DET-PTCC and West Central Railway, SECRly Authorities</u> on 6 th November 2012 PTCC CASE RAILWAY DETAILS FORWARDED T CEA BSNL DETAILS BY 30/07/2013 TO CEA	<u>SECR-has forwarded Telecom Performa-A&B to CEA-New Delhi on Dtd15/07/2013</u> <u>I.V.calculations pending at CEA</u>	EPR Calculation, Single phase to ground fault current bus of respective station and other details submitted.	Induced Voltage Calculation to be expedited from the office of Director-PTCC-CEA-New Delhi
11	400kV D/C Jabalpur-Jabalpur Pool transmission line part-III <u>BSNL Case No. 364</u> <u>CEA CASE NO. 369</u> <u>WCR CASE NO. 101</u>	16	1) Railways and BSNL Authorities 400kV D/C Jabalpur-Jabalpur transmission line on 1 st Nov 2012. 2) BSNL DETAILS TO CEA BY DTD. 30/07/2013.	<u>I.V.calculations pending at CEA</u>	<u>DET PTCC Mumbai has forwarded Telecom details to CEA-New Delhi on 05.08.2013</u> <u>DET PTCC Mumbai has forwarded Telecom details to CEA-New Delhi on 01.08.2013</u>	The line is targeted for commissioning by Nov-2013 (Forest clearance and other statutory already available). Request to CEA for furnishing IV by <u>10/10/2013</u>

Additional Area PGCL Page 2 of 5

S. Balasubramanian

5

Moser Baer Power Generation Projects

12	TPS (Anuppur Power Project) for connecting 400kV D/C MB TPS – Jabalpur Pooling SS Tr. Line <u>BSNL Case No. 363</u> <u>CEA CASE NO. MP-368</u>	246	<u>SDE-PTCC / DET-PTCC and West Central Railway, SECR on 1st November 2012.</u>	<u>SECR-has forwarded Telecom A&B to Delhi on 19/07/2013</u> <u>CEA-New Delhi</u>	<u>EPR Calculation still not forwarded</u> <u>I.Y. Calculations pending at CEA</u>	<u>DET PTCC Mumbai has forwarded Telecom details to CEA-New Delhi on 07.08.2013</u>	The line is targeted for commissioning by Jan-2014 (Forest clearance and other statutory clearance already available). <u>Request to CEA for furnishing IV by 15/11/2013.</u>
----	--	-----	--	--	---	---	--

S. Babbar

O/o DET(PTCC), Northern Zone,
Inspection Circle, Room No. 469,
Kidwai Bhawan, Janpath,
New Delhi-110001
Phone-011- 23713816 (O), 011-23713817(FAX)



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No.PTCC(T)/DV-2501/2013-14

Dated at ND the 30.09.2013

To,
The AGM (PTCC),
Inspection Circle,
Jabalpur-482001

Subject: *AGENDA/STATEMENTS FOR 97TH CLPTCC MEETING*

Agenda of 97th CL PTCC Meeting , approved /Pending cases, latest status of Un-guarded Power Crossing, SLPTCC meetings conducted and Electrocution cases are enclosed herewith in the following Annexures as under :

- I. Agenda for 97th CLPTCC Meeting.
- II. Status of approved CLPTCC and SLPTCC cases from 01.04.2013 to 30.09.2013
- III. Status of pending Central PTCC with CEA, ND & SEB's up to 30.09.2013
- IV. Latest status of Un-guarded Power Crossing as on 30.09.2013
- V. Latest status of SLPTCC meetings conducted from 01.02.2013 to 30.09.2013
- VI. Statement of Electrocution (Fatal/Non-Fatal) cases from 01.02.2013 to 30.09.2013

Any other information required may please be asked

DET(PTCC) N.ZONE
NEW DELHI.

Copy to:

1.The Director(PTCC), O/O CEA, Katwaria Sarai, New Delhi-110016

ANNEXURE-I

AGENDA FOR 97TH CLPTCC MEETING**1. Proposals not submitted of SLPTCC & CLPTCC Case**

As per Section 160 of Electricity ACT-2003 and Section "A"(Chapter-III) of PTCC Manual- 2010 the proposals of SLPTCC & CLPTCC cases not submitted by the State Power Authorities as under:

- A. **SLPTCC Cases:** Proposals of 11/33 KV S/C of Power lines not submitted by the State Power Authorities in Northern Zone for PTCC Route Approvals.

Action taken by the CEA ND

B.CLPTCC Cases: Proposals of 33 KV D/C and above of Power lines not submitted by the Power Authorities (i.e J&K, DTL-ND, UP(East), in Northern Zone for PTCC Route Approvals and Central PTCC Cases charged/ commissioned without PTCC Route Approval, **The Electrical Safety Inspector issued Commissioning Certificate without obtaining the PTCC Route Approval.** CEA ND is also issued a letter to all SEBs for taking the PTCC Route Approvals as per **Section 160 of Electricity Act-2003.** But above Power Authorities are not regularized till date.

Action taken by CEA ND**2.Charged CLPTCC Cases without PTCC Route Approval**

As per 94th CLPTCC meeting held at Madurai on 20.01.2012, it is decided in the meeting that blanket waiver can not be given for 14 nos of Power lines which are already charged during 2005 to 2007 without taking PTCC Route Approval and PTCUL was asked to forward PTCC Proposals for all such power lines which have been charged unilaterally. But till date, no any proposals of charged power lines have been submitted. CEA ND is also issued a letter vide LD&T/1/2012-PTCC/185 Dated 12.04.2012 in this regards

Necessary action taken by CEA ND**3. Training for IV Computations**

Training schedule for IV computations of power lines may be organized by the CEA ND for staff of SEBs/SDE(PTCC), so the pending issues can be solved immediately.

Action taken by the CEA ND**4. Charging of Rs.10,000/-case from private parties/DMRC Jaipur by RVPNL, Jaipur**

Practice for charging Rs.10,000/-per PTCC Case by RVPNL Jaipur from private/DMRC are not stopped till date.

Action taken by the CEA ND

ANNEXURE-II**APPROVED CASES FOR CENTRAL PTCC FROM 01.04.2012 TO 30.09.2013****A . RAJASTHAN**

S.N	Name of the route	Length in Kms	Ref. Date	Approved date
1	132 KV LILO to Bansur(220 KV GSS) from Bansur- Kotputli line	1.05	20.11.12	11.04.13
2	132 KV S/C PS-II to Godawari Green Energy Ltd. line	10.7	19.03.13	27.04.13
3	400 KV D/C Kalisindh – Anta line	82.443	10.02.12	17.06.13
4	132 KV S/C Lalsot- Bhadoti line	50	21.11.12	21.06.13
5	400 KV D/C Kanwai – Anta line	50.3	10.02.12	28.06.13
6	132 KV S/C Bhawad –Mathania line	14.071	21.01.13	29.06.13
7	132 KV S/C Tijara –M/S Kajaria Ceramics Ltd, Vill. Gaipur line	15	22.02.13	16.07.13
8	132 KV S/C Danta - M/S Kanchan India Ltd.line	3	04.03.13	23.07.13
9	132 KV D/C Chhonkrawada- Bhusawar	14.273	07.09.12	26.08.13
10	132 KV S/C Jakhrana – Mandan line	32	18.02.13	26.08.13
11	132 KV LILO to Behror(220 KV GSS) from Keshwana-Behror line	15	21.02.13	26.08.13
12	33 KV D/C U/G Cable from Mansarover RSS- Mansarover ASS for Jaipur Metro Rapid Transit System	2.1	29.07.13	29.08.13
13	33 KV D/C U/G Cable from Sindhi Camp RSS- Sindhi Camp ASS for Jaipur Metro Rapid Transit System	0.5	29.07.13	29.08.13
14	765 KV 2XS/C Anta(Baran) – Phagi Line (Ckt-I)	210	29.09.11	30.08.13
15	765 KV 2X S/C Anta(Baran) – Phagi Line (Ckt-II)	215	29.09.11	30.08.13
16	132 KV LILO TO Sayla from Sayla- Duspan line	10	29.04.13	04.09.13
17	220 KV D/C Line to connect LILO of 220 KV S/C Heerapura-Khetri(Ckt-II) to LILO of one Ckt. Of 220 KV D/C Kotputli-Neemrana line	50	12.04.10	06.09.13
18	220 KV LILO to Bamantukda from Kankroli- Bali line	4	30.01.12	06.09.13
19	220 KV LILO To Bamantukda from Bhilwara –Bali line	9.5	06.03.12	06.09.13
20	132 KV S/C Borunda – Nimbol line for M/S Siddhi Vinayak Cement Ltd	15.490	02.08.13	06.09.13
21	220 KV S/C Cable between Heerapura(400 KV GSS) Jaipur- NPH(220KV GSS) Jaipur	11.45	30.11.11	07.09.13
22	220 KV D/C Neemrana(PGCIL)- Behror line	27	20.11.12	11.09.13
23	400 KV D/C Chhabra – Anta line	89.788	10.02.12	11.09.13
24	220 KV LILO To Chonkarwada from Nadbai – Mandwar line	2.5	01.08.12	11.09.13
25	220 KV LILO to Bansur(220KV GSS) from Alwar-Kotputli line	1.048	12.11.12	12.09.13
26	220 KV D/C Bhawad- Baithwasia line	33.100	28.02.13	12.09.13
27	132KV S/C Baithwasia –Matora line	21	04.03.13	13.09.13
28	400 KV D/C Phagi(Jaipur South)-Heerapura line	48	31.03.11	19.09.13
29	400 KV D/C Phagi(Jaipur South)-Ajmer line	105	01.04.11	19.09.13
30	220 KV D/C Sanganer – Sitapura (GIS) Line	11.5	26.04.12	19.09.13
31	220 KV D/C LILO to Lasot from Anta- Dausa line	9.5	02.05.12	19.09.13

B. HARYANA=NIL

C. PUNJAB

1	400 KV D/C Rajpura – Dhuri T/line	85.169	11.05.12	17.04.13
2	400 KV D/C Muktsar – Makhu T/Line	195.520	04.10.11	19.09.13

D. HIMACHAL PRADESH

1	132 KV D/C From Village Saloan of existing 132 KV D/C Kangoo-Mattansi to propped 132 KV S/S at Jahoo Dist. Hami pur	5.949	07.04.13	02.05.13
2	220 KV D/C Kunihar- Rouri line	27.965	22.01.13	20.05.13
3	132 KV D/C from Tangnu- Romai HEP to 66/132/220 KV P.Station Sunda T/Line	11.7	12.07.13	17.07.13
4	220 KV D/C from 33/220 KV S/Stn Lahal –Bundhil HEP at Kharamukh, Distt-Chamba T/Line	2.066	17.06.11	24.08.13
5	220 KV D/C from 66/132/220 KV P.Station Sunda to 220 KV Switching Station Harkoti T/Line	22.693	12.07.13	24.08.13
6	220 KV D/C T/Line from Hrikoti(Snale)-220/400 KV S/Stn Gumma	39.17	28.03.12	02.09.13
7	400 KV D/C T/Line from 220/400 KV S/Stn Gumma – Lilo point on Jhakri – Abdulapur PGCIL line	3.198	28.03.12	02.09.13
8	220 KV S/C T/L on DC Tower from 33/220 KV GIS S/Stn Karian to 400 KV PGCIL Pooling S/Stn Rajera(Chamera)	3.914	15.12.10	12.09.13

E DELHI=NIL**F. U.P (East)**

1	765 KV S/C Satna –Gwalior Ckt-I, Part-II(UP Portion)	337	15.10.11	30.04.13
2.	765 KV S/C Satna- Gwalior Ckt-II, Part-II(UP Portion)	337	15.10.11	30.04.13
3	220 KV S/C Gonda – Basti T/line	104.374	13.09.11	30.05.13
4	33 KV S/C from 33KV S/S Mandhna- 220 KV S/S Bithoor line	5.85	20.04.13	17.06.13
5	765 KV S/C Fatehpur – Agra (Part-II, Pkg-G4, 2 nd line) associated with Sasaram Ultra Mega Power Project Scheme-2	167	06.04.13	19.09.13

G. UTTARANCHAL

1	33 KV D/C Underground Power Cable from Kashipur- Alganj	2.5	12.04.13	08.05.13
2	400 KV (Quad) Dehradun- Bagpat T/L, Part-I, PKG-A-3	84	21.10.10	15.07.13

H.U.P (West)

1	765 KV S/C Meerut – Agra T/Line (Part-II), pkg-A6	131.28	15.10.11	18.04.13
2	33 KV D/C from 400 KV PGCIL Attamanda - 765 KV S/S Hansi-Hansa Bareilly	1.2	09.11.12	25.06.13
3	33 KV D/C U/G Power Cable from 132 KV S/Stn.Sikandra Rao- 33/11 KV Barai Shahpur Line	6.802	16.09.13	25.09.13

J& K=NIL

ANNEXURE-III**CLPTCC Cases pending with CEA/SEB's for IV Computations****RAJASTHAN**

S.N	Name of Route/Capacity	Kms	Ref .Date	Reason for Pendency
1	220.KV S/C Jhunjhunu-Nawalgarh line	30.5	27.10.10	CEA Dt.24.11.11
2	200 KV D/C LILO to 400 KV GSS Ajmer from Beawar- Ajmer line	18	11.03.10	CEA DT.02.06.11
3	220 KV D/C LILO to 400 KV GSS Ajmer from Ajmer-Kishangarh line	6	11.3.11	CEA Dt. 02.05.11
4	220 KV D/C Hindaun – Gangapur City Line	50	28.04.11	CEA Dt. 21.02.12
5	220 KV LILO to Mandalgarh from Bhilwara-Kota line	20	06.09.11	CEA Dt.01.12..11
6	220 KV S/C Bhilwara- M/S Jindal Saw Ltd. Bhilwara	3	09.09.11	CEA Dt.12.12..11
7	220 KV LLO to Kachera from Merta – Nagaur line	9	19.09.11	CEA Dt.12.03.12
8	220KV LILO to Hamirgarh from Bhilwara–Chittorgarh line	8	14.11.11	CEA Dt..27.04.12
9	220 KV S/C Sikar – Nawalgarh line	24	15.11.11	CEA Dt..27.04.12
10	220 KV LILO to Amber from Debari-Kankroli line	16	03.02.12	CEA Dt. 20.07.12
11	220 KV S/C Renwal – Danta line	30	08.02.12	CEA Dt.15.10.12
12	220 KV S/C Sirohi – Pindwara line	25	01.03.12	CEA Dt.15.10.12
13	220 KV LILO to Badnu from Rattangarh – Bikaner Line	21.106	27.03.12	CEA DT. 08.08.12
14	220 KV D/C LILO to Babai from Khetri –Jaipur line	2.5	14.05.12	CEA DT.07.08.12
15	765 kv Gwalior –Jaipur Circuit-1(Part-II) T/Line (Rajasthan portion)	130	11.06.12	CEA DT.13.06.12/26.07.13
16	220 KV LILO to Jethana from Ras-Merta line	21	26.04.12	CEA Dt. 22.12.12
17	220 KV S/C Sujangarh –Tahendesar line	54.9	14.05.12	CEA DT 14.01.13
18	400 KV D/C Bhilwara – Chittorgarh line	48	14.05.12	CEA DT 14.01.13
19	220 KV Upgradation of existing 132 KV S/C Sanganer-Chaksu line to 220 KV D/C Line	42	06.07.12	CEA DT 14.01.13
20	220 KV D/C Ramgarh –Dechu line	196.290	26.07.12/ 03.08.12	CEA DT. 17.12.12
21	132 KV S/C Ramgarh – Railway S/Stn Ramgarh line	1.5	01.08.12	Submitted to RVPNL DT.29.08.12
22	220 KV D/C Jethana –Mangaliyawas TSS(DFCC) line	7	14.08.12	CEA DT.22.12.12
23	132 KV S/C Deeg- Railway Station Deeg line-	5	07.09.12/ 15.10.12	Submitted to RVPNL Dt. 05.11.12
24	220 KV D/C Jethana – Ajmer 400 KV GSS Line	70	23.05.12/	CEA DT.02.05.13
25	132 KV LILO to Maniya from Dholpur-Rajakhera line	14.690	19.09.12/ 15.10.12	Submitted to RVPNL Dt. 21.12.12
26	220 KV LILO to Alwar(400KV GSS) from Alwar- Dasua line	4	29.09.12	CEA DT 05.08.13
27	220 KV LILO to 400/220 KV GSS PGCIL Jaipur(South) from Duni-SEZ-1 Lline	28	18.10.12/ 10.12.12	CEA DT. 29.01.13
28	220 KV D/C Chittorgarh(400 KV GSS)- Sawa line	25	26.10.12	CEA DT 05.08.13
29	220 KV D/C Babai-220 KV TSS of M/S DFCC Maonda line	9.5	05.12.12	CEA DT.29.01.1
30	220 KV D/C Kishangarh-220 KV TSS of M/S DFCC Kishangarh line	25	05.12.12	CEA DT 16.07.13
31	220 KV LILO to Chitorgarh(400 KV GSS) from Chittorgarh- Debari line	2	21.12.12	Submitted to RVPNL Dt. 18.03.13

32	132 KV S/C Paloda- Ghatol line	40	21.01.13/ 06.02.13	Submitted to RVPNL Dt. 06.09.13
33	765 KV S/C Jaipur –Bhiwani, Part-I, Ckt-I(up to Mid point Lakha ka Nagal) T/Line	133.41	11.02.13	CEA DT. 07.08.13
34	765 KV S/C Lakha Ka Nagal -Bhiwani Part-I,(Ckt-II) T/Line	137.425	18.02.13	CEA DT 30.09.13
35	220 KV LILO to Bap from Barsingsar-Phalodi line	25	26.02.13	CEA DT 13.09.13
36	220KV D/C Bap-Bhadla line	60	26.02.13	CEA DT 13.09.13
37	765 KV S/C Gwalior -Jaipur Circuit-1I(Part-II) T/Line (Rajasthan portion)	143	01.03.13	CEA DT.26.07.13
38	132 KV S/C Cable between Banar -OPH	6.86	04.03.13	Submitted to RVPNL Dt.05.08.13
39	400 KV D/C Bhilwara – Ajmer line	155	05.03.13	CEA DT.02.07.13
40	132 KV D/C U/G Cable between NPH-MBM Engg College line	4.4	09.05.13	Submitted to RVPNL Dt. 30.09.13
41	132 KV D/C U/G Cable between NPH-MBM Engg College line	2.46	09.05.13	Submitted to RVPNL Dt. 30.09.13
42	132 KV LILO to Vatika(220 KV GSS) from Balawala-Phagi line	8	14.05.13	Submitted to RVPNL Dt. 30.09.13
43	220 KV D/C Jaipur(South PG)- 220 KV GSS Vatika line	30	27.05.13	Submitted to RVPNL Dt. 30.09.13
44	LILO to 220 KV GSS Vatika from 220 KV S/C KTPS- Sanganer line	8	27.05.13	Submitted to RVPNL Dt. 30.09.13
45	220 KV S/C from 220 KV GSS Jalore - 220KV GSS Sayla	53	27.05.13	CEA DT.06.09.13
46	220 KV D/C from PGCIL 400 KV GSS Bhinmal - RVPN 220 KV GSS Sayla	42	27.05.13	CEA DT. 12.09.13
47	132 KV S/C from Chomu - Jatawali(Dehra) line)	13.4	04.06.13	Submitted to RVPNL Dt. 31.07.13
48	220 KV D/C LILO To 400 KV GSS Udaipur from 220 KV S/C Debari- Chittorgarh line	2	14.06.13	Submitted to RVPNL Dt. 30.09.13
49	220 KV D/C LILO To Deedwana(400 KV GSS) from Kuchaman-Dhod line	45	18.07.13	CEA DT.06.09.13

CEA=36. SEB= 13

HARYANA

S. N	Name of Route/Capacity	Kms	Ref.Date	Reason for pendency
1	132 KV S/C Badhra-Loharu Line	18	04.11.03`	HVPNL Panchkula dt. 06.04.10 for IV
2	132 KV S/C Bhiwani 220 KV S/Stn to Bhiwani132KV S/Stn-I.A.Line	13.5	04.11.03	HVPNL Panchkula dt. 06.04.10 for IV
3	132KV S/C Bhiwani-Tosham Line	26	04.11.03	HVPNL Panchkula dt. 06.04.10 for IV
4	LILO of 220 KV D/C Shahbad-Pehowa Line at 220 KV S/Stn Durala	2.812	10.09.08	CEA Dt.19.01.09
5	220 KV D/C from 220 KV S/Stn Sampla- Mohana line	34.7	23.12.09	CEA Dt. 10.05.10.
6	132 KV D/C from 132 KV S/S Assaundha- 132 KV Traction S/S of Rly at Village Assaundha	1.96	09.05.11	HVPNL Panchkula dt. 04.10.12 for IV
7	132 KV S/C LILO at 132 KV S/S Assaundha from 220 KV S/S Narela- 132 KV B/Garh	4.991	09.05.11	HVPNL Panchkula dt. 04.10.12 for IV

CEA=2, SEB=5

PUNJAB

S. N	Name of Route/Capacity	Kms	Ref. Date	Reason for pendency
1	66 KV T-Off Nagra Line	0.74	19.07.10/ 10.08.10	PSPCL dt. 27.10.2010 for IV of Telecom/Rly Ckts.
2	66 KV Dhuri-Katron T-Off Ghanaouri Kalan line	0.64	09.08.10	PSPCL dt. 27.10.2010 for IV of Telecom/Rly Ckts.
3	66 KV S/C Rajla – Balbera line	11.753	03.01.11/ 21.02.11	PSPCL dt. 13.09.2011 for IV of Tele. Ckts)
4	66 KV D/C Nabha – Bakhopir line	9.502	03.01.11/ 21.02.11	PSPCL dt. 13.09.2011 for IV of Tele/Rly Ckts.
5	220 KV D/C Line on DC Towers from Botianwala – Mastewal	11.798	24.05.11/	CEA Dt. 13.09.11
6	220 KV LILO BTI –Malout line LILO for Badal	25.15	24.05.11/	CEA dt. 27.01.12
7	400 KV D/C Talwandi Saboo- Muksar line	100.3	30.05.11	CEA Dt.22.12.12
8	66KV D/C on SC Towers from Dan Singhwala- Aklia Kalan	6.31	07.06.11	submitted to PSPCL Dt. 24.11.12
9	66 KV D/C Line on SC Towers from Madhir- Kot Bhai	7.528	21.06.11	Handout G.T.Sheet not allowed.
10	220 KV D/C LILO To 220 KV S/S IKolaha from Govindgarh- Malerkotla line	6.65	07.07.11	CEA dt. 16.11.11
11	220 KV D/C on DC Tower from Bahadurgarh- Devigarh	28.058	08.07.11	CEA dt. 16.11.11
12	400 KV D/C Talwandi Suboo- Dhuri T/Line	87.789	14.07.11	CEA Dt.21.05.12/29.06.13,
13	400 KV D/C Talwandi Suboo-Nakodar and one Ckt lilo at Moga	166.018	27.07.11	CEA DT.26.11.12
14	400 KV D/C Makhu – Amritsar T/Line	64.552	12.10.11	CEA DT.15.06.13
15	66 KV S/C Budhlada-Datawas on S/C Tower line	10.101	20.10.11	PSPCL DT. 29.06.13
16	220 KV S/C Bhalwan – Nabha line	21.518	27.07.12	CEA Dt 04.10.12
17	220 KV LILO TO Bangan from Patran – Sunam line		06.08.12	CEA Dt. 04.10.12
18	220 KV LILO from Rajla –Patran at Kakrala on DC Towers	3.275	12.09.12	CEA Dt. 04.10.12
19	66 KV S/C from 220 KV S/Stn Mehalbalan-66 KV S/Stn Thulliwal DC Towqers	8.950	25.09.12	submitted to PSPCL Dt. 24.11.12
20	66 KV S/C from 220 KV S/Stn Mehalbalan-66 KV S/Stn Thibriwal DC Towqers	9.802	25.09.12	submitted to PSPCL Dt. 24.11.12
21	22 KV D/C GHTP Lehra Mohabbat – Mansa for Talwandi Saboo T/Line	29.850	04.10.12	Handout G.T.Sheet not allowed.
22	220 KV D/C T/Lfrom 400 KV S/S Muksar- 220 KV S/S Ghubaya	37.913	04.10.12	CEA DT.18.02.13.
23	220 KV D/C GHTP Lehra Mohabbat – Mansa LILO for Dhanaula T/Line	38..760	04.10.12	Handout G.T.Sheet not allowed.
24	220 KV D/C Muksar – Kotkapura(Sandhwan) line	38.180	22.10.12	CEA Dt.14.01.13
25	220 KV D/C LILO at Kotkapura(Sandhwan) from Muksar – Bazakhanaline	1.520	22.10.12	CEA Dt.14.01.13
26	220 KV D/C Govindwal Sahib- Chohla Sahib line	27.623	05.12.12	CEA DT.15.03.13
27	220 KV D/C Goindwal Sahib- Sultanpur line	18.995	05.12.12	CEA DT.15.03.13
28	220 KV Dhuri- Bhalwan Loop Out line	13.552	29.01.13	CEA DT. 29.06.13
29	220 KV Dhuri- Bhalwan Loop in line	13.7	12.02.13	- CEA DT. 29.06.13
30	66 KV D/C Dabwali Road Bhatinda- Barnala Road Bhatinda	6.779	01.03.13	Submitted to PSPCL DT.29.06.13
31	220 KV D/C from 400 KV S/S Dhuri (Balwan)- Bangan on DC Tower	50.343	08.03.13	CEA DT. 29.06.13

32	220 KV D/C Govindwal Sahib- Bottianwala T/Line	64.245	15.03.13	CEA DT.15.06.13
33	220 KV D/C LILO AT Sadiq from Ferozpur- Talwandi Bhai T/Line	38.760	12.04.13	DE-Faridkot (Handrawn Sheet)
34	66 KV Malout Road BTI- Dabwali Road BTI Line	10.506	15.04.13	PSPCL DT. 29.06.13 Rly-pending
35	220KV D/C from 400 KV S/S Muktsar – 220 KV S/S Abohar	42.531	18.04.13	CEA Dt. 27.05.13
36	220 KV D/C from 400 KV S/Stn Rajpura- Devigarh line	36.751	16.05.13/	DE-PTL/ Rly details pending (Handwan Sheet)

CEA=21. SEB=15

HIMACHAL PRADESH

S.N	Name of the Route/Capacity		Ref. Date	Reason for pendency
1	220 KV D/C T/Line to be LILO at 220/66 KV S/S Baddi	5.079	14.07.10	CEA Dt.18.03.11
2	LILO of 400 KV D/C Banala(Parbati Pooling Point)- Amritsar T/L at Hamirpur	3.36	06.07.12	CEA Dt. 31.08.12
3	400 KV D/C to Rampur HEP(HP) from Nathpa Jhakri – Nalagarh T/Line	3.556	21.11.12/ 01.01.13	CEA Dt. 14.01.13
4	220 KV D/C LILO to Hamirpur from Jalandhar- Hamirpur(Loop IN & Loop Out)	16.75	24.06.13	CEA DT.29.06.2013

CEA=4

DELHI

S.N	Name of the Route/Capacity		Ref. Date	Reason for pendency
1	66 KV D/C from 220 KV Papankala-II to G-15 Dwarka T/L	3.598	28.12.08	With DMRC ND
2	66 KV S/C U/G Cable Kanjhawala-DMRC RSS Mundka	7.775	02.04.09	With DMRC ND
3	220 KV D/C XLPE U/G Cable between 220 KV S/S Shalimar Bagh & 220 KV S/S Wazirpur along Yamuna Canal.	4.5	30.09.09	CEA Dt15.12.09
4	66 KV D/C U/G XLPE Cable from DTL S/Stn Mehrouli to DMRC RSS Chhattarpur	2.105	08.10.09	Power line not marked on GSI MAP
5	220KV D/C XLPE U/G Cable between 220KV Peeragarh GIS S/Stn and 220 KV Wazirpur GIS S/Stn.	10	15.06.10	CEA Dt.30.10.10
6	66 KV D/C from Sarita Vihar DTL S/stn to Sarita Vihar RSS of DMRC	2.4	23.06.10	Power line not marked on GSI MAP
7	66 KV D/C from Central Secretariate- Parkstreet RSS	1.9	25.06.10	Power line not marked on GSI MAP
8	66 KV S/C U/G Cable from Mundka 400/220/66 KV DTL Grid Station – DMRC RSS at Mundka	5.03	31.03.11 /08.04.11	Power line not marked on GSI MAP
9	33 KV D/C Central Secretariate Metro Station- Mandi House Metro Station		05.08.13	Collected Tecom submitted to DMRC Dt.25.09.13 for IV

CEA=2. DMRC=7

UP(EAST)

S.N	Name of the Route/Capacity		Ref. Date	Reason for pendency
1	765 KV D/C Sasaram –Fatehpur (Part-I) T/Line (PKG A4)	167 un	27.07.10/	CEA dt. 07,09.11

2	800 KV HVDC Gorakhpur-Lucknow(Gomati River Crossing) PKG-A7, Part of Bishwanath Charli-Agra T/L	190.5	30.04.11	CollectedTelecom details pending with PGCIL
3	400 KV D/C Gonda – Shahjahanpur T/Line	220	21.05.12	CEA Dt.06.09.12
4	400 KV D/C Tanda– Gonda T/Line	92	05.06.12	CEA Dt. 06.09.12
5	400 KV D/C Rewa Road –Meja T/Line under UP BOOT Scheme (Pkg-1)	33.5	08.10.12	CEA Dt.30.04.13
6	400 KV D/C Bara–Meja T/Line under UP BOOT Scheme (Pkg-1)	28	08.10.12	CEA Dt.30.04.13
7	800 KV HVDC Gopalganj- Gorakhpur T/Line, Pkg-A-6(UP-Portion)	187.396	25.04.13	CEA DT. 15.06.13
8	765 KV S/C Kanpur – Jhyatikara(Part-i) T/Line	272.85	30.07.13	CEA DT. 29.08.13

CEA=7, pgcil=1

UP(WEST)

S.N	Name of the Route/Capacity		Ref. Date	Reason for pendency
1	132 KV D/C U/G Cable from UPPCL Noida Sect-45- DMRC RSS Botanical Garden	4.45	19.06.09	Handrawn sheet used for marking of Power line
2	400KV D/C LILO to Shaharanpur from Dehradun- Bagpat T/Line	128.539	10.01.12	CEA Dt.01.02.12
4	400 KV D/C Maipuri- Aligarh T/Line	93	13.06.12	CEA DT. 05.01.13
5	765 KV S/C Mainpuri –Unnao T/Line	185	08.10.12	CEA DT 16.03.2013/06.09.13
6	765 KV S/C Mainpuri- Bara Ckt-I T/Line	385	30.10.12	CEA DT.21.06.13/RLY Pending
7	765 KV S/C Mainpuri- Bara Ckt-II T/Line	380	30.10.12	CEA DT.21.06.13/RLY Pending
8	400 KV D/C Agra – Sikar T/Line (up-Portion)	196.622	01.01.13	CEA Dt. 27.04.13
9	400 KV D/C Mainpuri – Orai LILO 1&2 T/Line	43.3	01.06.13	CEA DT 15.07.13
10	400 KV D/C Agra – Sikar T/Line (Rajsthan portion))	196.522	06.09.13	CEA Dt. 28.09.13

CEA=9, DMRC=1

UTTARANCHAL

S.N	Name of the Route/Capacity		Ref. Date	Reason for pendency
1	400 KV (Quad) Dehradun- Bagpat T/L, Part-II, PKG-A-4	81	25.10.10	CEA DT. 20.06.11
2	132 KV S/C Line for M/S Hero-Honda from 220 KV SIDCUL Haridwar	2.734	19.07.11	Submitted to XEN, PTCUL, Dt.02.08.11
3	220 KV LILO from Roorkee- Roshnabad at 400 KV S/S PGCIL Roorkee T/Line	2x4.99	14.03.12	CEA dt..22.03.12
4	400 KV (Quad) Roorkee- Saharanpur at SharanpurT/Line	36.062	28.04.12	CEA dt. 30.04.12
5	220 KV D/C Ghuttu - Ghansali T/Line	2x19.383	12.07.12	CEA Dt.04.10.12

CEA=4, SEB=1

J& K = NIL

SUMMARY OF PENDING CLPTCC CASES FOR IV COMPUTATIONS

S.N.	CIRECLE	PENDING WITH CEA ND FOR IV	PENDING WITH SEB's FOR IV	TOTAL
1	Rajasthan	36	13	49
2	UP (East)	08	00	08
3	UP (West)	07	00	07
4	Uttarnchal	04	01	05
5	Haryana	02	05	07
6	Punjab	21	15	36
7	Himachal	04	00	04
8	J & K	00	00	00
9	Delh	02	07	09
TOTAL		84	41	125

ANNEXURE-IV**SLPTCC MEETINGS HELD CIRCLE WISE FROMSLPTCC M 01.02 2013TO 30.09.2013**

S. No	Circle	Meetings held	Remarks
1	J & K	02.06.2010(by BSNL)	Due in Sept.2010(by Power) Defaulty UNIT
2	Himachal Pradesh	16.03.2012-(BY Power)	-Due in June.12(By BSNL) assured to conducted shortly
3	Punjab	14.06.13(by BSNL)	Due in Sept.13(by Power)
4	UP (East)	04.01.2013(By BSNL)	Due in March.2013(By Power)
5	Uttaranchal	14.04.2013(by BSNL) 27.09.13(by POower)	Due in Dec.2013(by BSNL)
6	Rajasthan	21.12.2012(by Power)	Due in March.2013 (by BSNL),
7	Delhi	05.05.2009(by MTNL)	Due in Sept.2009 (By Power) Defaulty UNIT
8	UP (West)	14.03.2013(by Power)	Due in June.2013(By BSNL)
9	Haryana	15.02.2011(by Power)	Due in May.2011(by BSNL) Defaulty UNIT
		4	

NOTE: Above default Circles are not taking keen interest to conduct quarterly SLPTCC Meetings at regular intervals even after several letters/reminders issued in this regards.

ANNEXURE-V

COMPERATVE STATEMENT OF UNGUARDED POWER CROSSING AS ON 30.09.2013

Circlewise Position Of Comparative Statement Of Unguarded Power Crossing									Total Guarded from 01.02.2013 to 30.09.2013
Monthly Report For the Month Of July									
Circle	Position at the beginning of the Month				Position at the end of the Month				
	Power	Telecom	Others	Total	Power	Telecom	Others	Total	
Haryana	0	0	0	0	0	0	0	0	0
HP	0	0	0	0	0	0	0	0	0
J&K	0	0	0	0	0	0	0	0	0
MTNL-ND	0	0	0	0	0	0	0	0	0
Punjab	0	0	0	0	0	0	0	0	0
Rajasthan	0	0	0	0	0	0	0	0	0
UP-E	0	1	0	1	0	1	0	1	0
UP-W	3	0	0	3	3	0	0	3	0
Uttranchal	0	0	0	0	0	0	0	0	0
Total	3	1	0	4	3	1	0	4	0

ANNEXURE-VI

STATEMENT OF ELECTROCUTION CASES FROM 01.02.2013 TO 30.09.2013

S.No	Name of circle	Electrocution cases (fatal / non-fatal) during period 01.04.2012to 30.09.2013
1	Rajasthan	No electrocution cases reported (occurred) Fatal / Non- Fatal during the above said period
2	UP (East)	
3	UP (West)	
4	Uttarnchal	
5	Haryana	
6	Punjab	
7	Himachal	
8	J & K	
9	Delh	



PUNJAB STATE TRANSMISSION CORPORATION LIMITED,
Regd. Office: PSEB Head Office, The Mall, Patiala-147001
Office of Chief Engineer /Transmission System,
3rd Floor, Shakti Sadan, Patiala-147001

Telephone: 0175-2303676 e.mail ce-tl@pstcl.org FAX 0175-2301536

To

✓ The Director (PTCC),
Central Electricity Authority,
Load Despatch & Telecommunication Division,
NREB Complex, 18-A,
Shaheed Jeet Singh Sansarwal Marg,
Katwaria Sarai, New Delhi-110016.

FAX No. 011-26859952
011-26565183

Memo No. 1286 /DT-6201/Vol-XII

Dated: 3-10-2013.

Subject: Agenda for 97th Central PTCC meeting to be held at New Delhi on 21.10.2013.

Please refer to your office Memo No. CEALD&T/1/2013-PTCC dated 25.09.2013 on the subject cited above.

In this regard, it is intimated that the following routes are pending for PTCC clearance as on 03.10.2013 which may kindly be discussed as part of Agenda items for early clearance.

1. PTCC Cases pending for BSNL Clearance

Sr. No.	Name of Transmission Line	Pending Since	Concerned DET offices
1.	PTCC case of 400KV Makhu-Amritsar D/C line. (L-675)	12.10.2011	Amritsar
2.	PTCC Case of 220KV Dhuri-Bhalwan Loop out D/C on D/C Tower Line. (L-691)	29.01.2013	Sangrur
3.	PTCC Case of 220KV Dhuri-Bhalwan Loop in D/C on D/C Tower Line. (L-692)	12.02.2013	Sangrur
4.	PTCC case of 220KV Goindwal Sahib to Bottianwala D/Ckt. Line. (L-694)	08.03.2013	Sangrur
5.	PTCC Case of 400KV D/C Line from 400KV S/Stn. Rajpura to Nakodar. (L-697)	30.04.2013	Patiala
6.	PTCC Case of 220KV line from 400KV S/Stn Dhuri (Bhalwan) to Bangan D/C on D/C Tower Line. (L-698)	08.03.2013	Sangrur
7.	PTCC Case of 220KV D/C Rajpura - Lalru line. (L-699)	18.04.2013	Patiala
8.	PTCC Case of 220KV S/C line on D/C towers from 400KV S/Stn. Ludhiana to Doraha. (L-700)	09.05.2013	Patiala
9.	PTCC Case of 220KV D/C line on D/C Towers from 220KV Sub-Station Bagha Purana to Baza Khana (L-702).	27.06.2013	Ludhiana
10.	PTCC Case for route approval of 220KV Makhu to Rashiana D/C line (L-703).	10.09.2013	Ferozepur & Amritsar

2. PTCC Cases Pending for Railway Clearance


Sr. No.	Name of Transmission Line	Pending Since
1.	PTCC case of 220KV D/C Line on D/C towers from Bahadurgarh to Devigarh (L-667)	8.8.2011
2.	PTCC case of Lilo of 220KV Malerkotala-Gobindgarh Line at 220KV S/Stn. Ikolaha. (L-668)	7.7.2011
3.	PTCC case of 400KV Talwandi Sabo - Dhuri D/C Line. (L-669)	14.7.2011
4.	PTCC Case 66KV line from 220KV S/Stn. Mehalkalan to 66KV S/Stn. Thikriwal line. (L-682)	25.9.2012
5.	PTCC Case 66KV line from 220KV S/Stn, Mehalkalan to Thuliwal S/C on D/C Tower line. (L-683)	25.9.2012
6.	PTCC Case of 220KV Goindwal Sahib to Chonla Sahib D/Ckt. Line. (L-689)	05.12.2012
7.	PTCC Case of 220KV D/Ckt Goindwal Sahib - Sultanpur Transmission Line. (L-690)	05.12.2012

8.	PTCC Case of 220KV Dhuri-Bhalwan Loop out D/C on D/C Tower Line. (L-691)	29.01.2013
9.	PTCC Case of 220KV Dhuri-Bhalwan Loop in D/C on D/C Tower Line. (L-692)	12.02.2013
10.	PTCC case of 220KV Goindwal Sahib to Bottianwala D/Ckt. Line. (L-694)	08.03.2013
11.	PTCC Case of 220KV line from 400KV S/Stn. Dhuri (Bhalwan) to Bangan D/C on D/C Tower Line. (L-698)	08.03.2013
12.	PTCC Case of 220KV D/C Rajpura - Lalru line. (L-699)	18.04.2013
13.	PTCC Case of 220KV S/C line on D/C towers from 400KV S/Stn. Luchiana to Doraha. (L-700)	09.05.2013
14.	PTCC Case of 220KV D/C line on D/C Towers from 220KV Sub-Station Bagha Purana to Baza Khana (L-702).	27.06.2013
15.	PTCC Case for route approval of 220KV Makhu to Rashiana D/C line (L-703).	10.09.2013

3. PTCC Cases pending with CEA due to Induced Voltage Calculations

Sr. No.	Name of Transmission Line
1.	PTCC case of 220KV DC line on DC Towers from Bottianwala-Mastewala. (L-662)
2.	PTCC case of 220KV Bathinda-Malout Line LILO for Badal. (L-663)
3.	PTCC case of 400KV DC Talwandi Saboo-Mukatsar Line. (L-664)
4.	PTCC Case of 400KV D/C Line Talwandi Sabo-Nakodar & One Ckt. LILO at Moga. (L-671)
5.	PTCC case of 400KV Mukatsar-Makhu Transmission Line. (L-672)
6.	PTCC case of 220KV Bhalwan-Nabha S/Ckt. on D/Ckt. Tower line. (L-679)
7.	PTCC case of LILO of One Ckt. of 220KV Patran-Sunam at Bangan. (L-680)
8.	PTCC case of LILO of One Ckt. of 220KV Rajla - Patran at Kakrala D/Ckt. on D/Ckt. Tower Line. (L-681)
9.	PTCC Case of 220KV D/C Transmission line from 400KV S/Stn. Mukatsar to 220KV S/Stn. Ghubaya (L-686)
10.	PTCC Case of 220KV DC line from Mukatsar-Bajakhana line LILO for Kotkapura (Sandhwan). (L-687)
11.	PTCC Case of 220KV DC line from Mukatsar-Kotkapura (Sandhwan) line (L-688)

This is for information and further necessary action please.


Addl. SE/T&S-IV,
for CE/TS, PSTCL, Patiala

CC:

1. The DET/PTCC,
North Zone Room No. 469,
Kidwai Bhawan, 4th Floor, Janpath,
New Delhi.

2. The SDE (PTCC), CTO Complex,
Adj. GPO Compound, Ambala Cantt.

for information and
further necessary action Please.