



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलप्मेंट डिविजन
Power Communication Development Division
एन आर पी सी परिसर शहीद जीत सिंह मार्ग ,कटवारिया सराय
NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai
नई दिल्ली-110016 New Delhi - 110 016

Telefax 011-26859952



[ISO: 9001: 2008]

No. CEA/PCD/103 CLPTCC Meeting/2016/

Date: 18.11.2016

To,

All Central PTCC Members (As per attached list)**Subject: Agenda for 103rd Central PTCC meeting to be held at Jabalpur on 25th Nov,2016**

Sir,

The Agenda along with meeting notice for 103rd Central level PTCC meeting going to be held on held 25th Nov,2016 at Jabalpur (M.P.) has been uploaded on CEA website <http://www.cea.nic.in> for information and necessary action.

Kindly initiate required action.

Yours faithfully

R. P. Pandey
(R.P Pandey)
Director (PTCC)



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority [ISO: 9001: 2008]
पावर कम्युनिकेशन डवलपमेंट डिवीजन
Power Communication Development Division
18- ए, एन. आर. पी. सी. परिसर, शहीद जीत सिंह मार्ग, कटवरिया सराय
18-A, NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai,
नई दिल्ली-110016 New Delhi - 110 016



No. CEA/PCD/103 CLPTCC Meeting/2016/

Date: 18.10.2016

To,

All Central PTCC Members (As per attached list)

Subject: 103rd Central Level Power and Telecommunication committee (CLPTCC) meeting- reg.

Sir,

The 103rd meeting of Central Level Power & Telecommunication Coordination Committee (CLPTCC) is scheduled to be held at Jabalpur, Madhya Pradesh as per the following programme:

Date of meeting	: 25 th Nov. 2016 (Friday)
Time	: 11:00 Hrs.
Venue	: Seminar HALL, Bharat Ratan Bhim Rao Ambedakar Institute of Telecom Training (BRBRAITT) Ridge Road Jabalpur

The compliance/follow up action of meeting minutes of last 102nd CLPTCC meeting of Gangtok and addition agenda item, if any may be sent to BSNL with a copy to CEA for incorporation in the main agenda.

The meeting shall be conducted by BSNL. The participants attending the meeting from your organization may communicate with the following officers of BSNL for assistance, if any.

1. Shri P. K. Jain AGM (MM) M. NO. 9425803008 e-mail agmmmtnd@gmail.com
2. Shri M. K. Gupta SDE (PTCC) M. No. 9425800834 e-mail agmsw@rediffmail.com

Yours faithfully,

Naresh Bhandari 18/10/16

(Naresh Bhandari)
Chief Engineer (PCD), CEA &
Co-Chairman, Central PTCC
M-9899061449
Email: CELDNTCEA@gmail.com

Annexure - SZ/1

Revised comments for point B.2 as on 09/11/2016

B.2	<p><u>Computerization of PTCC Route Approval Process</u></p> <p>a) To improve PTCC online portal, views of stakeholders were sought. APTRANSCO informed that they were not able to upload the complete proposal in the PTCC portal, only covering note could be uploaded. RRVPNL informed about difficulties being faced in operating the portal and suggested that a workshop should be organized by BSNL for state power utilities in every State. OPTCL also raised the same issue and suggested for workshop in their State also. Railway representative also showed inability in operating the portal. Representative from ITPC, BSNL, Hyderabad stated that currently pdf format documents up to 5 MB size can be uploaded, except Topo Map.</p> <p>b) CEA referred to ‘Software User Documentation for PTCC Portal’ issued by BSNL in January, 2016. First para at page-3 states submission of proposals along with maps for PTCC clearance. However, maps uploading facility has so far not been activated. CEA stated that Maps are like heart of PTCC proposal and without this online portal would only help in keeping track of the documents. BSNL was requested to address this issue expeditiously so that dependency of postal services is removed.</p> <p>c) Referring para-8.1 at page-8, where it is mentioned that at present private power authorities are not given any privilege to access this tool, CEA requested BSNL to clarify time limit for this. Referring para-3.4.1 at page-126 where it is mentioned that only CEA is authorized to register cases for 220kV and above lines of Private Power Authorities, CEA expressed its difficulties in implementing this. For example, information like details of concerned SDE (Telecom) and Railway zone tracks, which are within 8 KM periphery of the proposed power line are not known to CEA. Such information is available with the concerned power authority. CEA stated that uploading is a crucial activity and the responsibility of uploading of PTCC proposal should lie with the concerned power authority, they may seek assistance from anyone. It is similar to filing of income tax return where the responsibility lies with Tax Payer only. CEA informed that probably BSNL in this regard has taken strength from</p>	<p>a) Now APTRANSCO are able to upload the complete proposal containing Questionnaire, Soil Resistivity reading, EPR values along with covering letter (which is well within 5 MB) in the PTCC portal except the topo map.(Till date 46 cases were uploaded by APTRANSCO in the portal)</p> <p>(i) Workshops have been conducted in Eastern Zone, Western Zone & South Zone after the last CLPTCC meeting.</p> <p>(ii) Workshop was conducted at New Delhi on 31st March 2016 prior to last CLPTCC meeting.</p> <p>b) <u>Uploading of topo maps.</u> For many cases, (for which power line length is more) more than one map (in some cases 4 to 5 maps per case) covering 8 Kms on both sides of the entire stretch of the power line is involved. Moreover , the maps are not of uniform size. Hence the possibility of uploading the topo maps is to be studied in detail. This was also discussed in the meeting conducted with ITPC authorities on 3rd November 2016 , where in also inability of uploading the topo map was expressed.</p> <p>c) AGM (MM) O/o CGM Inspection & QA Circle, Jabalpur vide lr.no. TD/LP-2015/102nd CLPTCC meeting Dated at Jabalpur 29/08/2016 (vide Annexure-I) informed that “To avoid delay in processing the cases of Private Power Authority, it is approved by competent authority that concerned DE (PTCC) may process the cases off line as was done earlier, after scrutinizing by CEA. This will be for short period till version-2 of portal is developed. Later on these case will be registered by the web portal only”. Accordingly Power proposals from Private power authorities are being processed as OFFLINE cases. Development of</p>
-----	--	---

<p>clause 6.15 at page-21 of PTCC Manual. CEA clarified that processing of PTCC case of Private parties could still be done in CEA as far as checking of MOU/Agreement between Private parties and Central/State power transmission utilities is concerned; but it does not lead to responsibility of uploading of complete PTCC proposal. Representative from ITPC, BSNL, Hyderabad stated that in Version-2 of BSNL online portal, the private parties would be given privilege in the software tool for initiation of the power line PTCC proposal including uploading of documents, but their authenticity / genuineness will be verified by the CEA before they initiate the proposal.</p> <p>d) Besides above, CEA informed that it has been observed that the Server response time is large and it takes more time to open the file. No provision of giving remarks on the information received in CEA, has been observed, for example, if CEA wishes to give remark that Topomap has been received but markings are not proper. At present, CEA is also not able to upload IV comments on the portal. Director (PTCC), CEA stated that computation of IV comments depends on complete information from Power, BSNL, Railways and Defense. In case, any one is missing, the case can't be processed. Therefore, there should be provision in Portal to indicate the reason why case is pending in CEA. Shri K. Raji Reddy, JTO, A/T, BSNL, Hyderabad explained that currently there is limitation of file size of 5MB in PTCC portal, and they are proposing to enhance it to 25 MB in near future.</p> <p>e) CGM, BSNL, Jabalpur stated that concerns of all stakeholders including CEA would be addressed in due course. He agreed with the proposal of Workshops and instructed all DETs to coordinate with states under their Region and fix up the schedule for holding interactive Work shops inviting of members from Power, Railway, Defense and BSNL. He also instructed Shri Shivam Bansal, SDE, BSNL Northern Region to coordinate with CEA and resolve some of their portal related operational issues.</p>	<p>Version-2 of this application was discussed in the meeting with ITPC authority on 3-11-2016, for which minutes awaited. It was informed by ITPC authorities that version-2 is possible only after the upgradation of the server.</p> <p>d) Server response time can be improved, if the application is loaded on a high end server. Provision has been given for giving remarks by CEA on the information received by them and this will be enabled when uploading of IV comments on the portal by IV calculating authority is taken care in the next version..</p> <p>e) In South Zone, conducting work shop on “Operating the on line portal”, has been completed in Andhra Pradesh Circle at Hyderabad on 04-05-2016 and at Chennai on 24-08-2016. In Karnataka Circle at Bengaluru a demo on this portal was conducted during SLPTCC meeting held on 05.07.2016. East Zone- Bhuvaneshwar on 03-08-2016. (Vide Annexure-V) West Zone- Mumbai on 21-07-2016. (Vide Annexure-VI) North Zone: Workshop was conducted at New Delhi on 31st March 2016 prior to last CLPTCC meeting.</p>
--	---

Annexure SZ/1/1

SOUTH ZONE- COMPLIANCE OF Minutes of 102nd Central PTCC meeting held in Gangtok, Sikkim on 27th May, 2016

Item .No.	Item description	<u>South Zone compliance as on 17-09-2016</u>
B.1	<p><u>Ensuring 'Zero Level' on unguarded power crossings</u> All DETs (PTCC), BSNL informed that there were no unguarded power crossings in their respective zones. It was decided that all DETs would keep watch and if any unguarded power crossing case comes to their knowledge, they shall take suitable measures to guard the power crossing at the earliest. DETs may also inform CEA, if required. DETs shall update the status in next CLPTCC meeting.</p>	<p>As on 31/08/2016-UGPC is NIL. The status of the same is being updated in every South Zone-SLPTCC meeting.</p>
B.2	<p><u>Computerization of PTCC Route Approval Process</u> To improve PTCC online portal, views of stakeholders were sought. APTRANSCO informed that they were not able to upload the complete proposal in the PTCC portal, only covering note could be uploaded. RRVPNL informed about difficulties being faced in operating the portal and suggested that a workshop should be organized by BSNL for state power utilities in every State. OPTCL also raised the same issue and suggested for workshop in their State also. Railway representative also showed inability in operating the portal. Representative from ITPC, BSNL, Hyderabad stated that currently pdf format documents up to 5 MB size can be uploaded, except Topo Map.</p> <p>CEA referred to 'Software User Documentation for PTCC Portal' issued by BSNL in January, 2016. First para at page-3 states submission of proposals along with maps for PTCC clearance. However, maps uploading facility has so far not been activated. CEA stated that Maps are like heart of PTCC proposal and without this online portal would only help in keeping track of the documents. BSNL was requested to address this issue expeditiously so that dependency of postal services is removed. Referring para-8.1 at page-8, where it is mentioned that at present private power authorities are not given any privilege to access this tool, CEA requested BSNL to clarify time limit for this. Referring para-3.4.1 at page-126 where it is mentioned that only CEA is authorized to register cases for 220kV and above lines of Private Power Authorities, CEA expressed its difficulties in</p>	<p>1) AGM (MM) O/o CGM Inspection & QA Circle, Jabalpur vide Ir.no. TD/LP-2015/102nd CLPTCC meeting Dated at Jabalpur 29/08/2016 informed that "To avoid delay in processing the cases of Private Power Authority, it is approved by competent authority that concerned DE (PTCC) may be process the cases off line as was done earlier, after scrutinizing by CEA. This will be for short period till version-2 of portal is developed. Later on these case will be registered by the web portal only". Accordingly Power proposals from Private power authorities are being processed as OFFLINE cases.</p> <p>2) In South Zone, conducting work shop on "Operating the on line portal", has been completed in Andhra Pradesh Circle at Hyderabad and in Karnataka Circle at Bengaluru. Workshop was conducted in Tamilnadu Circle at Chennai on 24th August 2016, minutes of which has already been communicated vide this office Ir.no. SR-PTCC/CM/2013-17/157 dtd. 27/08/2016 to all concerned.</p> <p>3) Development of Version-2 of this application will be explored after a meeting with ITPC authority.</p>

implementing this. For example, information like details of concerned SDE (Telecom) and Railway zone tracks, which are within 8 KM periphery of the proposed power line are not known to CEA. Such information is available with the concerned power authority. CEA stated that uploading is a crucial activity and the responsibility of uploading of PTCC proposal should lie with the concerned power authority, they may seek assistance from anyone. It is similar to filing of income tax return where the responsibility lies with Tax Payer only. CEA informed that probably BSNL in this regard has taken strength from clause 6.15 at page-21 of PTCC Manual. CEA clarified that processing of PTCC case of Private parties could still be done in CEA as far as checking of MOU/Agreement between Private parties and Central/State power transmission utilities is concerned; but it does not lead to responsibility of uploading of complete PTCC proposal.

Representative from ITPC, BSNL, Hyderabad stated that in Version-2 of BSNL online portal, the private parties would be given privilege in the software tool for initiation of the power line PTCC proposal including uploading of documents, but their authenticity / genuineness will be verified by the CEA before they initiate the proposal.

Besides above, CEA informed that it has been observed that the Server response time is large and it takes more time to open the file. No provision of giving remarks on the information received in CEA, has been observed, for example, if CEA wishes to give remark that Topomap has been received but markings are not proper. At present, CEA is also not able to upload IV comments on the portal.

Director (PTCC), CEA stated that computation of IV comments depends on complete information from Power, BSNL, Railways and Defense. In case, any one is missing, the case can't be processed. Therefore, there should be provision in Portal to indicate the reason why case is pending in CEA.

Shri K. Raji Reddy, JTO, A/T, BSNL, Hyderabad explained that currently there is limitation of file size of 5MB in PTCC portal, and they are proposing to enhance it to 25 MB in near future.

CGM, BSNL, Jabalpur stated that concerns of all stakeholders including CEA would be addressed in due course. He agreed with the proposal of Workshops and instructed all DETs to coordinate with states under their Region and fix up the

	<p>schedule for holding interactive Work shops inviting of members from Power, Railway, Defense and BSNL. He also instructed Shri Shivam Bansal, SDE, BSNL Northern Region to coordinate with CEA and resolve some of their portal related operational issues.</p>	
B.3	<p><u>SLPTCC meetings</u></p> <p>In the last meeting, it was decided that SDE (PTCC) of the respective circles shall keep informed CEA regarding defaulting power utilities for not holding SLPTCC meetings so that CEA could take up the matter with such utilities.</p> <p>All DETs (PTCC), BSNL have provided information and it was observed that SLPTCC meetings are being held regularly except Haryana, Punjab and UP (East & West) in Northern region.</p> <p>In regard to State Level PTCC, CEA referred page-157 of PTCC Manual where constitution of SLPTCC is given. In line with CLPTCC, SLPTCC has also GM (Telecom) of concerned Telecom Circle, BSNL and Chief Engineer (Transmission) of concerned SEB's/State Power Transmission Corporation as Chairman in alternate years.</p> <p>It was decided that year wise roaster for conducting SLPTCC meetings should be prepared jointly by concerned BSNL and Power authority in the State and who so ever is responsible for holding quarterly SLPTCC meetings in that particular year, should convene the meetings. In case the roaster is not followed and SLPTCC meetings are not convened then the other authority either BSNL or Power would take up the matter with the concerned authority, if required by writing 2-3 letters. In case even then there is no outcome and SLPTCC meetings are not convened then the matter should be brought to the notice of BSNL/Jabalpur and CEA. The matter should also be brought to CLPTCC forum.</p>	<p>Regarding year wise roaster for conducting SLPTCC meeting this office has addressed letters to both Member Power SLPTCC and Member Telecom SLPTCC of South Zone vide this office Ir.no. SR-PTCC/CM/2013-17/141 dtd. 18/07/2016. (Email sent on 19/7/2016). Reply yet to be received from all Member Power & Member Telecom SLPTCC. The roaster such received will be communicated in due course.</p>
B.4	<p><u>Nomination of members from DISCOMs for SLPTCC meetings</u></p> <p>DETs (PTCC), BSNL, Eastern, Western, Southern & Northern Region have provided information on this issue and it was observed that nomination of members from DISCOMs for SLPTCC meetings are being received. However, it was decided that in case nominations from some DISCOMs remain pending then GM (Telecom Circle), BSNL of the respective states should take up the matter with those DISCOMs, if required by writing 2-3 letters. In the absence of response, the</p>	<p>No defaulting DISCOMs in south Zone</p>

	<p>matter should be brought to the knowledge of CEA with copies of previous communications.</p>	
B.5	<p><u>Non submission of PTCC proposal of SLPTCC/CLPTCC by PTCUL</u></p> <p>(i) Charging of transmission lines without PTCC Route Approval</p> <p>DET, PTCC, BSNL, Northern Region informed that out of thirteen cases, RAC has been issued for one case. Twelve cases are under process with concerned SDEs (PTCC), BSNL for marking of their telecom details.</p> <p>(ii) Other cases of non-submission of PTCC Proposals</p> <p>DET, BSNL, PTCC, Northern Region informed that Haryana, UP, HP, J&K and DISCOMs of Delhi are not submitting the power proposals for PTCC clearance.</p> <p>The matter was deliberated and it was observed that BSNL may find out if any power authority is charging their lines without PTCC clearance. If so, BSNL may communicate CEA the details of such lines. CEA shall take up the matter with concerned state's Secretary (Energy); as has been done earlier.</p>	<p>(i) & (ii) Not pertains to South Zone & hence No comments</p>
B.6	<p><u>Alternate Protection in place of GD Tubes:</u></p> <p>GD tube protection is required for affected Telecom cable. In 100th CLPTCC meeting, BSNL had informed that their field units are facing difficulty in mounting a lot of GD tubes in shorter span of underground cable. After detailed deliberations, it was decided that a Sub-Committee comprising of representatives from PGCIL / State Power Utilities, BSNL and CEA may be formed, for arriving at a solution for protection to telecom assets. The Committee comprises Sh. V Ganesan DGM A/T, Inspection Circle, Chennai, as Convener; Sh. NareshBhandari, Director (PTCC), CEA, and Sh. S Balakumar, Chief Manager, Powergrid, Vadodara, as Members.</p> <p>The Sub-Committee Members had discussion on 29.09.2015 at Chennai. It was noted that in case number of locations of GD tubes as recommended in PTCC Manual 2010 is more than two i.e. at MDF (Main Distribution Frame) and Pillar only then difficulties are being experienced and one of the options is to erect dummy pillars to provide GD tubes. Various other options like change of copper cable with OFC, re-routing of telecom cable, shifting of power line in the affected span, earthing of screen of PIJF cable at an interval of 50 m etc. were discussed. At the end of the meeting, it was agreed that one member from Railways,</p>	<p>DGM A/T Inspection Circle, Chennai has communicated the information collected from RTEC to all the members of Sub committee on 21/07/2016. The next Sub committee meeting is proposed during the first week of November 2016 and report will be submitted before the meeting.</p>

	<p>preferably from RDSO (Research Designs & Standards Organization), and one member from TEC (Tele-communication Engineering Centre), DOT, preferably from RTEC (SR), Bengaluru, may be co-opted. BSNL was also requested to collect following information:</p> <ul style="list-style-type: none"> (i) Withstand capability of metallic screen of PIJF cable in respect of electromagnetic induction occurring from faulty power line. (ii) What would be extent of electromagnetic induction passing through the metallic screen of PIJF cable? (iii) To confirm that screening factor of 0.5 from PIJF cable is on account of outer screening in the PIJF cable, relevant to the enclosed telecom copper conductor. (iv) Induced Voltage withstand capability of Telecom Copper Conductor. (v) Technical specification and diagram of GD tubes and IPM. (vi) Technical Specification and cross-section of PIJF cable being used in BSNL. (vii) Recommendations of TEC, DOT, on how to tackle high induced voltage on underground PIJF cable. <p>The details of nominated members from RDSO and RTEC (SR) have now been received.</p> <p>The matter was discussed and it was decided that BSNL would information pertaining to above stated points to all the members of the Sub-Committee. BSNL may also convene meeting to discuss and resolve the issue. CEA stated that since it is a safety related matter, it should be expedited, as one year has already elapsed. CGM, Inspection Circle, BSNL instructed DGM, BSNL, Chennai to quickly take up the issue and resolve it by 31st July 2016.</p>	
B.7	<p><u>Kerala SEB case regarding EPR values</u></p> <p>In the last meeting, matter in respect of EPR values for 220kV line from 400kV Mannukad substation to 220kV Kanjikkode substation was deliberated. BSNL brought out agenda for fixing of limits for EPR zone values. it was decided in the last meeting that a Sub-Committee be formed consisting of members from Railway, Power Grid, BSNL and CEA to resolve the issue.</p> <p>The Sub-Committee had discussions on 25/04/16 & 09/05/16. The Sub-Committee recommended that for calculation of EPR zone distance, single phase to ground (SLG) fault current should be considered. The</p>	<p>Minutes of the 102nd CLPTCC meeting has been forwarded to all concerned power authority of South Zone for further action by them.</p>

	<p>Sub-Committee noted the similar views from Western Region Power Transmission Utilities, expressed during SLPTCC meeting, as intimated by DET, BSNL, Western Region.</p> <p>CLPTCC endorsed the decision of Sub-Committee that Single Line to Ground (SLG) Fault Current shall be considered by the Power Authority to calculate Earth Potential Rise (EPR) Zone Distance (in meter). Item closed</p>	
<p>B.8</p>	<p><u>Nomination of Member (POWER) from APTRANSCO and TSTRANSCO</u></p> <p>In the last meeting, it was informed that due to recent bifurcation of Andhra Pradesh State into two States as Telangana and Andhra Pradesh, two separate Electricity utilities are functioning as APTRANSCO and TSTRANSCO with headquarters at Hyderabad. From Andhra Pradesh, proposals for clearance of EHT (Extra High Tension) lines are being submitted by Chief Engineers of APTRANSCO from Hyderabad i.e. Chief Engineer 400 KV SS, Chief Engineer Lift Irrigation, Chief Engineer Construction-I, Chief Engineer Construction-II, etc. The proposals from TSTRANSCO are being submitted by Chief Engineer, TSTRANSCO/Hyderabad. It was suggested that a nodal officer may be nominated as Member (Power), SLPTCC from each Utility, authorizing them to forward and process all the Power line PTCC cases for better coordination.</p> <p>CEA informed that nominations from APTRANSCO and TSTRANSCO have been received and communicated to BSNL. Item closed</p>	<p>Nomination from APTRANSCO TSTRANSCO have been received in this office.</p> <p>Also it is informed that still from Andhra Pradesh, proposals for clearance of EHT (Extra High Tension) lines are being submitted by Chief Engineers of APTRANSCO from Hyderabad i.e. Chief Engineer 400 KV SS, Chief Engineer Lift Irrigation, Chief Engineer Construction-I, Chief Engineer Construction-II, etc. The proposals from TSTRANSCO are being submitted by Chief Engineer, TSTRANSCO/Hyderabad. It is requested that necessary action may be taken with APTRANSCO to forward and process all the Power line PTCC cases from Member Power (SLPTCC) for better coordination.</p>
<p>B.9</p>	<p><u>Non-submission of proposal / telecommunication details from Defense</u></p> <p>It was informed by Defense representative in the last meeting that all long route telecom cables of Defense are OFC. However, garrison areas have U/G copper cable. Defense representative confirmed that marking of Defense Telecom circuits on the topo maps will be done, if power proposals are sent by power transmission utilities.</p> <p>Therefore, Power proposals are being sent to Director General (Signals), Defense, Army Head Quarters, New Delhi, by power transmission utilities. CEA confirmed that replies from Defense are being received; but sometimes they are late. Defense representative informed that to expedite</p>	<p>In South Zone-Region-wise control centers and the details from Defence authority yet to be received.</p>

	<p>PTCC clearance, it has been decided to decentralize the process and form region-wise control centers and the details in this regard would be communicated soon.</p> <p align="center">(Action: Defense Authority)</p>	
B.10	<p><u>Pending Energization Certificate – Kerala SEB Transmission Line</u></p> <p>The energization certificate for 220kV D/C line from 220kV SS Pothencode to 220kV SS Kattakkada is pending from BSNL side. In the last meeting, CGM, Inspection Circle, Jabalpur stated that this issue would be taken up with field office of BSNL at Chennai for early issue of energization certificate.</p> <p>BSNL informed that 220kVD/C line from 220kV SS Pothencode to 220kV SS Kattakkada, RAC issued on 01/05/2015 by DET, PTCC, BSNL, Chennai. He further informed that energization Approval is pending from Kerala Circle. The matter was also discussed in the last SLPTCC meeting. TVM SSA to raise Demand Note for Protection Work. SDE (PTCC) Inspection & QA Circle of Trivandrum visited SDE (PTCC) TVM SSA on 27/04/2016 and constantly pursuing the case. It was intimated by BSNL of Trivandrum SSA that some pillars recommended for protection in the RAC are not matching with existing pillars in Pothencode and hence they will be giving revised telecom details in fresh map for further process.</p> <p>CLPTCC discussed the issue and opined that delay in Energization Approval demoralizes Power Utilities and purpose of issuing RAC is also defeated. As in this case, there has been delay of more than one year in issuing Energization Approval. CEA proposed that after issue of RAC, if power authority, based on demand note issued by BSNL, deposit required payment then power authority should be allowed to charge the line. Issue of Energization approval is internal matter of BSNL and for that power authority should not suffer. Otherwise also, for cases where induced voltage falls in the range 430 V to 650 V and protection cost is to be borne by BSNL, power authority charge its line without wait for Energization approval from BSNL.</p> <p>CEA also proposed that when demand note is raised by BSNL or Railways or Defense; and the power authority deposits the required amount then it becomes incumbent for the receiver – in this case BSNL or Railways to furnish Utilization Certificate for the amount received. CGM agreed with the proposal and opined that instead of asking for past details, this process could be commenced from year 2016 onwards. It was also agreed that this would be standing Agenda in every CLPTCC meeting.</p> <p align="center">(Action: BSNL, Railways, Defense)</p>	<p>Estimate for protection work issued by Trivandrum SSA to KSEB Trivandrum for an amount of Rs. 13,26,028/- on 09/09/2016. KSEB to make payment.</p> <p>Regarding Utilization Certificate a letter has been addressed to Member Telecom SLPTCC of South Zone to follow the guidelines given in minutes of 102nd CLPTCC meeting and requested to submit the Fund utilization certificate to Member Power SLPTCC for the pending cases for which Energisation certificate is to be issued from 2016 onwards from this office vide lr.no. SR-PTCC/CM/2013-17/142 dtd. 18/07/2016 (Email sent on 19/07/2016).</p>

Annexure – SZ/2

South Zone-DETAILS OF SLPTCC MEETING CONDUCTED from 01.01.2016 to Till date

SL.	Name of the Circle	SLPTCC MEETING CONDUCTED ON	Venue
1	ANDHRA PRADESH	23.02.2016	Hyderabad
		03.08.2016	Hyderabad
	TELENGANA	23.02.2016	Hyderabad
		03.08.2016	Hyderabad
2	KERALA	24.02.2016	Trivandrum
		28.07.2016	Trivandrum
		11.11.2016	Thrissur
3	KARNATAKA	05.07.2016	Bangalore
4	TAMILNADU	26.04.2016	Chennai
		28.09.2016	Chennai

Annexure - SZ/3

BHARAT SANCHAR NIGAM LIMITED

INSPECTION CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange
1st Floor, No.26, Sardhar Patel Road, Guindy, Chennai-32.
Phone 04422355550 email:deptccchi@gmail.com

To

1. Member Power SLPTCC
Andhra Pradesh/Telungana/Karnataka/Kerala/Tamilnadu
Hyderabad/Bengaluru/Trivandrum/Chennai
2. Member Telecom SLPTCC
Andhra Pradesh/Telungana/Karnataka/Kerala/Tamilnadu
Hyderabad/Bengaluru/Trivandrum/Chennai

No:SR-PTCC/CM/2013-17/141

dtd. @ CNI-32 the 18/07/2016

Sub :Follow up Action of 102nd CLPTCC-SLPTCC meeting-reg

Ref:Director (PTCC),CEA/New Delhi office lr.no. CEA/PCD/102nd CLPTCC/356
dtd. 27/06/2016

As per the decision of 102nd CLPTCC meeting held on 27/05/2016, the year wise roaster for conducting SLPTCC meetings may be prepared jointly by concerned BSNL and Power authority in each state and sent to this office at the earliest. A copy of letter received from CEA/New Delhi is enclosed herewith for further process.

Encl a/a

Hevil
19/07/2016.
Divisional Engineer Telecom PTCC,
Inspection Circle, Southern Region
Chennai - 32.

Copy to:

1. Director (PTCC), CEA/New Delhi.
2. AGM (PTCC) Insp. & QA Circle, Jabalpur
3. SDEs PTCC Insp. & QA Circle for n/a

Annexure - SZ/4

Reminder

BHARAT SANCHAR NIGAM LIMITED
INSPECTION & QA CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange
1st Floor, No.26, Sardhar Patel Road, Guindy, Chennai-32.
Phone 04422355550 email:deptocchi@gmail.com

To

1. Member Power SLPTCC
Andhra Pradesh/Telungana/Karnataka/Kerala/Tamilnadu
Hyderabad/Bengaluru/Trivandrum/Chennai
2. Member Telecom SLPTCC
Andhra Pradesh/Telungana/Karnataka/Kerala/Tamilnadu
Hyderabad/Bengaluru/Trivandrum/Chennai


No:SR-PTCC/CM/2013-17/168

Dtd. @ CNI-32 the 26/10/2016

Sub: Follow up Action of 102nd CLPTCC-SLPTCC meeting-reg

- Ref: (1) Director (PTCC),CEA/New Delhi office lr.no. CEA/PCD/102nd CLPTCC/356
dtd. 27/06/2016
(2) This office lr.no. SR-PTCC/CM/2013-17/141 Dtd. 18/07/2016

Kindly refer to the letters under reference above. As per the decision of 102nd CLPTCC meeting held on 27/05/2016, the year wise roaster for conducting SLPTCC meetings is requested from this office vide letter Under ref.(2) above. The same may be prepared jointly by concerned BSNL and Power authority in each state and sent to this office at the earliest.


26/10/2016
Divisional Engineer Telecom PTCC,
Inspection & QA Circle, Southern Region
Chennai - 32.

Copy to:

1. Director (PTCC), CEA/New Delhi.
2. AGM (PTCC) Insp. & QA Circle, Jabalpur
3. SDEs PTCC Insp. & QA Circle for n/a

KARNATAKA POWER TRANSMISSION CORPORATION LIMITED

Phone: Off. 22267034
22384279
Fax. Off. 22282287



Office of the
Chief Engineer Electricity,
State Load Despatch Centre,
28, R. C. Cross Road,
Bangalore - 560 009

Date: 8/4/15

No. CEE/SLDC/PTCC/Nomination/- 286
(Encl: as in letter)

To,
The Divisional Engineer (Telecom),
PTCC, T&D Circle, BSNL, # 26, 1st Floor,
Raj Bhavan Telephone Exchange,
Sardar Patel Road, Guindy,
CHENNAI - 600 032.



Sir,

Sub: Nomination from DISCOMS to attend SLPTCC meeting.-Reg.
Ref: Y.O.Ltr. No. SR-PTCC/CM/2013-15/64 DT. 01.04.2015.

* * * *

With reference to the above, the list of nominees from five ESCOMS for attending the SLPTCC meeting are as shown below, namely.,

Sl.No.	Name of the ESCOM	Nominee
1.	BESCOM	The Member Secretary, SLPTCC, & The General Manager (P & M), B.E.S.COM, Corporate Office, K.R. Circle, BANGALORE-560 001.
2.	CESCOM	The Member Secretary, SLPTCC & The General Manager (Tech), Chamundi Electric Supply Company, # 927, L.J. Avenue, New Kantharaj Urs Road, Saraswathipuram, MYSORE-570 009.
3.	MESCOM	The Member Secretary, SLPTCC, & The Chief Engineer (El), Mangalore Zone, Mangalore Electric Supply Company Limited, MANGALORE.
4.	HESCOM	The Member Secretary, SLPTCC, & The Executive Engineer (El), (Tech), Hubli Electric Supply Company, Corporate Office, Navanagar, HUBLI - 25.
5.	GESCOM	The Member Secretary, SLPTCC, & The Superintending Engineer Ele, (M I S), Corporate Office, G.E.S.COM, Station Road, GULBARGA-585 102.

This is for your kind information and further needful.


Yours faithfully,

Member (Power) SLPTCC &
Chief Engineer Electricity,
SLDC, KPTCL, Bangalore- 9.

Annexure -SZ16

TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED
VIDYUT SOUDHA :: HYDERABAD

From
Chief Engineer/Construction,
APTRANSCO,
Vidyut Soudha,
Hyderabad - 500 082



To
The Divisional Engineer(Telecom)
(PTCC),
Southern Region,
Chennai-32

Lr.No.CE/Constn./ADE/T/E-CEA-PTCC/D.No. 56 /2015, Dt. 23.05.2015.

Sir,

Sub: APTransco - Nominations from DISCOMS for attending SLPTCC meeting- Reg.

Ref: SR-PTCC/CM/2013-15/64 Dtd at Chennai -32 the 1st April,2015.

With reference to the above, It is to inform there are two DISCOMs are present in Andhra Pradesh and nominations from each DISCOM for attending the SLPTCC meeting is as follows.

SNO	Name of the DISCOM	Naminee
1	APEPDCL	Chief General Manager(O&CS) Corporate office, APEPDCL, Visakhapatnam Mobile : 9440812567 Office :0891-2582200
2	APSPDCL	Chief General Manager(Operation), Corporate Office,APSPDCL Tirupathi Mobile : 9493174300

This is for favour of information and further necessary action.

Yours faithfully,



CHIEF ENGINEER
CONSTRUCTION

Copy communicated to
The Chief General Manager(O&CS)
Corporate office, APEPDCL, Visakhapatnam

The Chief General Manager(Operation),
Corporate Office,APSPDCL,Tirupathi

Annexure - SZ/7

2016/10/21
703



PTCC Section,
% CGM Telecom, BSNL,
Telangana Circle,
R.No.904, Door Sanchar Bhavan,
Abids, Hyderabad- 500 001
Tel. No. 2320 1567

IndiaBroadband
LIVING WITH SPEED

भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)

BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. TA/PTCC/34-91/2015 - 2016/06.

Dated : 21-10-2016.

To

The Divisional Engineer Telecom.,
PTCC, South Zone,
1st Floor, Raj Bhavan Exchange,
No. 26, S.P. Road, Guindy,
CHENNAI - 600 032.

Madam,

SUB: Compliance on the Minutes of 102nd CLPTCC Meeting - Reg.

REF: Lr. No. CEA/PCD/102 CLPTCC/2016/916, dated 09.05.2016

N/A/P

With reference to the above cited minutes, the compliance on Salient points pertaining to A.P. &

Telangana Circles is furnished herewith :

Point No. B.4 : This office invited Members of all DISCOMS in A.P. & TS to attend the 3rd SLPTCC Meeting held on 03.08.2016.

All Members attended. Two Members from the two DISCOMS in Telangana State (TSNPDCL, TSSPDCL) have been nominated in the SLPTCC.

Point No. B.5 II: No such instance is reported from the field.

Pending Cases: All pending cases were discussed in the 3rd SLPTCC meeting held on 03.08.2016 and minutes forwarded to all concerned.

This is for information please.

[Handwritten Signature]

Asst. General Manager (USO & PTCC),
O/o C.G.M. Telecom., Telangana Circle,
Hyderabad - 1.

Anneature -SZ/8

KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Indian Companies Act, 1956)
(Registered office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram 695 004)

Office of the Chief Engineer, Transmission South

Vidyuthi Bhavanam, Pattom Thiruvananthapuram 695 004	KSIEB	Telephone: +91-471-2446471 Fax: +91-471-2514460 Email: cets@ksebn.net.com
---	--------------	---

No. DCE(TS)/EE1-AEE3/PTCC/15-16/ 02

Dated: 06.04. 2015

To

The Divisional Engineer(Telecom)

PTCC, Southern Region,

Raj Bhavan Telephone Exchange

First Floor, No. 26, Sardar Patel Road, Guindy, Chennai- 600 032.

Sub: Follow up action on the minutes of the 99th CLPTCC meeting on Item B.S - reg.


Ref: Your letter no. SR-PTCC/CM/2013-15/64 dtd at Chennai-32 the 1st April 2015

With reference to the above, I hereby inform that eight distribution licencees are working in Kerala in addition to Kerala State Electricity Board Limited. Among the above eight licencees three licencees are utilizing public space for distribution network. The details eight licencees are as follow.

1. Kannan Devan Hill Plantation Ltd, Munnar
2. Thrissur Municipal Corporation, Thrissur
3. Cochin Port Trust Limited
4. Technopark, Kazhakkuttam, Trivandrum
5. Cochin Special Economic Zone, Eranakulam
6. KINESCO Power Utilities(P) Ltd (KINFRA PARK), Eranakulam
7. Infopark, Cherthala & Kakkanad
8. Smart City, Eranakulam

The first three licencees listed above are using public space for distribution network. This is for your information, please.

Thanking you,
Yours faithfully



R. Radhakrishnan

Deputy Chief Engineer(Tech) &
Member(Power)- PTCC

Copy to: Sub Divisional Engineer(PTCC)
BSNL, Trivandrum

Annexure - SZ/9

TAMILNADU TRANSMISSION CORPORATION LTD.,

From

Er.N.Krishnasami, B.E.,
Chief Engineer/Transmission,
6th Floor, NPKRR Maaligai,
144, Anna Salai,
Chennai - 600 002.

To

The Divisional Engineer,
PTCC / Southern Region,
Raj Bhavan Telephone Exchange,
I Floor, 26, Sardar Patel Road,
Guindy, Chennai - 32.

Lr.No. CE/TR/SE/TR-I/EW/A1/ PTCC GI./D.No. 367 /15, dated: 15 .04.2015.

Sir,

Sub: Minutes of the 99th Central PTCC meeting held at Jabalpur on 27.11.14 -
Item No. B - 8 - Nomination from DISCOMS - Reg

Ref: Lr. No. SR-PTCC/CM/2013-15/64 dt 01.04.2015.

Referring to the letter cited, it is informed that at present TANGEDCO is the only
Distribution Licensee in the State and there are no DISCOMS operating in the State at
present.


13/4/2015
2/2
Superintending Engineer/Transmission -I
For Chief Engineer/ Transmission

Annexure - SZ/10



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

Office of the Chief General Manager
NWO-CFA Cell
Kerala Circle, PMG Jn., Trivandrum-695033
Phone: 0471-2303434.

To

The DE PTCC,
Inspection & QA Circle,
Chennai.

No.OP/PTCC/ 2011-16/ 14

Dated at Trivandrum the 31-10-2016.


Sub: - Year wise roaster for conducting SLPTCC meeting 2016-17-reg.

Ref: - SR-PTCC/CM/ 2013-17/ 168 Dtd @CNI-32 the 26/10/2016.

With reference to the letter cited above, the proposed dates for conducting SLPTCC meeting in Kerala Circle for the year 2016-17 are

1. 11-11-2016 to be conducted by BSNL.
2. 16-02-2017 to be conducted by KSEB.

One SLPTCC meeting conducted on 28-07-2016 by KSEB at Trivandrum.


DGM (NWO-CFA),
O/o CGMT, Kerala Circle, 31/10/16
Trivandrum.

Copy to: SDE PTCC, Inspection Circle, TVM.

OFFICE OF DY.G.M. A/T,
INSPECTION (T&D) CIRCLE, BSNL
RAJBHAVAN TELE.EXGE BLDG
26 SARDAR PATEL ROAD
GUINDY CHENNAI 600032
Ph: 22300011 FAX 22354884



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. DGM AT/PTCC/XII/17

dated at Chennai-32 the 05.11.2016.

Sub: Committee meeting on provisioning of GD Tubes on Telecom Network-Reg.
Ref: Minutes of the meeting No: DGM AT/PTCC/XI/107 dated 09.10.2015.

As per the Minutes of Meeting of the 100th CLPTCC meeting and having reference to CGM Inspection Circle, Jabalpur letter No: TD/LP-2015/100th CLPTCC meeting dated 06.07.2015, it is proposed to conduct a meeting at Chennai at the chamber of Dy.General Manager A/T, Chennai on 17th November 2016, for discussions regarding examining and provisioning of GD Tubes on Telecom underground cable network. The following members are requested to attend the meeting.

- 1). Shri.Naresh Bhandari Director (PTCC), CEA, New Delhi
- 2). Shri.S.Balakumar Chief Manager, Power Grid, Vadodara
- 3) Smt.Chitra Suresh DET PTCC, Inspection Circle Chennai.
- 4) Shri. P.V.S.R.C. Murthy ADG, RTEC (SR) Bengaluru.
- 5) Shri.Yaspal Singh Tomar Director Telecom 3, Lucknow.

V. Ganesan
V. GANESAN 5/11/2016
Dy. General Manager
1st Floor, Raj Bhavan Tele Exchange,
26, Sardar Patel Road,
Guindy, Chennai-600 032.

Copy to:

1. CGM Inspection & QA Circle Jabalpur
2. Shri.Naresh Bhandari Director, CEA, New Delhi
3. Shri.S.Balakumar Chief Manager PGCIL, Vadodara
4. Smt.Chitra Suresh DET PTCC, Chennai.
5. Shri. P.V.S.R.C.Murthy, ADG, RTEC (SR) Bengaluru.
6. Shri.Yaspal Singh Tomar, Director Telecom 3, Lucknow.

ANNEXURE – NZ/1

DET(PTCC), Northern Zone,
Inspection & QA Circle,
CTS Compound, Netaji Nagar,
New Delhi-110023
Phone-011- 26113815



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. PTCC/NZ/CLPTCC/2016-17

dated at ND the 10.11.2016

To,
AGM(PTCC)
Inspection & QA Circle, Jabalpur

Sub: **Revised Compliance on 102nd CLPTCC meeting minutes and Agenda for 103rd CLPTCC.**

The compliance on the 102nd CLPTCC minutes pertaining to this unit is as given below:

No.	Item	Compliance from DE PTCC NZ																		
A	<u>Confirmation of Minutes of previous meeting</u>	Confirmed																		
B.1	<u>Ensuring 'Zero Level' on unguarded power crossings</u>	No such case reported from territorial circle of Northern Zone to DE PTCC NZ																		
B.2 B.2	<u>Computerization of PTCC Route Approval Process</u> Organization of workshops	Workshop in NZ is planned on 17.11.2016 in New Delhi and notice for the same is already served.																		
(B.3)	<u>SLPTCC meetings</u>	<p>In FY16-17: the status of SLPTCC meeting held is as under:</p> <table border="1"><tbody><tr><td>RAJ</td><td>1</td></tr><tr><td>HARYANA</td><td>0</td></tr><tr><td>PUNJAB</td><td>0</td></tr><tr><td>HIMACHAL</td><td>0</td></tr><tr><td>J&K</td><td>0</td></tr><tr><td>DELHI</td><td>1</td></tr><tr><td>UP(W)</td><td>0</td></tr><tr><td>UP(E)</td><td>0</td></tr><tr><td>UTR</td><td>1</td></tr></tbody></table> <p>Roster of SLPTCC i.r.o. Delhi was finalized and circulated through MOM of SLPTCC. Next SLPTCC of Rajasthan is scheduled in this month and Roster will be finalized during the meeting. For rest circle status is yet to be received from SDE(PTCC), Lucknow/Ambala.</p>	RAJ	1	HARYANA	0	PUNJAB	0	HIMACHAL	0	J&K	0	DELHI	1	UP(W)	0	UP(E)	0	UTR	1
RAJ	1																			
HARYANA	0																			
PUNJAB	0																			
HIMACHAL	0																			
J&K	0																			
DELHI	1																			
UP(W)	0																			
UP(E)	0																			
UTR	1																			
(B.4)	<u>Nomination of members from DISCOMs for SLPTCC meetings:</u>	Instructions being followed. The nominations have been received for the states where SLPTCC meeting is being conducted(as mentioned above																		

ANNEXURE – NZ/1

		against B3)
(B.5)	<u>Non submission of PTCC proposal of SLPTCC/CLPTCC by PTUCL</u>	Marking of telecom/railway details is in process for 12 cases. Latest status is yet to be received from SDE(PTCC), Lucknow
(B.6)	<u>Alternate Protection in place of GD Tubes:</u>	Not pertaining to NZ.
B.7	Non submission of proposal/ telecommunication details from Defence	To be clarified by Defense.
D	New Agenda points	Instructions will be followed.
D.1	Improper submission of BSNL details	
D2	Provisional PTCC RAC in emergency	This proposal may be accepted
D3	On the spot verification of data	May be decided during meeting
D4	RAC issued from BSNL	Not pertaining to NZ.


The new agenda may be taken as **NIL**.

DET (PTCC) ND

Copy to:

1. Director (PTCC), PCD Division, CEA, New Delhi.
2. Addl GM, Inspection & QA Circle, Chandigarh.
3. GM (North), Inspection & QA Circle, New Delhi.

O/o PTCC (Northern Zone),
Inspection Circle, CTS Compound,
Netaji Nagar,
New Delhi-110023
Phone-011- 26113815



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No: DE(PTCC)/NZ/Workshop/2016-17/

Dated at ND the 04.11.2016

Sub: Digitization of PTCC process through PTCC portal.

In accordance with the subject cited above, it is to intimate you that PTCC portal for digitization of PTCC cases as per requirement of Project monitoring Group of Cabinet Secretariat of PMO has already launched by Inspection & QA Circle, BSNL. A workshop on step by step working of this PTCC portal as discussed in 102nd CLPTCC meeting is scheduled to be held on 17.11.2016 from 11:00AM onwards in the seminar hall of NCNGN Circle, BSNL, CTS Compound, Netaji Nagar, New Delhi.

It is requested to attend/nominate the officer for the said workshop.

DE (PTCC)

Inspection Circle, New Delhi.

Mob: 09868243318

Email id: deptccnd@gmail.com.

To

1. The Chief Engineer, PCD, CEA, New Delhi.
2. The Chief Engineer HVPNL, Panchkula.
3. The Chief Engineer PSTCL/PSPCL, Patiala.
4. The Chief Engineer PITCUL, Dehradun.
5. The Chief Engineer UPPCL, Lucknow.
6. The Chief Engineer RRVPNL, Jaipur.
7. The Chief Engineer DTL, New Delhi.
8. The Chief Engineer, WUPPTCL, Ghaziabad.
9. The ED, DMRC, New Delhi.
10. The Chief Engineer, PDD, Jammu.
11. The Chief Engineer, PGCIL, Jammu.
12. The Chief Engineer, PGCIL, Varanasi.
13. The GM(S & T), NR, New Delhi.
14. The GM(S & T), NWR, Jaipur.
15. The GM(S & T), NCR, Jabalpur.
16. The GM(S & T), NER, Gorakpur.
17. The DG (Signals), DHQ PO, New Delhi.
18. PS to The CGM, BSNL Territorial Circle, Jammu/Ambala/Chandigarh/Jaipur/Meerut/Lucknow/Dehradun/Shimla.
19. DGM (P& D), MTNL, New Delhi
20. SDE(PTCC), Inspection & QA Circle, Ambala/Jaipur/Lucknow.
21. Sh. K.Raji Reddy, JTO, Inspection & QA circle, Hyderabad

Copy To:

1. PGM(South), Inspection & QA circle, Bangalore.
2. GM(North), Inspection & QA circle, New Delhi.
3. AGM (PTCC), Inspection & QA circle, Jabalpur.

ANNEXURE- EZ/1

O/o DET(PTCC), Eastern Zone,
Inspection & QA Circle,
Burrabazar Telephone Kendra(2nd Floor)
148 C R Ave, Kolkata-700 007
Email-detptccer@gmail.com
Mob: 9433400096, Land no.22413724.



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

PTCC-ER/102 CLPTCC/2016-17/08

Dated at Kolkata 29.10.2016

To

The AGM/PTCC,
Inspection & QA circle,
Jabalpur.

Sub:- Compliance /follow up action of MOM 102 nd CLPTCC meeting.(Eastern Zone)

Ref:- 1)Your letter no.TD/LP-2015/102nd CLPTCC meeting dtd. 02.09.2016.

2) Director PTCC ,NewDelhi letter no.CEA/PCD/102nd CLPTCC dtd.28.07.2016

Sir,

With ref. to cited above letter no. the compliance & follow up action of MOM 102 nd CLPTCC meeting are mentioned below-

Ref.Sl.no.	Headings	Remarks
B1	Ensuring 'Zero Level' on unguarded power crossings	Every month the report is received from each Telecom circle.(unguarded power crossing=0)
B2	Computerization of PTCC Route Approval Process	Workshop of eastern zone was held in Bhubaneswar on 3 rd August' 16.
B3	SLPTCC meetings	Action is already been taken. In 2016, 4 nos. SLPTCC meetings were held by BSNL in Patna, Bhubaneswar, Kolkata and Guwahati. * Another SLPTCC meeting of West Bengal is going to be held on 08.11.2016. It is decided that on rotation basis year wise SLPTCC meeting will be conducted by BSNL and POWER Grid .In the year 2017, SLPTCC meeting will be conducted by POWER Grid. In 2016 total 5 nos. SLPTCC meeting are going to be completed by BSNL.

ANNEXURE- EZ/1

O/o DET(PTCC), Eastern Zone,
Inspection & QA Circle,
Burrabazar Telephone Kendra(2nd Floor)
148 C R Ave, Kolkata-700 007
Email-detptccer@gmail.com
Mob: 9433400096, Land no.22413724.



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

B4	Nomination of members from DISCOMs for SLPTCC meetings	<p>Several letters were given to state utilities (1.DET/PTCC-ER/DISCOM/15-16/01,dtd.11.3.16 2. DET/PTCC-ER/DISCOM/16-17/01,dtd.14.6.2016, 3. DET/PTCC-ER/DISCOM/16-17/03,dtd.25.7.16. 4. DET/PTCC-ER/DISCOM/16-17/04 datd 03.09.2016) Only 1.DVC, 2. Power Grid (ER-II,Kolkata), 3. Power Grid, NE Transmission system had replied mentioning the DISCOM member's names. The letters from rest of the units not received. (Every corresponding letter was given to Director PTCC,NewDelhi) * The letter copies are enclosed herewith .</p>

ANNEXURE- EZ/1

O/o DET(PTCC), Eastern Zone,
Inspection & QA Circle,
Burrabazar Telephone Kendra(2nd Floor)
148 C R Ave, Kolkata-700 007
Email-detptccer@gmail.com
Mob: 9433400096, Land no.22413724.



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

C6	PendingPTCC Cases in Eastern Region	
1	220 KV LILO LINE AT NAMRUP FROM TINSUKIA TO NTPS EXISTING LINE	Clearance certificate issued on 6/6/16
2	400KV DC LINE FROM LATEHAR TO PATRTU	Clearance certificate issued on 5/5/2016
3	220KV DC LINE FROM GOBINDPUR TO DUMKA	Pending with CEA for Defense
4	400KV DC LINE FROM KHARAGPUR TO CHAIBASA	Clearance certificate issued on 5/5/2016
5	400KV DC LINE FROM LATEHAR(ESSAR) TO LATEHAR(JSEB)	Pending with CEA for Railway details
6	200KV DC LINE FROM TTPS TP GOVINDPUR SS	Clearance certificate issued on 16.8.2016
7	400KV DC LINE FROM PATRATU TO BERO	Pending with CEA for Defense
8	220KV DC LINE FROM GOLA TO RANCHI SS	Pending with CEA for Defense
9	220 KV D/C 3 PHASE CHANDRAPURA (CTPS) OF DVC TO MAIN RECEIVING STATION OF BSL (SAIL)	Certificate issued on 24.5.16
10	400KV DC LINE FROM PURULIA TO RANCHI TRANSMISSION LINE	Certificate issued on 16.6.2016
11	220KV DC LINE PARADIP TO MRSS AT M/S ESSAR STEEL LTD.	Latest status of IV report n/a in DET/PTCC, Kolkata office
12	220KV LILO LINE ON DC TOWER FROM BUDHIPADA- TARKHERA LINE TO PROPOSED 220/132/33KV SS KUANRMUNDA	Latest status of IV report n/a in DET/PTCC, Kolkata office
13	765KV DC TRANS LINE FROM ANGUL TO JHARSUGUDA	Pending with CEA for Railway details
14	765KV DC LINE FROM JHARSUGUDA PS TO DHARAMJAYGARH EAST COAST NCC POWER PROJECT	Pending with CEA for Railway details
15	765KV DC TRANS LINE FROM ANGUL PS- SRIKAKULAM PS	Certificate issued on 13/7/2016
16	220 KV DC TRANS. LINE FROM DOMJUR TO HOWRAH	Latest status of IV report from CEA n/a in DET/PTCC, Kolkata office
17	LILO LINE OF 400 KV SUBHASHGAEH – JEERAT TR. LINE AT RAJGHAT GIS	Certificate issued on 4/5/2016
18	400KV DC TRANS. LINE FROM HALDIA TO SUBHASHGRAM	Pending with CEA for Defense
19	220 KV D/C TR. LINE FROM KAGATHANG to PGCIL S/S at LEGSHIP (SAGBARI)	Certificate issued on 8/7/2016
D1	220KV D/C Benapanjari of PGCIL s/s to Puri (samangara) s/s Line	Telecom survey will be conducted in October' 16
D1	400kV D/C line from New Duburi Grid s/s to MRSS of M/s Tata Steel Limited	Sent to CEA for IV calculation on 30.4.2016.

**The Pending cases as on 25.10.2016 in eastern zone are mentioned below-
(Details are mentioned in the separate attachment)**

ANNEXURE- EZ/1

O/o DET(PTCC), Eastern Zone,
Inspection & QA Circle,
Burrabazar Telephone Kendra(2nd Floor)
148 C R Ave, Kolkata-700 007
Email-detptccer@gmail.com
Mob: 9433400096, Land no.22413724.



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

CLPTCC Pending cases status AS ON 25.10.2016

Sl.no.	STATES	CLPTCC PTCC clearance Certificates issued 2016-17	Pending for BSNL survey	Pending for IV calculation reports not received from CEA	TOTAL CLPTCC PENDING CASES
1	Assam	1	0	0	0
2	Bihar	2	4	0	4
3	Jharkhand	5	3	5	8
4	Orissa	1	5	5	10
5	West Bengal	3	4	4	8
6	NE-I	0	0	0	0
7	NE-II	0	0	0	0
	REGION TOTAL	12	16	14	30

ANNEXURE- EZ/1

O/o DET(PTCC), Eastern Zone,
Inspection & QA Circle,
Burrabazar Telephone Kendra(2nd Floor)
148 C R Ave, Kolkata-700 007
Email-detptccer@gmail.com
Mob: 9433400096, Land no.22413724.



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

SLPTCC Pending cases Status AS ON 25.10.2016

Sl.no.	STATES	SLPTCC clearance Certificates issued 2016-17	Pending for BSNL survey	Pending for IV calculation reports not received from STATE ELECTRICITY BOARD	TOTAL SLPTCC PENDING CASES
1	Assam	1	0	1	1
2	Bihar	0	0	0	0
3	Jharkhand	4	2	0	2
4	Orissa	0	4	9	13
5	West Bengal	0	1	1	2
	NE-I	0	0	0	0
	NE-II	0	0	0	0
	REGION TOTAL	5	7	11	18

Note * :- Out of pending 48 cases , 8 were offered through online.

AGENDA FOR 103 rd CLPTCC meeting

NIL



DE/PTCC(ER),

INSPECTION & QA circle,Kolkata



No.DET/PTCC-ER/DISCOM/16-17/04

Dated. 03.09.2016

To

- 1)The Chief Engineer Trans project,WBSETCL, Kolkata .
- 2) The G.M.,OPTCL, Bhubaneswar,
- 3) The DGM,Engg.Eastern region Transmission I, Power Grid, Patna.
- 4) The DGM(Engg),North East Regional Transmission system, POWER GRID, Shillong.
- 5) The AGM,AEGCL,Guwahati
- 6) The G.M.,OPTCL, Bhubaneswar,

Subject- Nomination of DISCOM members.

Ref : My previous letters :- 1) DET/PTCC-ER/DISCOM/15-16/01 dated 11.03.2016
2) DET/PTCC-ER/DISCOM/16-17/02 dated 15.06.2016
3) DET/PTCC-ER/DISCOM/16-17/03 dated 25.07.2016

Sir,

This is to inform you , in this year 2016 4 SLPTCC meetings were held by BSNL in Patna(Bihar circle) on 17/2/2016, Kolkata (WestBengal circle) on 27/02/2016, Guwahati (Assam &NE) on 22/03/2016 and Bhubaneswar (Odissa circle) on 8/03/2016.

Although, it was informed earlier before the each meeting to all concerned power Distribution companies *of that concerned circle*, but unfortunately nobody (except AEGCL) from the power distribution companies has attended the meetings. It is requested to send the representative of the concerned power distribution company of that concerned zone to attend the meeting.

Earlier, it is also requested to send the name and contact nos. of the DISCOM members of the companies to the unit of DET/PTCC(ER),Kolkata by email

(detptccer@gmail.com). It is to be noted that it is the 4 th reminder in this year to you.

Now, again it is requested to send the name of DISCOM MEMBERS of your unit to the undersigned by email to the address detptccer@gmail.com .

* it is to be noted that nomination letters of DISCOM MEMBERS from DVC and Power Grid(ER-II),Kolkata have already been received by the undersigned.

Thanking you,

Copy to-

- | | |
|--|-------------------------|
| 1) The Director,PTCC ,CEA, New Delhi | DET/PTCC(ER), |
| 2) The DGM/AT,Inspection circle,Kolkata, | Inspection & QA circle, |
| 3)The AGM/PTCC,Inspection circle Jabalpur. | Kolkata. |

Encl:- Nomination letters received from DVC & Power Grid(ER-II),Kolkata.



No.DET/PTCC-ER/DISCOM/16-17/01

Dated. 14.06.2016

To

- 1)The Chief Engineer Trans project, WBSETCL, Kolkata .
- 2) The G.M.,OPTCL, Bhubaneswar,
- 3) The Executive Director Project , DVC, Kolkata,
- 4) The DGM,Engg.Eastern region Transmission II, Power Grid, Kolkata
- 5) The DGM,Engg.Eastern region Transmission I, 7) The AGM,AEGCL,Guwahati Power Grid, Patna.
- 6) The DGM(Engg),North East Regional Transmission system, POWER GRID, Shillong.

Subject- Nomination of DISCOM members.

Ref:- My earlier letter no.DET/PTCC-ER/DISCOM/15-16/01Dated 11.03.2016

Sir,

With ref. to above this is another reminder regarding the information of DISCOM members.

In the last 102nd all India CLPTCC meeting held at GANGTOK also, the same point has been risen regarding non receipt of the lists of DISCOM members of the power utilities of Eastren jone by the DET/PTCC(ER),Kolkata.

Earlier, it is also requested to send the name and contact nos. of the DISCOM members of the companies to the unit of DET/PTCC(ER),Kolkata by email(detptccer@gmail.com).

Now, again it is requested to you to send the name of DISCOM MEMBERS of your unit to the undersigned by email to the address of detptccer@gmail.com

Thanking you,

Copy to-

- 1) The Director,PTCC ,CEA, New Delhi for talking n/a.
- 2) The AGM/PTCC,Inspection circle Jabalpur.

For and on behalf of
Central P.T.C.C.

D.E.T (PTCC), E/Region,
Inspection circle, BSNL, Kolkata.



No.DET/PTCC-ER/DISCOM/16-17/03

Dated .25.07.2016

- 1)The Chief Engineer Trans project, WBSETCL, Kolkata .
- 2) The G.M.,OPTCL, Bhubaneswar,
- 3) The DGM,Engg.Eastern region Transmission II, Power Grid, Kolkata
- 4) The DGM,Engg.Eastern region Transmission I, Power Grid, Patna.
- 5) The AGM,AEGCL,Guwahati
- 6) The DGM(Engg),North East Regional Transmission system, POWER GRID, Shillong.

Subject- Nomination of DISCOM members.

Ref:- My earlier letter no.DET/PTCC-ER/DISCOM/16-17/01Dated 14.06.2016

Sir,

With vide ref. no. above this is another reminder regarding the information of DISCOM members. In the last 102nd all India CLPTCC meeting held at GANGTOK also, the same point has been risen regarding non receipt of the lists of DISCOM members of the power utilities of Eastren jone by the DET/PTCC(ER),Kolkata.

Earlier, it is also requested to send the name and contact nos. of the DISCOM members of the companies to the unit of DET/PTCC(ER),Kolkata by email(detptccer@gmail.com).

This is to inform you that only DVC has nominated one member and informed formally to the undersigned.

Now, again it is requested to you to send the name of DISCOM MEMBERS of your unit to the undersigned by email to the address of detptccer@gmail.com

Thanking you,

DET/PTCC(ER),
INSPECTION AND QA CIRCLE,
KOLKATA

Copy to-

- 1) The Director,PTCC ,CEA, New Delhi for talking n/a.
- 2) The AGM/PTCC,Inspection circle Jabalpur.

Inspection & QA Circle,
Burrabazar Telephone Kendra(2nd Floor)
148 C R Ave, Kolkata-700 007
Email-detptccer@gmail.com
Mob: 9433400096, Land no.22413724.



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

PTCC-ER/102 CLPTCC/2016-17/10

Dated at Kolkata 08.11.2016

To

The AGM/PTCC,
Inspection & QA circle,
Jabalpur.

Sub:- Comments on new agenda.

With ref. to cited above letter no. the compliance & follow up action of MOM 102 nd CLPTCC meeting are mentioned below-

D. New agenda points:

D.1 Improper Submission of BSNL telecom Details

It is observed that DETs of some region are directly forwarding BSNL telecom details which they receive from SDEs to CEA. Sometimes it is seen that the marking of BSNL telecom cables is not done or are not clear. Also the Telecom cable details are missing or illegible. It created difficulty in computation of Induced Voltage calculation. In this regard a letter dated 25/07/2016 has been sent to all DETs requesting to submit BSNL telecom details in proper format (a copy enclosed at annexure). Still some cases were observed where the details are forwarded without scrutinizing them.

Comments of DET/PTCC(ER)- NIL

D.2 Provisional PTCC Route Approval Certificate in emergency

Government has accorded high priority for construction of Power Transmission lines. As the installed power is increasing, so the power evacuating transmission lines are also increasing accordingly. To fulfill the deadlines and to harness the benefits of early completion of projects, Power authorities in some cases are constructing the power transmission lines in less than 6 months from the date of sanctioning of project. PTCC Route approval process may take more than 6 months. In such a scenario Power utilities face hardship. To take care of such scenarios and to meet any emergencies, Provisional PTCC Route approval may be issued on case to case basis. Chief Engineer, PCD, CEA may certify for the issuance of Provisional PTCC RAC after taking an undertaking from the power authority that the power authority would take care of any eventuality due to induction on BSNL, Railway and Defense Telecom cables and that all required compliances would be submitted within 30 days.

Comments of DET/PTCC(ER)- NIL

Inspection & QA Circle,
Burrabazar Telephone Kendra(2nd Floor)
148 C R Ave, Kolkata-700 007
Email-detptccer@gmail.com
Mob: 9433400096, Land no.22413724.



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
 BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

D.3 On the spot verification of Data submitted by Power authority, BSNL and Railway authorities

CEA Induced Voltage calculations are based on the data submitted by Power, BSNL and Railway Authorities. It is observed in some cases that the data/Documents submitted by power authority are not in concurrence with our previous records. Details submitted by BSNL/Railway authorities are also improper. This necessitates on the spot verification by CEA for ensuring BSNL/Railway Telecom circuits safety.

Comments of DET/PTCC(ER)- NIL.

D.4 RAC issued from BSNL

CEA observed that in the past Provisional/Final RACs were issued without comments from CEA. PTCC Route Approval for 400 kV D/C dedicated line from Coastal Energen Power Plant to 765/400 kV Tuticorin Pooling station was issued without final comments on Defense NOC from CEA.

Comments of DET/PTCC(ER)- N/A

• Workshop of digitalization of PTCC portal (EASTERN ZONE)-

The workshop was held in Bhubaneswar on 3rd August'2016. The following power utility

Representatives were present-

- 1.) OPTCL Odissa,
- 2.) POWER GRID (ER-II),Kolkata,
- 3.) POWER GRID Odissa,
- 4.) POWER GRID (N.E.ZONE),Shillong
- 5.) D.V.C(Government of India undertaking)
- 6.) AEGCL, Guwahati.

• Defaulters in DISCOM (Eastern Zone)

- 1) Power Grid (ER-I),Patna,
- 2) OPTCL, Bhubaneswar,
- 3) AEGCL,Guwahati,
- 4) WBSETCL,Kolkata
- 5) Jharkhand state electricity Board
- 6) Bihar state electricity board

DET/PTCC(ER),Kolkata

O/o DET(PTCC), Inspection circle,
3rd Floor, D-Wing, BSNL Admin Bldg.
Juhu Tara Road, Santacruz (West)
MUMBAI-400 054.
Email-detptccmbi@gmail.com
Tele no.022-26611530



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

BSNL 3G)))) **BSNL LIVE**
Faster than your thoughts **2010**

NO. - IC/ MBI / PTCC / CLPTCC/46

Dated at Mumbai the 29.10.2016

To

The A.G.M.(MM)
O/o C.G.M., Inspection & QA Circle
Jabalpur-1.

Sub : Compliance on Minutes of 102nd Central PTCC meeting held in Gangtok, Sikkim on 27th May, 2016.


Ref. : 1) Your office letter no.TD/LP-2015/102ND CLPTCC meeting Date 02.09.2016.

2) Chief Engineer (PCD) ,CEA, New Delhi office letter no. CEA/PCD/103 CLPTCC Meeting / 2016 / date 28.10.2016.

Please find herewith the Compliance on Minutes of 102nd Central PTCC meeting held in Gangtok, Sikkim on 27th May, 2016.

Sr. No	Agenda Item	Compliance on agenda point																																													
B.1	Ensuring 'Zero Level' on unguarded power crossings	Monthly report sent Nil as on date.																																													
B.2	Computerization of PTCC Route Approval Process	PTCC portal live on Feb.2016. Workshop on PTCC portal conducted in Mumbai on 21.07.2016 as per CLPTCC meeting held on 27.05.2016.Further more workshop will be conducted if portal hardware upgraded to server level(work in progress)																																													
B.3	SLPTCC meetings	Roster is being prepared for west zone. SLPTCC meetings are being conducted at regular interval in West zone. <table border="1"> <thead> <tr> <th>Sr.No.</th> <th>Name of Circle</th> <th>Place of Meeting</th> <th>Date of Meeting</th> <th>Meeting conveyed by</th> </tr> </thead> <tbody> <tr> <td>1</td> <td rowspan="3">Maharashtra</td> <td>Satara</td> <td>18.05.2016</td> <td>BSNL</td> </tr> <tr> <td>2</td> <td>Mumbai</td> <td>21.07.2016</td> <td>MSETCL, HO, Mumbai (PTCC workshop)</td> </tr> <tr> <td>3</td> <td>Pune</td> <td>23.09.2016</td> <td>MSEICL</td> </tr> <tr> <td>4</td> <td rowspan="2">Madhya Pradesh</td> <td>Jabalpur</td> <td>17.03.2016</td> <td>MPPTCL</td> </tr> <tr> <td>5</td> <td>Gwalior</td> <td>24.09.2016</td> <td>BSNL</td> </tr> <tr> <td>6</td> <td rowspan="2">Chhatisgarh</td> <td>Raipur</td> <td>06.05.2016</td> <td>CSPTCL</td> </tr> <tr> <td>7</td> <td>Bilaspur</td> <td>10.11.2016</td> <td>BSNL (Proposed)</td> </tr> <tr> <td>8</td> <td rowspan="2">Gujrat</td> <td>Jamnagar</td> <td>22.08.16</td> <td>GETCO,BSNL ,Jamnag</td> </tr> <tr> <td>9</td> <td>Ahmedabad</td> <td>21.10.2016</td> <td>GMTD,BSNL,Ahmedab</td> </tr> </tbody> </table>	Sr.No.	Name of Circle	Place of Meeting	Date of Meeting	Meeting conveyed by	1	Maharashtra	Satara	18.05.2016	BSNL	2	Mumbai	21.07.2016	MSETCL, HO, Mumbai (PTCC workshop)	3	Pune	23.09.2016	MSEICL	4	Madhya Pradesh	Jabalpur	17.03.2016	MPPTCL	5	Gwalior	24.09.2016	BSNL	6	Chhatisgarh	Raipur	06.05.2016	CSPTCL	7	Bilaspur	10.11.2016	BSNL (Proposed)	8	Gujrat	Jamnagar	22.08.16	GETCO,BSNL ,Jamnag	9	Ahmedabad	21.10.2016	GMTD,BSNL,Ahmedab
Sr.No.	Name of Circle	Place of Meeting	Date of Meeting	Meeting conveyed by																																											
1	Maharashtra	Satara	18.05.2016	BSNL																																											
2		Mumbai	21.07.2016	MSETCL, HO, Mumbai (PTCC workshop)																																											
3		Pune	23.09.2016	MSEICL																																											
4	Madhya Pradesh	Jabalpur	17.03.2016	MPPTCL																																											
5		Gwalior	24.09.2016	BSNL																																											
6	Chhatisgarh	Raipur	06.05.2016	CSPTCL																																											
7		Bilaspur	10.11.2016	BSNL (Proposed)																																											
8	Gujrat	Jamnagar	22.08.16	GETCO,BSNL ,Jamnag																																											
9		Ahmedabad	21.10.2016	GMTD,BSNL,Ahmedab																																											
B.4	Nomination of members from DISCOMs for SLPTCC meetings	Not applicable since Discoms are attending the SLPTCC meeting regularly. Already discussed in CLPTCC meeting.																																													

B.5	Non submission of PTCC proposal of SLPTCC / CLPTCC by PTCUL	
i	Charging of transmission lines without PTCC Route Approval	Not applicable to West Zone, Mumbai.
ii	Other cases of non-submission of PTCC Proposals	Not applicable to West Zone, Mumbai.
B.6	Alternate Protection in place of GD Tubes:	Point pertaining to Honorable CEA office, New Delhi.
B.7	Kerala SEB case regarding EPR values	Not applicable to West Zone, Mumbai.
D	New Agenda	
D.1	Improper submission of BSNL Telecom detail	As far as western region is concerned It is not applicable since proposals are duly scrutinized before forwarding to CEA office . All concerned SDE(PTCC) are following the procedure.
D.2	Provisional PTCC route approval certificate in emergency	There is no delay . However west zone if asked ready to give provisional RAC with information / approval of competent authority.
D.3	On the spot verification of Data submitted by power authority, BSNL, & Railway authorities	Not applicable to West Zone, Mumbai.
D.4	RAC issued from BSNL	Not applicable to West Zone, Mumbai.


 मंडळ २९/११/२०१६
 पीटीसी, मुंबई
 Divisional Engineer
 PTCC, Mumbai-16.

Copy to Director(PCD), CEA, New Delhi-16.For kind information please.

O/o DET(PTCC), Inspection circle,
3rd Floor, D-Wing, BSNL Admin Bldg.
Juhu Tara Road, Santacruz (West)
MUMBAI-400 054.
Email-d-etptccmbi@gmail.com
Tele no.022-26611530



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

BSNL 3G))) BSNL LIVE
Faster than your thoughts 2010

NO. - IC/ MBI / PTCC / CLPTCC/46

Dated at Mumbai the 29.10.2016

To
The A.G.M.(PTCC)
O/o C.G.M., Inspection & QA Circle
Jabalpur-1.

Sub : Follow up action of 102nd CLPTCC – SLPTCC meeting .Ref. Director (PTC), CEA, New Delhi office letter no. CEA/PCD/102ND CLPTCC/ 1356-1360 Date 27.06.2016

As per 102ND CLPTCC meeting held at Gangtok on 27th May 201, It was decided to prepare the calendar / Roaster for SLPTCC meeting scheduled to be held during calendar / Financier year 2016-17. Minutes has been circulated to all JTO/SDE working MH/MP/CG/Gujarat Accordingly calendar/ Schedule has been prepared by concerned JTO/SDE in consultation with BSNL/Power authority for West Zone.

SLPTCC meeting are conducted regularly as per page-157 of PTCC Manual 2010.

SLPTCC meeting held in DET(PTCC), Western Zone, Mumbai since 01.03.16 to 15.11.16				
Sr. No.	Name of Circle	Place of Meeting	Date of Meeting	Meeting conveyed by
1	Maharashtra	Satara	18.05.2016	BSNL
2		Mumbai	21.07.2016	MSETCL, HO, Mumbai (PTCC workshop)
3		Pune	23.09.2016	MSETCL
4	Madhya Pradesh	Jabalpur	17.03.2016	MPPTCL
5		Gwalior	24.09.2016	BSNL
6	Chhatisgarh	Raipur	06.05.2016	CSPTCL
7		Bilaspur	10.11.2016	BSNL (Proposed)
8	Gujrat	Jamnagar	22.08.16	GETCO,BSNL ,Jamnagar
9		Ahmedabad	21.10.2016	GMTD,BSNL, Ahmedabad

DET(PTCC)
Mumbai-54

मंडळ अभियंता
पीटीसी, मुंबई-५४.
Divisional Engineer
PTCC, Mumbai-54.

O/o DET(PTCC), Inspection circle,
3rd Floor, D-Wing, BSNL Admin Bldg.
Juhu Tara Road, Santacruz (West)
MUMBAI-400 054.
Email-detptccmbi@gmail.com
Tele no.022-26611530



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

BSNL 3G))) BSNL LIVE
Faster than your thoughts 2010

NO. - IC/ MBI / PTCC / CLPTCC/46

Dated at Mumbai the 29.10.2016

To
The A.G.M.(PTCC)
O/o C.G.M., Inspection & QA Circle
Jabalpur-1.

Sub : Follow up action of 102nd CLPTCC –Organization of workshops .

Ref. Director (PTC), CEA, New Delhi office letter no. CEA/PCD/102ND CLPTCC/ 1361 -1365 Date 23.06.2016

As discussed in 102ND CLPTCC meeting held at Gangtok on 27th May 2016, Workshop on PTCC portal was conducted with live demo on 21.07.2016 in the Conference Hall, O/o Chief Engineer (Project Schemes),MSETCL, Bandra(E),Mumbai -4000051.

Following organization has been invited / attended the said workshop viz MSETCL ,MSEDCL, Konkan Railway, Western railway, Central Railway, PGCIL Kalyan & Vadodara ,BSNL .

PTCC portal initiative / working has been appreciated by external authorities also. Further due discussion has been held with G.M. (West) honorable A.K. Jha sir along with Shri. Reddy JTO A/T Hyderabad .

Right now portal can be utilized for offline monitoring purpose only, unless hardware upgraded to server.

DET(PTCC)
Mumbai-54

मंडळ अभियंता
विभागीय, पुणे-५४.
Divisional Engineer
PTCC, Mumbai-54.

O/o DET(PTCC), Inspection circle,
3rd Floor, D-Wing, BSNL Admin Bldg.
Juhu Tara Road, Santacruz (West)
MUMBAI-400 054.
Email-detptccmbi@gmail.com
Tele no.022-26611530



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

BSNL 3G))) BSNL LIVE
Faster than your thoughts 2010

NO. - IC/ MBI / PTCC / CLPTCC/46

Dated at Mumbai the 29.10.2016


To
The A.G.M.(PTCC)
O/o C.G.M., Inspection & QA Circle
Jabalpur-1.

Sub : Follow up action of 102nd CLPTCC – Defense .

Ref. Director (PTC), CEA, New Delhi office letter no. CEA/PCD/102ND CLPTCC/ 1428 -1429 Date 30.06.2016

As discussed in 102ND CLPTCC meeting held at Gangtok on 27th May 2016, defense representative has attended the said meeting & to expedite the PTCC cases , decentralization process of PTCC clearance & formation of regional module is being considered by representative of defense authority . After deliberation, defense authority in principally agreed to post state wise / region wise officer for expediting PTCC clearances.

Honorable CEA authority should deliberate this point since action is pending.


DET(PTCC)
Mumbai-54

मंडल अभियंता
पैलिडी, मुंबई- ५४.
Divisional Engineer
PTCC, Mumbai-54.

Annexure-wz/5

O/o DET(PTCC), Inspection circle,
3rd Floor, D-Wing , BSNL Admin Bldg.
Juhu Tara Road, Santacruz (West)
MUMBAI-400 054.
Email-detptccmbi@gmail.com
Tele no.022-26611530



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

BSNL 3G))) BSNL LIVE
Faster than your thoughts 2010

NO. - IC/ MBI / PTCC / CLPTCC/46

Dated at Mumbai the 29.10.2016


To
The A.G.M.(PTCC)
O/o C.G.M., Inspection & QA Circle
Jabalpur-1.

Sub : Follow up action of 102nd CLPTCC .

Ref. Director (PTC), CEA, New Delhi office letter no. CEA/PCD/102ND CLPTCC/ 1408 -1412 Date 30.06.2016

If induced voltage is in between 430- 650 volts , protection equipment cost is to be beard by BSNL .How ever beyond 650 Volts , concerned power authority has to bear the cost of protection equipment .So concerned division will submit the demand note & after payment RAC is being issued .

As far as west zone is concerned it has dealt with so many cases & no delay .This letter is not applicable to west zone .How ever order given by CEA office is strictly adhered by this office for co existence


DET(PTCC)
Mumbai-54

मंडल अभियंता
दिविजन, मुंबई-५४.
Divisional Engineer
PTCC, Mumbai-54.

O/o DET(PTCC), Inspection circle,
3rd Floor, D-Wing, BSNL Admin Bldg.
Juhu Tara Road, Santacruz (West)
MUMBAI-400 054.
Email-detptccmbi@gmail.com
Tele no.022-26611530



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

BSNL **3G**))) BSNL **LIVE**
Faster than your thoughts 2010

NO. - IC/ MBI / PTCC / CLPTCC/46


Dated at Mumbai the 29.10.2016

To
The A.G.M.(PTCC)
O/o C.G.M., Inspection & QA Circle
Jabalpur-1.

Sub : Follow up action of 102nd CLPTCC – Nomination of members from DISCOMs for SLPTCC meeting .

Ref. Director (PTC), CEA, New Delhi office letter no. CEA/PCD/102ND CLPTCC/ 1351-1355 Date 27.06.2016

Discoms members are attending the meeting regularly as far as western zone is concerned .


DET(PTCC)
Mumbai-54

मंडल अभियंता
पीटीसी, मुंबई-५४.
Divisional Engineer
PTCC, Mumbai-54.

ANNEXURE – WZ/6/1

1) Maharashtra State DISCOM side

Following officers were present in the 179th SLPTCC meeting held at Pune on 23.09.2016.

Sl. No.	Name of the Officer	Designation	Mob. no.
1	Mrs. Kalpana Patil	E.E.(RE-III), O/o C.E.(Dist.) ,Head office, MSEDCL, Mumbai	9930626273
2	Shri.N.U.Raut	Dy.Ex.Eng. , O/o S.E., Circle Office, MSEDCL, Amravati	7875763671
3	Shri.M.J.Adhikari	A.E.,MSETCL, Pune	7030964860

2) Madhya Pradesh State DISCOM side

Sl. No.	Name of the officer	Designation	Phone no.
1	Shri. M.S.Atre	S.E, Central Zone Distribution Company	9425016000
2	Shri.Sanjay Arora	D.G.M.(East/ North)	9425805695
3	Shri.B.K.Goyal	S.E.(West/ North)	8989983833

3) Chhatisgarh State DISCOM side

Sl. No.	Name of the officer	Designation	Phone no.
1	Shri. M.D.Badgaiya	E.E, Distribution Company	9425219089

4) Gujrat State DISCOM side

Gujrat UGVCL

Sl. No.	Name of the officer	Designation	Phone no.
1	Shri.A.K.Mangal	Chief Engineer	9925212114

M.C. UGVCL

Sl. No.	Name of the officer	Designation	Phone no.
1	Shri.Megha Madav	Chief Engineer	9925208252

P. GVCL

Sl. No.	Name of the officer	Designation	Phone no.
1	Shri.U.P.Joshi	Executive Engineer	9925211691

CENTRAL ELECTRICITY AUTHORITY
Power Communication Development Division

CEA AGENDA FOR THE 103rd CENTRAL PTCC MEETING

Compliance of 102th Central PTCC meeting:

B.1 Ensuring 'Zero Level' on unguarded power crossings

In the last CLPTCC meeting, all DETs (PTCC), BSNL informed that there were no unguarded power crossings in their respective zones. It was decided that all DETs would keep watch of any unguarded power crossing case which comes to their knowledge and they would take suitable measures to guard the power crossing.

In the last CLPTCC meeting it was decided that DETs shall update the status in next CLPTCC meeting. In this regard all DETs may update the status.

B.2 Computerization of PTCC Route Approval Process

In the last CLPTCC meeting representative from ITPC, BSNL, Hyderabad stated that in Version-2 of BSNL online portal, the private parties would be given privilege in the software tool for initiation of the power line PTCC proposal including uploading of documents, but their authenticity / genuineness will be verified by the CEA before they initiate the proposal. Also it was informed that the current limitation of file size of 5 MB in PTCC portal would be enhanced to 25 MB in near future. **In this regard CEA has written a letter to Nodal officer of PTCC portal (a copy enclosed at Annexure – I) to kindly indicate tentative timelines for the upgradation and implementation of the suggested changes to the Online PTCC portal. No response is received till date.**

To address concerns of all stakeholders and to help familiarize with the working of PTCC portal, workshops were to be conducted by all DETs in their respective zones. In this regard a letter was sent to all DETs to conduct workshops inviting members from power, Railway, Defense, BSNL and CEA. **(A copy enclosed at Annexure – II)**. In the letter two actions were suggested towards better functioning of PTCC portal. Firstly, a demo icon showing a video with various steps involved in the submission of online PTCC case be created on the home page of PTCC portal and the other suggestion to keep “Progress of familiarization of PTCC Portal” agenda in every SLPTCC meeting.

Northern Zone has not conducted any meeting on PTCC portal.

BSNL may update the latest developments in PTCC route approval Portal and the implementation of actions suggested by CEA.

B.3 SLPTCC meetings

In the last CLPTCC meeting, it was decided that year wise roaster for conducting SLPTCC meetings should be prepared in each state jointly by BSNL and power authority and meetings be held quarterly. CEA in a letter to all DETs (a copy enclosed at **Annexure – III**) has requested to initiate action in this regard and inform CEA. In case the roaster is not followed and SLPTCC meetings are not convened then the matter should be brought to the notice of BSNL/Jabalpur and CEA. The matter should also be brought to CLPTCC forum.

All DETs may intimate any noncompliance regarding SLPTCC meetings.

B.4 Nomination of members from DISCOMs for SLPTCC meetings

In the last CLPTCC meeting, DETs (PTCC) of all zones have informed that nomination of members from DISCOMs for SLPTCC meetings are being received and that GM (Telecom Circle), BSNL would take up the matter with DISCOMs whose nominations are pending in their respective states. In the absence of response from DISCOMs, the matter should be brought to the knowledge of CEA with copies of previous communications.

In this regard CEA has written letters to all DETs (a copy enclosed at **Annexure – IV**) to submit the list of nominated members from DISCOMs for SLPTCC meetings which have already been received by DETs and the copies of communication done by GM (Telecom Circle), BSNL to the pending nominations from DISCOMs.

All DETs may submit their latest status of DISCOM members. Any communication done with DISCOMs in pursuance of nomination of members for SLPTCC meetings with no response from DISCOMs may also be submitted.

B.5 Non submission of PTCC proposal of SLPTCC/CLPTCC by PTCUL

(i) Charging of transmission lines without PTCC Route Approval

DET, PTCC, BSNL, Northern Region informed in the last CLPTCC meeting that 12.nos PTCUL post facto PTCC cases are under progress with concerned SDEs (PTCC), BSNL for marking of their telecom details.

CEA has written a letter to DET (Northern Zone), BSNL to expedite the process of marking and sent to CEA for further processing (a copy enclosed at **Annexure –V**). Still no response has been received.

DET (Northern Zone) may inform the latest status of these case.

(ii) Other cases of non-submission of PTCC Proposals

In the last CLPTCC meeting DET, BSNL, PTCC, Northern Region informed that Haryana, UP, HP, J&K and DISCOMs of Delhi are not submitting the power proposals for PTCC clearance.

The matter was deliberated and it was observed that BSNL may find out if any power authority is charging their lines without PTCC clearance. If so, BSNL may communicate CEA the details of such lines. CEA shall take up the matter with concerned state's Secretary (Energy); as has been done earlier.

Latest status may be informed.

B.6 Alternate Protection in place of GD Tubes:

GD tube protection is required for affected Telecom cable. In 100th CLPTCC meeting, BSNL had informed that their field units are facing difficulty in mounting a lot of GD tubes in shorter span of underground cable. After detailed deliberations, it was decided that a Sub-Committee comprising of representatives from PGCIL / State Power Utilities, BSNL and CEA may be formed, for arriving at a solution for protection to telecom assets. The Committee comprises Sh. V Ganesan DGM NT, Inspection Circle, Chennai, as Convener; Sh. Naresh Bhandari, Director (PTCC), CEA, and Sh. S Balakumar, Chief Manager, Powergrid, Vadodara, as Members.

The Sub-Committee Members had discussion on 29.09.2015 at Chennai. It was noted that in case number of locations of GD tubes as recommended in PTCC Manual 2010 is more than two i.e. at MDF (Main Distribution Frame) and Pillar only then difficulties are being experienced and one of the options is to erect dummy pillars to provide GD tubes. Various

other options like change of copper cable with OFC, re-routing of telecom cable, shifting of power line in the affected span, earthing of screen of PIJF cable at an interval of 50 m etc. were discussed. At the end of the meeting, it was agreed that one member from Railways, preferably from RDSO (Research Designs & Standards Organization), and one member from TEC (Tele-communication Engineering Centre), DOT, preferably from RTEC (SR), Bengaluru, may be co-opted. BSNL was also requested to collect following information:

- (i) Withstand capability of metallic screen of PIJF cable in respect of electromagnetic induction occurring from faulty power line.
- (ii) What would be extent of electromagnetic induction passing through the metallic screen of PIJF cable?
- (iii) To confirm that screening factor of 0.5 from PIJF cable is on account of outer screening in the PIJF cable, relevant to the enclosed telecom copper conductor.
- (iv) Induced Voltage withstand capability of Telecom Copper Conductor.
- (v) Technical specification and diagram of GD tubes and IPM.
- (vi) Technical Specification and cross-section of PIJF cable being used in BSNL.
- (vii) Recommendations of TEC, DOT, on how to tackle high induced voltage on underground PIJF cable.

The details of nominated members from RDSO and RTEC (SR) have now been received.

The matter was discussed and it was decided that BSNL would information pertaining to above stated points to all the members of the Sub-Committee. BSNL may also convene meeting to discuss and resolve the issue. CEA stated that since it is a safety related matter, it should be expedited, as one year has already elapsed. CGM, Inspection Circle, BSNL instructed DGM, BSNL, Chennai to quickly take up the issue and resolve it by 31st July 2016.

Information gathered from TEC, DOT regarding the above subject were sent to CEA vide letter dated 22/07/16. But till now there was no meeting conducted as decided in the last CLPTCC meeting.

B.7 Non-submission of proposal / telecommunication details from Defense

During last CLPTCC meeting Defense representative informed that to expedite Defense PTCC clearance, decentralization of the process of PTCC Clearance and formation of region-wise control centers and being considered

Kindly intimate any progress made in this regard.

D. New agenda points:

D.1 Improper Submission of BSNL telecom Details

It is observed that DETs of some region are directly forwarding BSNL telecom details which they receive from SDEs to CEA. Sometimes it is seen that the marking of BSNL telecom cables is not done or are not clear. Also the Telecom cable details are missing or illegible. It created difficulty in computation of Induced Voltage calculation. In this regard a letter dated 25/07/2016 has been sent to all DETs requesting to submit BSNL telecom details in proper format (a copy enclosed at annexure). Still some cases were observed where the details are forwarded without scrutinizing them.

D.2 Provisional PTCC Route Approval Certificate in emergency

Government has accorded high priority for construction of Power Transmission lines. As the installed power is increasing, so the power evacuating transmission lines are also increasing accordingly. To fulfill the deadlines and to harness the benefits of early completion of projects, Power authorities in some cases are constructing the power transmission lines in less than 6 months from the date of sanctioning of project. PTCC Route approval process may take more than 6 months. In such a scenario Power utilities face hardship. To take care of such scenarios and to meet any emergencies, Provisional PTCC Route approval may be issued on case to case basis. Chief Engineer, PCD, CEA may certify for the issuance of Provisional PTCC RAC after taking an undertaking from the power authority that the power authority would take care of any eventuality due to induction on BSNL, Railway and Defense Telecom cables and that all required compliances would be submitted within 30 days.

D.3 On the spot verification of Data submitted by Power authority, BSNL and Railway authorities

CEA Induced Voltage calculations are based on the data submitted by Power, BSNL and Railway Authorities. It is observed in some cases that the data/Documents submitted by power authority are not in concurrence with our previous records. Details submitted by BSNL/Railway authorities are also improper. This necessitates on the spot verification by CEA for ensuring BSNL/Railway Telecom circuits safety.

D.4 RAC issued from BSNL

CEA observed that in the past Provisional/Final RACs were issued without comments from CEA. PTCC Route Approval for 400 kV D/C dedicated line from Coastal Energen Power Plant to 765/400 kV Tuticorin Pooling station was issued without final comments on Defense NOC from CEA.

सांख्यिकी

16859952



केन्द्रीय विद्युत प्राधिकरण

ANNEX-1

Central Electricity Authority

पावर कम्युनिकेशन डवलप्मेंट डिविजन

Power Communication Development Division

एन आर पी सी परिसर शहीद जीत सिंह मार्ग ,कटवारिया सराय

NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai

नई दिल्ली-110016 New Delhi - 110 016



[ISO: 9001: 2008]

No. CEA/PCD/102nd CLPTCC/1381-1382

Date: 27-JUN-2016

Divisional Engineer (Telecom)

PTCC & Nodal Officer for PTCC Portal,
T&D circle, BSNL, #26, 1st floor
Raj Bhawan Telephone Exchange
Sardar Patel Road, Guindy
Chennai-600032

Subject: Follow up action of 102nd CLPTCC – Version-2 of PTCC Online Portal

During discussion held in the 102nd Central PTCC meeting at Gangtok on 27/5/2016, representative from ITPC, BSNL, Hyderabad stated that in Version-2 of BSNL online portal, the private parties would be given privilege in the software tool for initiation of the power line PTCC proposal including uploading of documents, but their authenticity / genuineness will be verified by the CEA before they initiate the proposal. It was also informed that currently there is limitation of file size of 5MB in PTCC portal, and they are proposing to enhance it to 25 MB in near future.

CEA had informed during discussion in the last CLPTCC meeting that the PTCC Portal Server response time is large and it takes more time to open the file. No provision of giving remarks on the information received in CEA, has been observed in the Portal, for example, if CEA wishes to give remark that Topomap has been received but markings are not proper. This provision is important because CEA's IV comments depends on complete information from Power, BSNL, Railways and Defense; and in case, any one is missing, the case can't be processed. Therefore, there should be provision in Portal to indicate the reason why case is pending in CEA. Further, it was informed that at present, CEA is also not able to upload IV comments on the Portal.

Kindly indicate the tentative timelines for the upgradation; and implementation of the above suggested changes to the PTCC Online Portal.

R.P. Pandey
o/c (R.P. Pandey)
Director (PTCC)

Copy for information to:

Chief General Manager, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur-482001 (Madhya Pradesh)



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट डिविजन
Power Communication Development Division
एन आर पी सी परिसर शहीद जीत सिंह मार्ग ,कटवारिया सराय
NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai
नई दिल्ली-110016 New Delhi - 110 016

संज्ञित

859952

ANNEX- II



[ISO: 9001: 2008]

No. CEA/PCD/102nd CLPTCC/1361-1365

Date: 23-JUN-2016

1. Divisional Engineer (Telecom)
PTCC, T&D circle, BSNL, #26, 1st floor
Raj Bhawan Telephone Exchange
Sardar Patel Road, Guindy
Chennai-600032

2. Divisional Engineer (Telecom),
PTCC, West Zone, BSNL
Inspection circle, 3rd Floor, 'D' Wing
BSNL, Administration Building,
Juhu Tara Road, Santacruz (West),
Mumbai-400054

3. Divisional Engineer (Telecom),
PTCC, Eastern Zone, Inspection circle,
BSNL, Burra Bazar, Telephone
Kendra, 3rd Floor, 148 Chhitaranjan
Avenue, Kolkata-700007

4. Divisional Engineer (Telecom),
PTCC, Northern Zone
Inspection circle, O/o GM (N),
CTS Compound, Netaji Nagar,
New Delhi-110023

Subject: Follow up action of 102nd CLPTCC – Organization of Workshops

In the 102nd Central PTCC meeting held at Gangtok on 27/5/2016, it was decided that all DETs would coordinate with the states under their respective Region; and fixup the schedule for holding interactive Workshops in regard to 'Online PTCC Portal', inviting members from Power, Railway, Defense, BSNL and CEA.

It is, therefore, requested that DETs may initiate organizing workshops and intimate CEA about their tentative programme. CEA representative would like to participate in each of the workshops.

Towards familiarization of PTCC Portal, two more actions are suggested. Firstly, a 'Demo' icon may be created on the home page of PTCC Portal; showing a video with various steps involved in submission of information on PTCC Portal. The other suggestion is that 'Progress of Familiarization of PTCC Portal' may be made as mandatory agenda item in every SLPTCC meeting. This would help in resolving issues on PTCC Portal, if any, at grass root level; and also help in fulfilling the ultimate goal of online PTCC portal.

R. P. Pandey

o/c (R.P. Pandey)
Director (PTCC)

Copy for information to:

Chief General Manager, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur-482001 (Madhya Pradesh)



केन्द्रीय विद्युत प्राधिकरण

ANNEX - III

Central Electricity Authority

पावर कम्युनिकेशन डवलपमेंट डिविजन

Power Communication Development Division

एन आर पी सी परिसर शहीद जीत सिंह मार्ग ,कटवारिया सराय

NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai

नई दिल्ली-110016 New Delhi - 110 016



[ISO: 9001: 2008]

No. CEA/PCD/102nd CLPTCC/1356-1360

Date: 27-JUN-2016

1. Divisional Engineer (Telecom)
PTCC, T&D circle, BSNL, #26, 1st floor
Raj Bhawan Telephone Exchange
Sardar Patel Road, Guindy
Chennai-600032

2. Divisional Engineer (Telecom),
PTCC, West Zone, BSNL
Inspection circle, 3rd Floor, 'D' Wing
BSNL, Administration Building,
Juhu Tara Road, Santacruz (West),
Mumbai-400054

3. Divisional Engineer (Telecom),
PTCC, Eastern Zone, Inspection circle,
BSNL, Burra Bazar, Telephone
Kendra, 3rd Floor, 148 Chhitaranjan
Avenue, Kolkata-700007

4. Divisional Engineer (Telecom),
PTCC, Northern Zone
Inspection circle, O/o GM (N),
CTS Compound, Netaji Nagar,
New Delhi-110023

Subject: Follow up action of 102nd CLPTCC – SLPTCC meetings

During discussion held in the 102nd Central PTCC meeting at Gangtok on 27/5/2016, it was decided that year-wise roster for conducting SLPTCC meetings should be prepared jointly by concerned BSNL and Power authority in each State and who so ever is responsible for holding quarterly SLPTCC meetings in that particular year, should convene the meetings; as being done in case of CLPTCC meetings.

DETs are requested to initiate action in this regard; and CEA may be informed accordingly.

R. P. Pandey
o/c (R.P. Pandey)
Director (PTCC)

Copy for information to:

Chief General Manager, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur-482001 (Madhya Pradesh)



केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलपमेंट डिविजन

Power Communication Development Division

एन आर पी सी परिसर शहीद जीत सिंह मार्ग, कटवारिया सराय

NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai

नई दिल्ली-110016 New Delhi - 110 016

ANNEX-IV

1859952



[ISO: 9001: 2008]

No. CEA/PCD/102nd CLPTCC/1351-1355

Date: 27-JUN-2016

1. Divisional Engineer (Telecom)
PTCC, T&D circle, BSNL, #26, 1st floor
Raj Bhawan Telephone Exchange
Sardar Patel Road, Guindy
Chennai-600032

2. Divisional Engineer (Telecom),
PTCC, West Zone, BSNL
Inspection circle, 3rd Floor, 'D' Wing
BSNL, Administration Building,
Juhu Tara Road, Santacruz (West),
Mumbai-400054

3. Divisional Engineer (Telecom),
PTCC, Eastern Zone, Inspection circle,
BSNL, Burra Bazar, Telephone
Kendra, 3rd Floor, 148 Chhitaranjan
Avenue, Kolkata-700007

4. Divisional Engineer (Telecom),
PTCC, Northern Zone
Inspection circle, O/o GM (N),
CTS Compound, Netaji Nagar,
New Delhi-110023

Subject: Follow up action of 102nd CLPTCC – Nomination of members from DISCOMs for SLPTCC meeting

During discussion held in the 102nd Central PTCC meeting at Gangtok on 27/5/2016, DETs, BSNL have informed that nomination of members from DISCOMs for SLPTCC meetings are being received. It was decided that GMs (Telecom Circle), BSNL would take up the matter with DISCOMs whose nominations are pending in their respective states. In case, despite persuasions, there is no response from DISCOMs, the matter should be brought to the knowledge of CEA with copies of previous communications made by GM (Telecom), BSNL with the defaulting DISCOMs.

DETs may pursue the matter and inform CEA, whenever intervention is required. So that, SLPTCC forum gets full nomination and becomes effective to resolve PTCC issues below 220kV voltage level.

R.P. Pandey
(R.P. Pandey)
Director (PTCC)

Copy for information to:

Chief General Manager, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur-482001 (Madhya Pradesh)

संज्ञासूचक प्रतीक

ANNEX - V

टेलीफैक्स सं०११. -२६८५९९५२



केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority [ISO: 9001: 2008]

पावर कम्युनिकेशन डवलप्मेंट डिविजन

Power Communication Development Division

एनआर.पी.परिसर .सी. -१८एशहीद , जीत सिंह सनसनवाल मार्ग ,कटवारिया सराय
NRPC Complex, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai

नई दिल्ली-११००१६ New Delhi - ११० ०१६



No. CEA/PCD/102nd CLPTCC/

Dated:28/07/16

DET (PTCC), Eastern Zone
Inspection circle, BSNL,
Burra Bazar Telephone Kendra,
3rd Floor, 148 Chhitranjan Avenue,
Kolkata 700007

Subject: Compliance/Follow Up action of 102nd CLPTCC of Eastern Region

Ref:1) DET(EZ), Kolkata, BSNL, Letter No. PTCC-ER/102CLPTCC/2016-17/02 dated 26/7/16

CEA vide above reference has received compliance letter from DET (EZ), BSNL. At point no. B4 it was mentioned that several letters were given to state utilities for nominating members from DISCOMs for SLPTCC meetings but only DVC has replied.

You may send the Copies of the letters written to states utilities requesting to nominate members from DISCOMs for SLPTCC meetings to CEA so that matter can be taken up with the concerned DISCOMs.

Yours faithfully

R. P. Pandey
(RP Pandey)
Director(PTCC)

Copy for information to:

The CGM, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur – 482001 (M.P).



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट डिविजन
Power Communication Development Division
एन आर पी सी परिसर शहीद जीत सिंह मार्ग ,कटवारिया सराय
NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai
नई दिल्ली-110016 New Delhi - 110 016

ANNEX- VI



[ISO: 9001: 2008]

No. CEA/PCD/102nd CLPTCC/ 1386-1386

Date: 27-JUN-2016

Divisional Engineer (Telecom),
PTCC, Northern Zone
Inspection circle, O/o GM (N),
CTS Compound, Netaji Nagar,
New Delhi-110023

Subject: Follow up action of 102nd CLPTCC – Pending PTCUL cases

During discussion held in the 102nd Central PTCC meeting at Gangtok on 27/5/2016, DET, PTCC, BSNL, Northern Region informed that 12 nos. PTCUL post facto PTCC cases are under process with the concerned SDEs (PTCC), BSNL for marking of telecom details.

As these cases are long pending with BSNL, the matter may be expedited and marked telecom details may be sent to CEA for further processing.

R.P. Pandey
o/c (R.P. Pandey)
Director (PTCC)

Copy for information to:

Chief General Manager, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur-482001 (Madhya Pradesh)

कानूनम नदी

11-26859952



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority

ANNEX - VII

पावर कम्युनिकेशन डवलपमेंट डिविजन

Power Communication Development Division



एन आर पी सी परिसर शहीद जीत सिंह मार्ग , कटवारिया सराय

NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai

[ISO: 9001: 2008]

नई दिल्ली-110016 New Delhi - 110 016

No. CEA/PCD/102nd CLPTCC/1428-29

Date: 30-JUN-2016

Directorate General of Signals, (Signals-7),
General Staff Branch, Integrated HQ,
Ministry of Defense (Army),
Sena Bhawan, DHQ, PO,
New Delhi - 110 011

Subject: Follow up action of 102nd CLPTCC

During discussion held in the 102nd Central PTCC meeting at Gangtok on 27/5/2016, representative from Defense authority informed that to expedite Defense PTCC clearance, decentralization of process of PTCC clearance and formation of regional modules is being considered.

Kindly intimate any progress made in this regard.

R. P. Pandey
(R.P. Pandey)
Director (PTCC)

Copy for information to:

Chief General Manager, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road,
Jabalpur-482001 (Madhya Pradesh)



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलप्मेंट डिविजन
Power Communication Development Division
एन आर पी सी परिसर शहीद जीत सिंह मार्ग, कटवारिया सराय
NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai
नई दिल्ली-110016 New Delhi - 110 016

ANNEX-VIII



[ISO: 9001: 2008]

No. CEA/PCD/102nd CLPTCC/1408-1412

Date: 28-JUN-2016

1. Divisional Engineer (Telecom)
PTCC, T&D circle, BSNL, #26, 1st floor
Raj Bhawan Telephone Exchange
Sardar Patel Road, Guindy
Chennai-600032

2. Divisional Engineer (Telecom),
PTCC, West Zone, BSNL
Inspection circle, 3rd Floor, 'D' Wing
BSNL, Administration Building,
Juhu Tara Road, Santacruz (West),
Mumbai-400054

3. Divisional Engineer (Telecom),
PTCC, Eastern Zone, Inspection circle,
BSNL, Burra Bazar, Telephone
Kendra, 3rd Floor, 148 Chhitaranjan
Avenue, Kolkata-700007

4. Divisional Engineer (Telecom),
PTCC, Northern Zone
Inspection circle, O/o GM (N),
CTS Compound, Netaji Nagar,
New Delhi-110023

Subject: Follow up action of 102nd CLPTCC

During discussions held in the 102nd Central PTCC meeting at Gangtok on 27/5/2016, the issue of pending energization certificate from BSNL side for 220kV D/C line from 220kV SS Pothencode to 220kV SS Kattakkada of Kerala SEB was discussed. CLPTCC viewed the delay seriously as there has been delay of more than one year in issuing Energization Approval, after sanction of RAC (Route Approval Certificate) from BSNL. The CLPTCC forum expressed that such delay in issue of Energization Approval not only demoralizes Power Utilities but also the very purpose of timely computation of induced voltage and issuing of RAC is also defeated.

During discussion, it was noted that insistence of Energization approval does not arise when the Induced Voltages falls between 430 Volt and 650 Volt, as protection cost is to be borne by BSNL. In such cases, the power authority, after issuing of RAC from BSNL, charges its transmission line.

When the Induced Voltages goes beyond 650 V, after issue of RAC, a demand note is issued by BSNL for cost of protection of telecom cable. CEA opined that once the demanded amount is deposited by the Power Utility then issuing of Energization Approval is an internal matter of BSNL and the Power Utility may not be kept on hold for want of Energization Approval.

DETs may consider discussion held in the last CLPTCC meeting and decide on the PTCC cases accordingly, which are held up for want of Energization Approval; and also for future PTCC cases.

R.P. Pandey
o/c (R.P. Pandey)
Director (PTCC)


Copy for information to:

Chief General Manager, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur-482001 (Madhya Pradesh)

ANNEX - I of ANNEX - IX

Case No. KNK -2959		SSA: Tumkur			
Name of the power line		220 KV SC line on DC towers from the proposed 220/33 KV Pooling station M/s SEI Aditi Power Pvt. Ltd. At Pavagada to the proposed 220/66 KV KPTCL SS at Pavagada (Kotagudda) in Pavagada Taluk, Tumkur Dist.			
Length:	11.997	Kms			
Average SR value :		ohm cms			
Sl.No.	Name of Telecom line	LOP in KMs	MC in Ohms	FC in Amps	IV in Volts
I P	Pavagada Exge UG cables				
	1 Exge to Penagonda Road P-P1				
	2 Exge to Bellary Road P-P2				
	3 Exge to Sira Road P-P3				
	4 Exge to Rajavanthi, Tumkur Road P-P4				
II K	Kotagudda Exge UG cables				
	1 Exge to Pavagada K-K1				
	2 Exge to Lingadahalli Road K-K2				
III S	Shailapura Exge UG cables				
	1 Exge to Belli Battalu S-S1				
	2 Exge to Lingadahalli Road S-S2				
IV C	C.K.Pura Exge UG cables				
	1 Exge to Pavagada C-C1				
	2 Exge to Lingadahalli Road C-C2				
V PNS	Ponnasamudra Exge UG cables				
	1 Exge to Gangasagar PNS-PNS1				
	2 Exge to Singareddy Halli PNS-PNS2				
VI N	Nagalamadike Exge UG cables				
	1 Exge to Pavagada N-N1				
	2 Exge to Thirumani Road N-N2				

x — x

	<p>RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED (An ISO 9001-2008 Certified Company) [Corporate Identity Number(CIN): U40109RJ2000SGC016485] Regd. Office: Vidyut Bhawan, Jyoti Nagar, Jaipur-302005 OFFICE OF EXECUTIVE ENGINEER(PTCC), JAIPUR VIDYUT BHAWAN, JANPATH ROAD, Shed No.8,JAIPUR -302005 Email: xen.ptcc@rvpn.co.in ; Website: www.rvpn.co.in</p>
---	--

No. RVPN/XEN(PTCC)/JPR/F.501-XI/ D. Dated

The Chief General Manager,
Inspection Circle,
Bharat Sanchar Nigam Ltd.,
Sanchar Vikas Bhawan,
Residency Road,
Jabalpur-482001

SUB: Agenda items for 103rd Central PTCC meeting to be held on 25th Nov, 2016 at Jabalpur (MP).

REF: letter no. TD/ LP-2015/103rd CLPTCC Meeting dtd. 13.10.2016

Sir,

With reference to the above, kindly find enclosed herewith agenda items in respect of RVPN to be included in main agenda of 103rd Central PTCC Meeting to be held on 25th Nov, 2016 at Jabalpur (MP).

Your's faithfully

Encl: As above

(N.K.Gupta)
**SE(QC Insp. & monitoring),
RVPN, Jaipur**

Copy submitted/forwarded to the following with a copy of Agenda Items for kind information & necessary action:

1. The Director(PTCC) & Secretary Power, Central Electricity Authority, LD&T Division, NREB Complex, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110016.
2. The Deputy General Manager (ADMN), Inspection & QA circle, Jabalpur.
3. The Addl. General Manager (NWO- CFA), BSNL O/o Chief General Manager, Sardar Patel Marg, C-Scheme, Jaipur.
4. The Divisional Engineer Telegraph (PTCC), O/o GM (North), Inspection circle, CTS compound, Nataji Nagar, Africa Avenue, New Delhi-110023.
5. The Sub Divisional Engineer(PTCC), Inspection circle(T&D), Q. No.1,Ground Floor, Sanganeri Gate Telephone Exchange, Jaipur- 302003.
6. The General Manager(S&T), North Western Railway, Head Quarter office, Room no. 136, Ist Floor, Near Jawaher circle, Jaipur-302017.
7. The Director General, Directorate General of Signals (Signals-7), General Staff Branch, Integrated HQ of MoD (Army), Sena Bhawan, DHQ,New Delhi.

Encl: As above

Red on 10/11/16
MJE
**SE(QC Insp. & monitoring),
RVPN, Jaipur**

To the DE (N2) for compliance

MJE
10/11/16

**AGENDA ITEMS FOR THE CENTRAL LEVEL PTCC MEETING TO BE HELD
ON 25.11.2016**

1. PTCC case of EHV power lines of RVPN, Jaipur pending with DET (PTCC), New Delhi for want of PTCC route approval certificate.

S. No.	Name of Power Lines
1	220 KV LILO to Amarsagar from one ckt. of Ramgarh-Dechu line.
2	132 KV S/C Bhawani mandi-M/s RTM Bhawani Mandi,Jhalawar.
3	132 KV S/C Bhinder-Joojhpura line.
4	132 KV S/C Chipabarod-Kolukheri line.
5	132 KV D/C Baithwasia-Hatundi line.
6	132 KV LILO to Swaroopganj from Pindwara-Aburoad line.
7	132 KV D/C Dahara-Digod line.
8	132 KV LILO to Dadabari from Sakatpura-I/A ckt.II line.
9	132 KV S/C Dechu-Setrawa line.
10	132 KV S/C Tinwari-Kirmarsaria line.
11	132 KV LILO to Paraseneu from Ratangarh-Sridungargarh line.
12	132 KV LILO to Kishanganj from Baran -Kelwara line.
13	132 KV LILO to Bhanipura from Sardarsahar-Rajiasar line.

The DET (PTCC), BSNL, New Delhi is requested to issue the PTCC route approval certificate for the above power lines at the earliest.

2. IV calculation of the following EHV power lines are awaited from DIR (PTCC), CEA, New Delhi.

S.No.	Name of Power Lines	Case processed on dtd.	Details sent to DET(PTC C), BSNL, New Delhi	Case pending with Dir(PTCC), CEA fot I.V. computation
1	220 KV D/C Rajgarh (Chhodiya)-Akal Line.	06.08.2015	29.10.2015	
2	220 KV LILO to Goner from one ckt.of Jaipur(South)-Chaksu line.	05.08.2015	06.11.2015	28.11.2015
3	Revised 220 KV D/C Phulera-Phulera(DFCC's TSS) line.	24.06.2015	19.11.2015	28.11.2015
4	220 KV S/C Morak-Bhawanimandi line.	16.12.2015	22.03.2016	
5	Shifting of 220 KV Ratangarh-STPS line passing through proposed 2x 660	07.10.2014	28.03.2016	

	MW unit no. 7 & 8 of STPS			
6	220 KV Bajju-Bhadla line.	16.05.2016	24.08.2016	

The Dir(PTCC), CEA, New Delhi may kindly be requested to arrange IV calculation at the earliest.

Annexure- D4



Smoother And
Callus Remove
MRP-Rs.1200
Rs. 400

Rediffmail.com

Office of Engineer-in- Chief /Transmission System,
3rd Floor, Shakti Sadan, Patiala-147001

Telephone: 0175-2303676 e.mail ce-tl@pstcl.org FAX 0175-2301536, 2207774

To

The Director (PTCC), e-mail. celdntcea@gmail.com
Central Electricity Authority,
Load Despatch & Telecommunication Division,
NREB Complex, 18-A,
Shaheed Jeet Singh Sansanwal Marg,
Katwaria Sarai, New Delhi-110016.

Memo No. 1046/US DT-6201/Vol-XIII

Dated: 9/11/2016

Subject: Agenda Points for 103rd Central PTCC meeting to be held at Jabalpur on 25.11.2016.

Please refer to your office memo no. TD/LP-2015/103rd CLPTCC Meeting dt. 13.10.2016 on the subject cited above.

In this regard, it is intimated that the following routes are pending for want of PTCC route approval as on 08.11.2016 which may kindly be discussed as part of Agenda Items for early clearance.

1. PTCC Cases pending for BSNL Clearance

Sr. No.	Name of Transmission Line	Pending Since	Concerned DET offices
1.	PTCC case of 220KV DC line on DC Towers from Bottianwala to Mastewala (L-662).	24.05.2011 ✓	Ferozepur ✓
2.	PTCC case of 220KV BTI to Malout Line LILO for Badal (L-663).	24.5.2011 ✓	Mukatsar
3.	PTCC case of 220KV Bhalwan to Nabha S/Ckt on D/Ckt. Tower line (L-679).	27.7.2012 ✓	Sangrur & Patiala
4.	PTCC case of LILO of One Ckt. of 220KV Patran to Sunam at Bangan (L-680).	6.8.2012 ✓	Sangrur
5.	PTCC case 220KV DC line from Mukatsar to Kotakpura (Sandhwan) (L-688).	22.10.2012 ✓	Fardkot
6.	PTCC case of 220 KV Moga to Mehalkaian DC on DC Tower Transmission line (L-723).	18.09.2015	Ferozepur
7.	PTCC case of 220 KV Focal Point Nabha to Naraingarh (Bhawanigarh) SC on DC Tower line (L-724).	19.08.2015	Sangrur
8.	PTCC case for 220KV line from 400 KV Makhu to 220 KV Dharamkot DC on DC Tower Transmission Line. (L-725).	05.10.2015	Ferozepur
9.	PTCC case of 220 KV line from 400KV Bhalwan to 220 KV Dhanaula DC on DC Tower line. (L-726).	10.12.2015	Sangrur
10.	PTCC case of 220KV Muktsar to Malout SC on DC Tower Transmission line (L-727).	15.01.2016	Ferozepur

Welcome to Rediffmail:


Sr. No.	Name of Transmission Line	Since
1	PTCC Case 66KV line from 220KV S/Stn. Mehalkalan to 66KV S/Stn. Thikriwal line.(L-682)	25.09.2012
2	PTCC Case for route approval of 220KV Nakodar to Kartarpur D/C Line (L-708)	31.01.2014
3	PTCC Case for route approval of 220KV S/C Transmission line from 400KV S/S Balachak to 220KV S/S Nariangarh. (L-718)	24.12.2014
4	PTCC case of 220 KV Moga to Mehalkalan DC on DC Tower Transmission line. (L-723)	18.09.2015
5	PTCC case of 220 KV Focal Point Nabha to Naraingarh(Bhawanigarh) SC on DC Tower line.(L-724)	18.09.2015
6	PTCC case for 220KV line from 400 KV Makhu to 220 KV Dharamkot DC on DC Tower Transmission Line (L-725)	05.10.2015
7	PTCC case of 220 KV line from 400KV Bhalwan to 220 KV Dhanaula DC on DC Tower line. (L-726)	10.12.2015
8	PTCC case of 220KV Muktsar to Malout SC on DC Tower Transmission line (L-727)	15.01.2016
9	PTCC case LILO of Both Circuits of 220KV Moga to Ferozepur at Talwandi Bhai line (L-728)	01.03.2016
10	PTCC case 220KV Malout to Abohar SC on DC Tower line (Punjab State) (L-729)	16.03.2016

3. PTCC Cases pending with DET/PTCC, New Delhi for route approval

Sr. No.	Name of Transmission Line	Director/PTCC New Delhi Office Memo No.
1	PTCC case of 220KV D/C Line on D/C towers from Bahadurgarh to Devigarh (L-667, PNB 276).	CEA/LD&T/PTCC/263 dt. 23.03.2015
2	PTCC Case of 220KV Dhuri to Bhalwan Loop out D/C on D/C Tower Line (L-691, PNB 297).	-do-
3	PTCC Case of 220KV Line from 400KV S/Stn. Dhuri (Bhalwan) to Bangan D/C on D/C Tower Line (L-698, PNB 300).	-do-
4	PTCC case of 220KV S/C line on D/C towers from 400KV S/Stn. Ludhiana to Doraha (L-700, PNB 309).	-do-
5	PTCC Case of 66KV SC on DC Madhir to Kot Bhai Transmission line. (L-707)	This office Memo No. 1494/L-707 dt. 04.11.2015

This is for information and further necessary action please.

1346/48
9/11/2016


Dy. Chief Engineer/TS (D),
PSTCL, Patiala

CC: 1. The DET/PTCC,
Northern Zone, O/o G.M./North,
BSNL, Inspection Circle,
CTS Compound, Netaji Nagar,
Africa Avenue Road,
New Delhi-110023

2. The SDE/ (PTCC), (Telecom),
Inspection (T&D) Circle, BSNL,
CTO Complex, Adj. GPO Compound,
Ambala Cantt-133001

For information and
further necessary action
please

Annexure- D5

Agenda points from PGCIL, WR-II, Vadodara for the 103rd Central PTCC Meeting to be held on 25.11.2016 at Jabalpur

FOR M.P. Portion

1. Projects under system strengthening scheme for WR-NR :

(A) 765 KV Jabalpur – Orai TL & LILO of 765kV S/C Satna – Gwalior tr. Line at ORAI SS

(Target Completion: - March-2017) (Case submitted on 22/01/16 to BSNL-Lucknow & BSNL – Allahabad)

{Case No. CEA: MP-400 & BSNL Mumbai case No. MP-436}

1. DET-PTCC-Mumbai has forwarded the MP Portion after marking of BSNL telecom details to Director-PTCC-CEA-New Delhi vide letter ref. no. IC/MBI/PTCC/MP-436 dt. 20/08/16 towards working out of Induced Voltage Calculations.
2. SDE-PTCC-Lucknow has forwarded the UP portion details vide letter dt. 25/04/16 to DET-PTCC-New Delhi and sent to Director-PTCC-CEA-New Delhi for Induced Voltage calculations.
3. NOC received from Directorate General of signals on dated 05/02/16
4. **CEA-New Delhi office is requested for expediting to work out the Induced Voltage calculations by November end 2016.**
5. PTCC route approval shall be issued from DET-PTCC-New Delhi and DET-PTCC-Mumbai, BSNL and / West Central Railway – Jabalpur and North Central Railway-Allahabad after receipt of IV details.

2. Projects under NTPC-GADARWARA Tr. System :

(A) LILO of existing 765kV S/C Seoni – Bina Transmission line at NTPC- Gadarwara STPS {Under Interim Arrangement} till readiness of dedicated 765kV D/C Gadarwara STPS – Jabalpur pooling transmission line associated with Gadarwara STPS (2x800 MW) of NTPC Part-A.

(Target Completion: - Nov-2016) (Case submitted to 15/03/16 to all concerned)

{DET PTCC Case No. MP-444; CEA PTCC Case No. MP-405}

1. Director CEA New-Delhi forwarded the IV calculation vide letter dated 24/10/16 to DET PTCC BSNL Mumbai.
2. DET PTCC Mumbai requested to expedite for issuance of PTCC route approval by 11th November-2016.

(B) 765 KV D/C Jabalpur Pooling SS – Gadawara Transmission line associated with Gadawara Transmission System (Part-A) : (Target Completion :- May-2017) (Case submitted to 27/06/16 to all concerned)

1. Letter forwarded to all concern Railway & BSNL authorities on 27/06/16 for marking of Railway & BSNL telecom details.
2. Vide letter dt. 05/09/16, BSNL-Jabalpur has forwarded the telecom details to SDE-PTCC-Bhopal and already forwarded to DET-PTCC-Mumbai on September-2016. DET-PTCC-Mumbai is expedited to has forwarded is to be expedited.

(C) 765 KV D/C Vindhyachal pooling – Jabalpur pooling transmission line under system Strengthening scheme associated with Vindhyachal – V : (Case submitted to 17/03/16 to all concerned)

1. Letter forwarded to all concern Railway & BSNL authorities on 17/03/16 for marking of Railway & BSNL telecom details.

(D) LILO of 400 KV D/C Vindhyachal – Jabalpur Ckt – 3 & 4 at REWA substation transmission line associated with Ultra Mega Solar Power Park at REWA:- (Case submitted to 08/09/16 to all concerned)

1. NOC received from WCR – Jabalpur & Director General of Signals. After further follow-up with SDE PTCC Bhopal, the same is forwarded to CEA-new Delhi for IV calculation.

FOR Gujarat Portion

1. LILO of 400 KV D/C Mundra – Limbdi at Bhachau SS: (Target Completion :- March -2017) (Case submitted to 11/07/16 to all concerned)

1. NOC received form Directorate General of signals on dated 27/09/16.
2. Letter forwarded to SDE-PTCC Ahmedabad for marking of BSNL-Telecom details. WR-Mumbai forwarded the Railway telecom details to Director CEA-New Delhi. After receiving details from SDE PTCC Ahmedabad, the same has to be send to DET PTCC Mumbai for further processing.

2. Green Energy Corridor Projects :

765 KV Bhuj pooling – Banaskantha TL : (Target Completion :- Aug-2017) (Case submitted to 09/09/16 to all concerned) {DET PTCC Case No. GUJ-2311, CEA Case No. GUJ-709}

1. NOC received from Directorate General of signals on dated 16/02/16
2. Matter to be expedited from SDE-PTCC-Ahmedabad /DET-PTCC-Mumbai and Western Railway-Mumbai for sending the Telecom details NOC awaited from concern Railways & BSNL offices.

(A) 400 KV D/C Banaskantha – Sankheri TL :- (Target Completion:- Dec-2016) (Case submitted to 09/09/16 to all concerned)

(BSNL Case No. GUJ - 2312 - CEA CASE NO. Guj-710)

1. Letter forwarded to all concern Railway & BSNL authorities on 07/12/16 for marking of Railway & BSNL telecom details.
2. Railway telecom details from Western railway on dated 03/11/2015 (**SG.158/28/12-609**) are already forwarded to Director-PTCC-CEA-New Delhi.
3. Matter to be expedited from SDE-PTCC-Ahmedabad /DET-PTCC-Mumbai and Western Railway-Mumbai for sending the Telecom details. NOC awaited from concern Railways & BSNL offices.

(B) 400 KV D/C Banaskantha – Chittorgarh TL :- (Target Completion :- Feb-2017) Case submitted to 14/04/16 to all concerned) (BSNL Case No. GUJ - 2341)

1. Railway telecom details from Western railway on dated 03/11/2015 (**SG.158/28/12-637**) are already forwarded to Director-PTCC-CEA-New Delhi for further processing.
2. Matter to be expedited from SDE-PTCC-Ahmedabad /DET-PTCC-Mumbai for sending the Telecom details. NOC awaited from concern Railways & BSNL offices.

3. 220 kV D/C Ringanwada-Magarwada Tr. Line :- (Case submitted to 13/07/15 to all concerned)

1. PTCC case submitted to all concerned authority vide letter dated 13.07.15.
2. CEA vide their letter ref. no. CEA/PCD/PTCC/W. Rly/552 dt.18/08/15 addressed to CSTE-WR-Mumbai has conveyed that route map marking from Western Railway was not received and only Proforma-A&B only received. After further follow-up with Western Railway, Mumbai, the same is forwarded to CEA-new Delhi.

3. Matter to be expedited from DET-PTCC-Mumbai for forwarding the BSNL details to Director-PTCC-CEA-New Delhi towards further issuance of Induced Voltage Calculations.

4. Registration already made with Directorate General of Signals, New Delhi.