



भारत सरकार
Government of India
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
भार प्रेषण एवं दूर संचार प्रभाग

[ISO: 9001: 2008]



Load Despatch & Telecommunication Division

एन.आर.पी.सी .परिसर, -18ए ,शहीद जीत सिंह सनसनवाल मार्ग ,कटवारिया सराय
NRPC Complex, 18-A, Shaheed Jeet Singh S. Marg, Katwaria Sarai,

नई दिल्ली 110016-

New Delhi - 110 016

सं० एल.डी.एण्ड.टी./ पी.टी.सी.सी. 2014/

दिनांक 19.11.2014

पी.टी.सी.सी. के सभी सदस्य

Subject: Agenda for 99th Central PTCC meeting –reg.

Agenda for 99th Central PTCC meeting to be held on 27th November 2014 at Jabalpur, MP is enclosed herewith. Kindly make it convenient to attend the same.

Encl: As above:

भवदीय,

(नरेश भण्डारी)

निदेशक (पी.टी.सी.सी.) एवं
सचिव (विधुत), सैन्ट्रल पी.टी.सी.सी.



BHARAT SANCHAR NIGAM LIMITED

(A Govt. of India Enterprise)

O/o CHIEF GENERAL MANAGER INSPECTION CIRCLE JABALPUR

AGENDA FOR THE 99TH CENTRAL PTCC MEETING

Date & Time for the Meeting

27th Nov. 2014, 10:30 Hrs

Venue for the Meeting

BRBRAITT (Seminar Hall)
Ridge Road Jabalpur

A. CONFIRMATION OF MINUTES OF THE PREVIOUS MEETING

The Minutes of the of 98th Central PTCC meeting held at Shillong on 30th May 2014 were uploaded on CEA website <http://www.cea.nic.in/> under the heading "New uploads" on month of Sept 2014. No comments have so far been received.

Members may like to confirm the minutes.

B. FOLLOW-UP ACTION ON DECISIONS TAKEN IN THE PREVIOUS CENTRAL PTCC MEETINGS

B.1 Ensuring 'Zero Level' on unguarded power crossings

DET(PTCC) BSNL, New Delhi- After meeting with Dy. Director (PTCC), CEA New Delhi, it was decided that visit to the two sites in UP(W) would be undertaken during 1st week of December 2014. However, a reminder has been issued to the concerned authorities to do the needful urgently.

Annexure-I

DET (PTCC) BSNL, Chennai, DET (PTCC) BSNL, Mumbai - Informed that, no case of unguarded power crossing in southern region, western region.

Annexure-II,III

DET (PTCC) BSNL, Kolkata- Informed that, since couple of years no report till yet received from the Telecom circles of Eastern zone, after issued many letters by DETPTCC Kolkata.

(Latest Ref. letters are 1.DET/PTCC-ER/13-14/23 dated 6.8.2013, 2. DET/PTCC-ER/13-14/42 dated 19.12.2013, 3.CGM, Inspection Circle, Jabalpur D.O. letter no. TD/LP-2015/97th CLPTCC/PART dated 30th Nov'2013. 4. DET/PTCC-ER/14-15/01 dated 01.04.2014, 5.DET/PTCC-ER/14-15/02 dated 30.06.2014, 6. DET/PTCC-ER/14-15/03 dated 30.08.2014)

Annexure-IV

Members may deliberate.

B.2 PTCC Manual -2010 edition

BSNL informed that some copies of PTCC manual had been procured and distributed to the concerned officers.

At present no further requirement

(point closed)

B.3 Computerization of PTCC Route Approval Process

B.3.1 Present status of the Project:

The work of System Integration (SI) was pending for want of direction from ministry of power. Presently CEA informed that appointment of developer is yet to be completed.

Members may deliberate.

B.3.2 Collection of Legacy Data for Computerization of PTCC Route Approval Process Inspection Circle office, Jabalpur- Letter issued by DGM (Admn.) O/o CGM Inspection Circle Jabalpur TD/LP-2015/CLPTCC meeting dated 10.06.2014, regarding computerization of Telecom details-PTCC requirement.

DET (PTCC) BSNL, Mumbai- Informed that, a letter was issued to all circles of Western region to take initiative for submission of legacy data on 01st Sept.14. In response only Gujarat Telecom Circle has submitted the Exchange/BTS Latitude & Longitude details of **8500 nodes of 12 SSA**. Same has been forwarded to Director PTCC ND by e-mail on dated 21/10/14 for further action.

For remaining Circle data will be collected shortly.

DET (PTCC) BSNL, Chennai- Vide letter no SR-PTCC/CM/13-14/36 dated 24.09.2014 requested to CGMs of southern region to provide Latitude & longitude details of BSNL Exchange/BTS. Information from following circle received-

- (1) All the SSA of Tamilnadu Circle have been submitted **5360 nodes** of the Exchange/BTS Latitude & Longitude details and same has been forwarded to Director PTCC ND on 28th Oct 2014 by e-mail.
- (2) The lat-long detail of **1460 nodes**, Exchange only in all SSA of Kerala Telecom Circle have been collected & same have been forwarded to Director PTCC ND by e-mail on 28/10/2014. For further action.

DET (PTCC) BSNL Kolkata- In 1st phase collected the Latitude & Longitude details of **2G & 3G BTS** of following nodes have been collected-

- (1) Kolkata Telecom District **1800 nodes**. (2) Bihar Telecom circle **2777 nodes**
- (3) Jharkhand Telecom circle **2677 nodes**. (4) NE-I Telecom circle **757 nodes** (5) NE-2 Telecom circle **1154 nodes** (6) Assam Telecom Circle **1326 nodes** (7) A&N Telecom Circle **138 nodes**.

Above details forwarded to Director PTCC CEA, New Delhi by e-mail for further action.

DETPTCC, Kolkata now peruse remaining circle to collect the data.

To form working group for collection of legacy data in Phase II for computerization of PTCC route approval process

- (i) DET PTCC ND informed that as per 98th CLPTCC meeting, DE (PTCC), ND visited the Faridabad SSA for collecting the required details and explore the various option of collection of the desired data on sample basis. After collection of the data, analysis will be done with CEA.
- (ii) Shri N. K. Ananda Rao SDE, PTCC Inspection Circle, Bangalore has been nominated to collect the route details of Telecom cable emanating from BSNL Exchange Bangalore.

Annexure-III/1

Members may discuss.

B.4 Supply of software for calculation of Induced Voltage and related Technical guidance

Director (PTCC), CEA informed that with the existing manpower, it is not possible to impart any formal training by CEA for the time being. However, CEA could provide the necessary online training/ assist them in computing IV calculation for some officials from BSNL, Power Utilities

and Railways, who may visit LD&T division with specific RA cases. For doing so, they may approach CE (LD&T), CEA/ Director (PTCC), CEA in advance. This system will provide twin benefits i.e. to get online training as well as to reduce pending PTCC RA cases. All members welcomed the training proposal of CEA. Regarding handing over of software for calculation of mutual coupling and fault current under single line to ground fault condition, CEA informed that the software has been developed in-house and further development is needed before the same is offered to the utilities for use.

Inspection Circle Jabalpur-

Letter already written to All DET PTCC of North, South, East and West Zones to depute staff for training at CEA ND office and also IV Calculation of Zone wise can be completed accordingly.

Annexure-V/1

Presently CEA informed that the software has been developed in-house and need further development / upgradation.

Members may discuss.

B.5 Charging of fee of Rs. 10,000/- per PTCC approval case from Private utilities by RVPNL, Jaipur.

DET (PTCC) BSNL Mumbai- Charging of fee from Private utilities-Honorable Chairman & Co Chairman will decide

Letter issued by Director (PTCC) ND on 10/09/2014 to **(1) Chief Engineer (P&D), MH state Power Tran. Corp. Mumbai (2) Chief Engineer (SO), State Load & Dispatch Centre KPTCL, Bangalore** for sending nomination form subcommittee to decide the charging of fee from private utilities.

AnnexureVI

Members may discuss.

B.6 Arranging SLPTCC meetings at regular intervals.

DET (PTCC) BSNL, New Delhi-The Circles are not regularized to conduct SLPTCC meeting except Rajasthan and Uttarakhand in Northern Zone.

DET (PTCC) BSNL, Mumbai- Meeting are conducted regularly in Madhya Pradesh & Maharashtra except Gujarat & Chhatisgarh circles authorities are requested to conduct the meeting regularly.

DET (PTCC) BSNL, Chennai- Non conducting of SLPTCC meeting in Karnataka and Andhra Pradesh instruction as per agenda item B.6 (MoM of 98th CLPTCC meeting) to conduct SLPTCC meeting at regular intervals.

DET(PTCC) BSNL, Kolkata - Informed that, Several times since the last three years, it was pursued to all Telecom circles and State power authorities of Eastern zone under DET/ PTCC (ER), Kolkata for conducting SLPTCC meeting, but till yet no action has been taken from any Telecom circle in Eastern zone.

Annexure-IV

Members may discuss.

B.7 Issues raised by DET (PTCC), BSNL, Chennai

(a) EPR submission Time limit:

CLPTCC requested all the power authorities to submit EPR details in time bound manner.

DET (PTCC) BSNL, Chennai - No comments

DET (PTCC) BSNL, Mumbai- EPR for existing as well as proposed s/s are to be submitted by power authority before issuing RAC.

(b) Decentralization of IV calculation for 220 KV power line to respective SEB.

As per **MoM of 98th CLPTCC**, it was decided that this issue will be taken up in the next meeting after going through the minutes of 71st CLPTCC meeting. In addition to this following comments – the cases of southern estates.

DET (PTCC) BSNL, Chennai- The letter No. Telecom/1/98-PTCC/3227 dated 12.11.98 issued by Director CEA New Delhi, in accordance with MoM of 71st CLPTCC meeting minutes for providing details to SEB for computing the Induced Voltage (IV) in case of 220 KV circuit. Accordingly 2 states were compiled these IV for 220 KV cases. **Annexure-V/2**

However, as per latest instructions received from Dy. Director PTCC CEA New Delhi vide Ir. No.CEA/LD&T/PTCC/2013-723 dated 10 Sept -2014, PTCC cases of 220 KV and above for all state of southern region are being forwarded to CEA, ND for Induced Voltage calculation. TRANSCO & KPTCL have been directed by this office to submit all the cases of 220KV and above to CEA, New Delhi. Also they have been directed to forward the BSNL TD and Topo map for PTCC cases of 220 KV already submitted from this office and pending with them for Induced Voltage calculation to CEA New Delhi along with copy of proposal.

DET (PTCC) BSNL, New Delhi- Northern Zone is following the instructions conveyed during last CLPTCC meeting and all such cases are sent to CEA received:

DET (PTCC) BSNL, Mumbai- Decentralization of IV calculation for 220KV Power line to respective SEB- IV calculation for 220KV and power line are to be done by CEA only.

Annexure-II

B.8 Nomination of members from DISCOMs for SLPTCC meetings

DET (PTCC) BSNL, Mumbai- Nomination of Members from DISCOMs for SLPTCC meetings, letters sent to all circles pertaining to Western region. Nomination from DISCOM is still awaited.

DET (PTCC) BSNL, Kolkata - Only 2 nominations were received from Power Grid (N.E.) & DVC in spite of repeated persuasion to all power authorities.

Members may discuss.

B.9 Non-submission of PTCC Proposals to SLPTCC/CLPTCC by PTCUL

Charged CLPTCC Cases without PTCC Route Approval

DET PTCC ND: There were 14 cases of charging without PTCC clearance initially and after a several reminders, seven cases of PTCUL Kumaon zone have been submitted to this office for regularization. However, the cases are yet to be processed for want of Telecom/Railway details for which a reminder has been issued (copy enclosed).

The 7 pending cases of PTCUL Garhwal zone have still not been submitted by PTCUL even after lot of pursuance.

OTHER CASES OF NON SUBMISSION OF PTCC PROPOSAL TO SLPTCC/CLPTCC FROM POWER AUTHORITY IN NORTH ZONE:

DET (PTCC) BSNL, New Delhi-As per Section 160 of Electricity ACT-2003 and Section "A" (Chapter-III) of PTCC Manual- 2010 the proposals of SLPTCC & CLPTCC cases not submitted by the State Power Authorities as under:

SLPTCC Cases: Proposals of 11/33 KV S/C of Power lines not submitted by the State Power Authorities in Northern Zone for PTCC Route Approvals

CLPTCC Cases: Proposals of 33 KV D/C and above of Power lines not submitted by the Power Authorities (i.e J&K, DTL-ND, UP(East), UP(West) in Northern Zone for PTCC Route Approvals and Central PTCC Cases charged/ commissioned without PTCC Route Approval , The Electrical Safety Inspector issued Commissioning Certificate without obtaining the PTCC Route Approval. CEA ND also issued a letter to all SEBs for taking the PTCC Route Approvals as per Section 160 of Electricity Act-2003. But above Power Authorities even after the letter of Director CEA are not regularized till the date.

DET PTCC, Mumbai: Power authority has to submit the proposal in the initial stage to avoid delay in PTCC approval.

Sh. RP Pandey, DD (PTCC), CEA stated that as per PTCC Manual, PTCC route approval is required by both Power and Telecom authorities before charging their new transmission lines / cables. But, it has been observed that since many years, Telecom authorities, both BSNL and Railways have not submitted any case in CEA for IV computation despite additions of new telecom cables. He stated that BSNL lays new cables without taking PTCC approval and when some accident happens then they approach PTCC forum for settlement of compensation claims. He stressed that PTCC forum should not entertain any such claim case where proof of PTCC approval is not produced in the very first instance. He therefore requested Central PTCC to look in to the matter and issue suitable instructions to the all concerned agencies of BSNL & Railways also to obtain required PTCC approval before laying / commissioning their cables/ lines etc.

BSNL opined that as the underground cable of BSNL is laid in every nook and corner of the country, therefore, it may not be possible to take the route approval for short length distribution cable before laying and already laid.

As no comments could be gathered from Railways, this issue would be taken up in the next meeting.

BSNL Comments-

As per Para 1.1 of section-“C” of chapter 3 of PTCC manual 2010, and also agreed upon above by CEA, BSNL is required to seek PTCC route approval for Trunk Line and not for local access underground cable.

In 98th CLPTCC meeting it was discussed and agreed that BSNL is not required to send short length distribution cable cases for PTCC route approval owing to the large network of underground cable spread in every nook and corner of the country, to avoid large no. of circuit for IV calculation.

Members may discuss.

B.10 Pending PTCC approval cases in CEA

Cases of the issue of PTCC route approval of HVDC line (+ 800kV Bishwanath Chariali in NER to Agra in NR was raised by ER Power Grid –

It is informed by CEA ND that the representative of Power Grid has been nominated and the 1st meeting of sub-group having member from DD CEA, DETPTCC ND, representative of Power Grid held on 10/11/2014. it was concluded in the meeting that being DC power there is no possibility of electrical induction in the nearby underground telecom cables **Annexure-VI/2**

Western Zone:

Pending PTCC approval cases in CEA= 47 No.

Northern Zone:

Pending PTCC approval cases in CEA= 37 No.

Southern Zone:

Pending PTCC approval cases in CEA= 8 No.

Eastern Zone:

Pending PTCC approval cases in CEA= 32 No.

CEA informed vide letter no.D.O.No.CEA/LD&T/1/2013-PTCC/965 DATED 13/11/2014 that about 190 registered cases causes telecom details are pending either from BSNL or Railways.

BSNL Comments-As per report received from all DETPTCC 122 CLPTCC cases pending due to Telecom & Railway details & 98 CLPTCC cases pending due to Telecom details.

Annexure-VIII, IX

Members may discuss.

B.11 AP Telecom Circle, BSNL, Hyderabad

Background:

Due to falling of 11kV power line on Telecom line(s), some equipment at Dubacherla Telephone Exchange on 17.4.1992 and some equipment at Pothavaram Telephone Exchange on 8.6.1992 got damaged. A.P. Telecom Circle, BSNL has asked the power authorities i.e. APEPDCL (Eastern Power Distribution Company Limited of A.P. limited) to pay the compensation of Rs. 2,77,356/- for Dubacherla Telephone Exchange and Rs.89,400/- for Pothavaram Telephone Exchange; for the damage caused. The case came up to Central PTCC in year 2009. Subsequently, a subcommittee was formed. The Sub-Committee discussed the matter in two meetings but the later entrant could not be established because the dates of PTCC approval of the 11 kV line and the BSNL telecom lines were not traceable. Looking at the information / details available, CEA has also carried out analysis of the case and the same was sent to BSNL, Jabalpur on 27.1.2014. It was noted from the analysis that the claim case is not sustainable since both power and BSNL authorities have failed to produce PTCC approval documents and thereby lateral entrant could not be established. During discussion, the participants opined that the new telephone exchange is set up in the electrified areas only and with this it would be lateral entrant.

The committee's most members agreed with CEA's analysis. It was observed that representative of A P Telecom Circle has not arrived and therefore one chance should be given to A P Telecom, BSNL because many chances were given to M/S APEPDCL. Accordingly the matter may be decided in the next PTCC meeting, in the presence of representative of APEPDCL and AP Telecom circle, BSNL.

DET (PTCC) BSNL Chennai-

AP Telecom circle has been addressed by this office based on the intimation received from CEA New Delhi vide Letter No. CEA/LD & T/1PTCC/2013-736 dtd 10/09/2014, to represent the ensuring 99th CLPTCC meeting without fail.

Annexure-III/5

Letter issued by Director (PTCC) ND vide Lett. No. CEA/LD & T/1PTCC/2013-736 on 10/09/2014 to CMD, M/s APDCL ,Vishakapatham to give finality to the long pending issue.

Members may discuss

B.12 Non-furnishing of Telecom Details by the concerned GM/BSNL of Respective SSAs in time to DE/PTCC/Chennai

It was decided that BSNL, Inspection Circle, Jabalpur shall look in to the matter.

B.13 & 14 Agenda from Karnataka Telecom Circle

Bangalore TD: Pending Payment

KolarTD: Delay in Payment

Karwar TD: Delay in Payment

AND

Demand Note raised by AGM (MM-I), BSNL, Pune against MSEDCL

The Committee noted that the agenda points B.13 and B.14 pertain to claim in respect of damage caused to BSNL exchanges due to LT distribution feeder. Discussions were held with reference to Electricity Act, and it was noted that electricity accidents are covered in section 161 of EA – 2003 and electrical inspectors of the concerned area is empowered to look into such matters. The Committee decided that central PTCC is not the forum to take decision on such issues.

BSNL COMMENTS

- i) The article 161 of EA 2005 covers the loss of human life or animal life or any injury to human being or animal and it does not mention about the property loss. However it is also mentioned that "Appropriate Government may, if it think fit, required any Electrical Inspector, or any other person appointed by it in this behalf to inquire the report".
- ii) The "Appropriate Government" here is defined in Para-2(5) of Electricity Act as Central Government which may be BSNL, Railway etc and in Para 2(6) "Authority" as CEA.
- iii) As mention above the act permits the "Appropriate Government" for appointing any other person also to enquire in the report and though property loss is not mentioned in the act but as this is related to the accident occurring due to induction of electricity, hence, the PTCC is the right forum to appoint any person and take decision on such cases.

Members may discuss

B.15 Conversion of 230kV D/C Overhead line into 230kV D/C 1X 1200Sq. mm XLPEUG Cable

DGM (CP&MM), Chennai Telephones, BSNL has raised this issue. CEA stated that this case has not been received by them so far and as such no comments can be made. It was decided that BSNL Chennai would send the complete case to CEA for examination prior to the discussions by the committee.

DETPTCC, Chennai informed that details of Conversion of 230kV D/C Overhead line into 230kV D/C 1X 1200Sq. mm XLPEUG Cable forwarded by DGM (CP&MM) Chennai Telephones to CEA ND, vide letter No. DECP/PTCC Corres.2014-15 dated 01/09/2014.

Annexure-III/2

Members may deliberate.

C. NEW AGENDA POINTS

(1) Proposed Agenda for 99th CLPTCC meeting DET(PTCC) BSNL Chennai -

Conversion of portion of existing O/H power line into U/G cable:

Many proposal are being received from state electricity board seeking PTCC clearing for converting a portion of O/H the exiting power line to U/G cable, due to Metro railway work or otherwise. In one such earlier case, CEA clarified that if due protection have been considered in the original O/H line then even if part of it is converted in to U/G cable, further protection may not be required. Since this may not be applicable in all cases as there is a possibility of route change, all the SEBs may be directed to submit the proposal of such cases along with RA details of O/H line and original map marking of change route wherein overhead portion has been converted, for quick processing of the case. Guideline for processing such cases may be issued.

In such cases if GD tube protection is warranted for affecting Telecom cable, field unit are facing difficulty in mounting more number of GD tubes in shorter span of UG cable. Alternate protection may be suggested.

Annexure-III/4

AGENDA ITEMS RECEIVED FROM VARIOUS UTILITIES

- (1) Agenda Received from MPPTCL, Jabalpur vide Lr No. 04-01/PTCC/1202/TRIV/7459 dated 29/09/2014.

Compliance for the agenda of MPPTCL, Jabalpur submitted by DE PTCC, Mumbai vide No. IC/ MBI/PTCC/CLPTCC /Meeting / 46 dated 16.10.2014.

As per Annexure-VII,VII/2

- (2) Agenda Received from GM (P&E) Assam Electricity Grid Corp. ltd Narangi Guwahti

Compliance for the agenda of GM (P&E) Assam electricity Grid Corp. has been submitted by DE (PTCC), Kolkata As per Annexure-VII/3,VII/4

- (3) Agenda Received from Dy. Chief Engineer (SPE) Damodar Valley Corporation Kolkatta vide Lr No.EDCON/SPM/PTCC/998 dated 13/10/2014.

Compliance for the agenda of Dy. Chief Engineer (SPE) Damodar Valley Corporation Kolkatta been submitted by DE (PTCC) Kolkata by e-mail on dated 01/11/2014. As per Annexure-VII/5,VII/6

- (4) Agenda Received from EE (PTCC) Rajsthan Rajya Vidyut Prasaran Nigam Limited Jaipur vide Letter No. RVPN/ZCE(T&C-JPZ)/XEN(PTCC)/JPR/F-501-XI/D-320 dated 05/11/2014.

As per Annexure-VII/7

O/o DET(PTCC), Northern Zone,
Circle, O/o.Sr.GM(North),
Africa Avenue Road,
Nagar, New Delhi-110023
Phone-011- 24101329 (O)

Ins]
CTS Comp
New D



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

PTCC(T)NZ/ND/99th CLPTCC//2014-15

Dated 13.11.2014

To,
The AGM(SW)
Inspection Circle, Jabalpur.

Sub: Clarification on Agenda points

As per intimation received, the clarifications on the agenda points is as shown below:

1. B.1 – Ensuring zero level on unguarded power crossings

After meeting with Dy.Director(PTCC), CEA New Delhi, it was decided that visit to the two sites in UP(W) would be undertaken during 1st week of December 2014. However, a reminder has been issued to the concerned authorities to do the needful urgently (copy enclosed).

2. B.3.2 – Collection of BSNL Legacy data for Project of PTCC computerization

The undersigned held a meeting during October 2014 with GMTD Faridabad regarding collection of BSNL legacy data for PTCC computerization and handed over the format for the same finalized with CEA, New Delhi. Last week again had a meeting with concerned DGMs & DEs, Faridabad who intimated that around 50% data have been prepared and would be made available at the earliest. Another meeting along with Dy.Director(PTCC) CEA New Delhi is planned during second week of December 2014.

3. B.7(b) – Decentralization of IV calculation for 220 KV power line respective SEB

Northern Zone is following the instructions conveyed during last CLPTCC meeting and all such cases are sent to CEA.

4. B.9 – Non-submission of PTCC proposals by M/s.PTCUL

There were 14 cases of charging without PTCC clearance initially and after a spate of reminders, seven cases have been submitted to this office for regularization. However, the cases are yet to be processed for want of Telecom/Railway details for which a reminder has been issued (copy enclosed).

This is issued for information and necessary action please.

(S.CHANDRAN)
DE(PTCC) NZ New Delhi

O/o DET(PTCC), Northern Zone,
Circle, O/o.Sr.GM(North),
Africa Avenue Road,
Nagar, New Delhi-110023
Phone-011- 24101329 (O)

Insj
CTS Comp
New P



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

PTCC(T)/PTCC-Cases/UTR/2014-15

Dated 01.11.2014

To,

- 1.The Executive Engineer(O&M), PTCUL,
132 KV S/S Kashipur,(U.S.Nagar),Uttaranchal.
- 2.The Executive Engineer(O&M), PTCUL
220 KV S/S.Pantnagar(U.S.Nagar). Uttaranchal.
- 3.The Executive Engineer(Proj& Const), PTCUL,
220 KV S/S Kataiyya, Mahuakheraganj, Kshipur(U.S.Nagar), Uttaranchal.

Sub : Clearance of charged PTCC Cases pertaining to O&M Division Kashipur and Pantnagar in Uttaranchal - REMINDER

Ref : 136/O&M Div.(K) Dated 13.02.2014 & 178/220(O&M)D(P)/220 KV/ Dated 25.02.2014

With reference to the above, the following complete PTCC Cases may be submitted to concerned DE's/SDE's BSNL at Kashipur/ Pantnagar and Railway Authority at Muradabad for marking the Telecom/Railway details on G.T.Sheet as well as on prescribed proforma in the vicinity of 8 Kms (Map Scale 1Cm= 0.5 Kms) of the route of proposed power line as under:

S.N	Name of Power Lines	Lengh in Kms	Date of Ref	Remarks
1	132 KV LILO Kashipur to Jaspur at 400 KV S/S Kashipur.	2.250	13.02.14	Telecom/ Railway details pending with DE/SDE, BSNL, Kashipur and DSTE, Moradabad.
2	132 KV LILO Kashipur to Ramnagar at 400 KV S/S Kashipur.	0.606	13.02.14	
3	132 KV D/CLILO Kalgarh to Kashipur -II at Rampur	21.917	13.02.14	
4	LILO of 220 KV Bareilly- Haldwani line at 220 KV S/S Pantnagar	9.516	25.02.14	Telecom/ Railway details pending with DE/SDE, BSNL, Pantnagar and DSTE, Moradabad.
5	132 KV D/C Kichha- Haldwani line Lilo at Rudrapur & Pantnagar	4.746	25.02.14	
6	132 KV Pilibhit- Khatima line Lilo at Sitargang	25.86	25.02.14	
7	132 KVD/C Sitargang - Kichha line	31.5	25.02.14	

It is requested that necessary instruction may be issued to the site Engineer to contact the concerned DE's/SDE's BSNL Kashipur/ Pantnagar and DSTE/Tele. of Railway Muradabad For collecting the Telecom/Railway details of above T/Lines without delay.

This is issued for further necessary action please.

DET(PTCC) N^o

Copy to:

1. The DGM(OPN), O/o CGMT.Uttaranchal Circle, Windlas Complex, Rajpur Road Dehradun for issuing instruction to DE's/SDE's at Kashipur/Pantnagar to provide Telecom details without delay.
2. The DSTE/Tele, O/o DRM, N.Railway, Muradabad for providing the Railway details without delay
3. The Director(PTCC),O/o CEA, New Delhi-110016 for information please.

DET(PTCC), Northern Zone,
Inspection Circle, O/o.Sr.GM(North),
CTS Compound, Netaji Nagar,
New Delhi-110023
Phone-011- 24101329



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No.PTCC(T)/DV-2501/2013-14

Dated at ND the 08.10.2014

To,
The AGM (PTCC),
Inspection Circle,
Jabalpur-482001

Subject: DRAFT AGENDA/STATEMENTS FOR 99TH CLPTCC MEETING

Ref : AGM(PTCC) JB No. TD/LP2015/CLPTCC meetings/98-99th dtd 06.09.14
Agenda of 99th CL PTCC Meeting is as under :

1.Un-guarded Power Crossings

The un-guarded power crossings are Zero except in the case of UP(West) in Northern Zone i.e.2 in UP(W) and joint team from O/o DE(PTCC), ND and CEA will visit the sites very shortly for analyzing the matter and finalization.

2. Proposals not submitted of SLPTCC & CLPTCC Case

As per Section 160 of Electricity ACT-2003 and Section "A"(Chapter-III) of PTCC Manual- 2010 the proposals of SLPTCC & CLPTCC cases not submitted by the State Power Authorities as under:

a) SLPTCC Cases: Proposals of 11/33 KV S/C of Power lines not submitted by the State Power Authorities in Northern Zone for PTCC Route Approvals

B.CLPTCC Cases: Proposals of 33 KV D/C and above of Power lines not submitted by the Power Authorities (i.e J&K. DTL-ND, UP(East), UP(West) in Northern Zone for PTCC Route Approvals and Central PTCC Cases charged/ commissioned without PTCC Route Approval , **The Electrical Safety Inspector issued Commissioning Certificate without obtaining the PTCC Route Approval.** CEA ND also issued a letter to all SEBs for taking the PTCC Route Approvals as per **Section 160 of Electricity Act-2003.** But above Power Authorities even after the letter of Director CEA are not regularized till the date.

3.Charged CLPTCC Cases without PTCC Route Approval

As per 97th/98th CLPTCC meeting, 14 Power lines which are already charged during 2005 to 2007 without taking PTCC Route Approval and PTCUL was asked to forward PTCC Proposals for such power lines which have been charged unilaterally. However neither any proposal of charging of power lines was submitted nor they have replied the CEA ND's letter No. LD&T/1/2012-PTCC/185 Dated 12.04.2012 and LD& T/1/2012-PTCC/717 dated 10.9.2014 in this regards.

4. Arranging SLPTCC Meeting at regular intervals

The Circles are not regularized to conduct SLPTCC meeting except Rajasthan and Uttarakhand in Northern Zone.

5. Collection of Legacy data for computerization of PTCC Route Approval Process

As per 98th CLPTCC meeting, DE (PTCC),ND visited the Faridabad SSA for collecting the required details and explore the various option of collection of the desired data on sample basis. After collection of the data, analysis will be done with CEA.

DET(PTCC) ND

O/o DET(PTCC), Western Zone,
3rd Floor, 'D' Wing, Admn. Bldg., BSNL Complex,
Santacruz(W), Mumbai -400054
Phone - 022- 26611530, 26608521



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. IC/MBI/PTCC /CLPTCC/46

Dated at Mumbai, the 20.10.2014

To,

The A.G.M. (PTCC),
Inspection Circle, Jabalpur.

Sub: Agenda points for 99th Central PTCC meeting to be held at Jabalpur in the month of November 2014.

B. Follow-up on the decisions taken in the 98th Central Level PTCC Meeting held at Shillong on 30.05.2014.

A letter have been issued to all circles to take initiative on the decisions taken in the last meeting.

B.1 Ensuring Zero level on unguarded power crossing.

In western region no cases of unguarded power crossing are pending. Reminder have been issued to all circles for submission of detail on 06.09.14

B.2. Computerization of PTCC Route Approval Process.

A letter have been issued to all circles of Western region to take initiative for submission of legacy data on 01.09.14. Some SSA of Gujrat Telecom Circle have submitted the legacy data. For remaining state data is to be collected shortly.

B.3 Supply of software for calculation of Induced voltage & related technical guidance.-No comments

B.4 Charging of fee from Private utilities-Honorable Chairman & Co Chairman will decide

B.5 Arranging SLPTCC Meeting at regular intervals- Meeting are conducted regularly in Madhya Pradesh & Maharashtra. Gujrat & Chhatisgarh circles authorities are requested to conduct the meeting regularly.

B.6 Issues raised by DET(PTCC), BSNL, Chennai

a) EPR submission Time Limit-EPR for existing as well as proposed s/s are to be submitted by power authority before issuing RAC.

b) Decentralization of IV calculation fro 220KV Power line to respective SEB- IV calculation for 220KV and power line are to be done by CEA only.

B.7 Nomination of Members from DISCOMs fro SLPTCC meetings.-Letters sent to all circles. Nomination from DISCOM are awaited

B.8 Non submission of PTCC proposals for SLPTCC/CLPTCC by PTCUL- Power authority has to submit the proposal in the initial stage to avoid delay in PTCC approval.

B.9 Pending Central PTCC cases with CEA / SEB / BSNL / RLY

Sr.No	Name of the Circle	No. of proposal for which detail forwarded to CEA for IV calculation	No. of Central Level PTCC proposal pending with State Electricity Board	No. of Central Level PTCC proposal pending with BSNL	No. of Central Level PTCC proposal pending with Railway	No. of Central Level PTCC proposal pending with BSNL +Railway
		C	B	A1	A2+D2	A
1	Maharashtra	15	9	13	3+4	9
2	Gujrat	28	1	4	1+18	1
3	Madhya Pradesh	1	1	0	1+5	5
4	Chhatisgarh	3	0	0	0+1	7
	Total	47	11	17	5+28	22

B.10 AP Telecom Circle, BSNL, Hyderabad.-Points pertains to DET(PTCC), Chnnai.

Annex II / 1

O/o DET(PTCC), Western Zone,
5th Floor, 'D' Wing, Admn. Bldg., BSNL Complex,
Santacruz(W), Mumbai -400054
Phone - 022- 26611530, 26608521
Email ID detptccmbi@gmail.com



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. IC/MBI/PTCC /CLPTCC/46

Dated at Mumbai, the 21.10.2014

To,

1. **The Secretary , CLPTCC/DGM(A), Inspection Circle, Jabalpur.**
2. **The Director(PTCC), O/o CEA, New Delhi .**

Sub: Follow-up action on minutes of the 98th Central PTCC meeting held on 30.05.2014 at Shillong

Follow up action on Minutes of 98th Central Level PTCC Meeting held at Shillong on 30.05.2014 are as follows

B.3.2 Collection of Legacy Data for Computerization of PTCC Route Approval Process- A letter have been issued to all circles pertaining to Western region for submission of legacy data on 01.09.2014.(Copy enclosed)

B.6 Arranging SLPTCC meetings at regular intervals - A letter have been issued to all circles pertaining to Western region for conducting SLPTCC meeting regularly on 06.09.2014. .(Copy enclosed)

B.8 Nomination of members from DISCOMs for SLPTCC meetings- A letter have been issued to all circles pertaining to Western region for conducting SLPTCC meeting regularly on 06.09.2014. .(Copy enclosed)

This is for your kind information please.

Encl. As Above

DET(PTCC)
Mumbai54.

Copy to:

1. **The DGM A/T , Inspection Circle, Mumbai. For necessary action please.**
2. **The SDE(PTCC)/Secretary SLPTCC, Ahmedabad/Bhopal / Mumbai. For necessary action.**

Annex - II/2

O/o DET(PTCC), Western Zone,
3rd Floor, 'D' Wing, Admn. Bldg., BSNL Complex,
Santacruz(W), Mumbai -400054
Phone - 022- 26611530, 26608521

भारत संचार निगम लिमिटेड
BHARAT SANCHAR NIGAM LIMITED

No.IC/MBI/PTCC/CLPTCC/46

Dated at Mumbai, the 06.09.2014

To,

The Managing Director
Central East/ South East /Central Zone,
Madhya Pradesh Distribution Company,
Jabalpur / Indore / Bhopal.

Subject : Follow-up action on the minutes of the 98th Central PTCC meeting held on 30.05.2014 at Shillong on Item No.B.8 regarding Nomination of member from Discom/Distribution companies for SLPTCC meeting"

As per minutes of 98th Central PTCC Meeting, the nomination (name of the Nodal Officers) from Discom/Distribution companies as a member of SLPTCC to be called from distribution companies for smooth functioning of PTCC .

It is requested that detail in prescribed format to be sent to this office along with necessary instructions may be issued to concerned Discom/Distribution Companies to provide the names of Nodal Officers for attending the SLPTCC meetings.

D.E.T. (R.P.C.C.) Mumbai
Office of (Government of India)
3rd Floor, D-Wing, Administrative Bldg.,
Jinubanda Telecom Complex,
Santacruz (West), Mumbai-400 054.

Copy to

1. The Secretary CLPTCC & DGM(A) Inspection Circle, Jabalpur. For information please.
2. The Sr.G.M(N), Inspection Circle, New Delhi.
3. The Director(PTCC) O/o the CEA, New Delhi. For information and necessary action please.
4. The DGM (NWO- CFA), BSNL, MP Telecom Circle, Bhopal.
5. The SDE(PTCC)/Secretary SLPTCC, Bhopal. It is requested to send this letter to all distribution companies for necessary action.

Annex II/3

O/o DET(PTCC), Western Zone,
3rd Floor, 'D' Wing, Admn. Bldg., BSNL Complex,
Santacruz(W), Mumbai -400054
Phone - 022- 26611530, 26608521

भारत संचार निगम लिमिटेड
BHARAT SANCHAR NIGAM LIMITED

No.IC/MBI/PTCC/CLPTCC/46

Dated AT Mumbai, the 06.09.2014


To,

The Superintending Engineer(RE) ,MSEDCL,Mumbai-54.

Subject : Follow-up action on the minutes of the 98th Central PTCC meeting held on 30.05.2014 at Shillong on Item No.B.8 regarding Nomination of member from Discom/Distribution companies for SLPTCC meeting"

As per minutes of 98th Central PTCC Meeting, the nomination (name of the Nodal Officers) from Discom/Distribution companies as a member of SLPTCC to be called from distribution companies for smooth functioning of PTCC .

It is requested that detail in prescribed format to be sent to this office along with necessary instructions may be issued to concerned Discom/Distribution Companies to provide the names of Nodal Officers for attending the SLPTCC meetings.


D.E.T. (P.T.C.C.) Mumbai
Office of (Government Engineer)
3rd Floor, D-Wing, Administrative Bldg.,
Juhu Danda Telecom Complex,
Santacruz (West), Mumbai-400 054.
06/09/2014

Copy to

1. The Secretary CLPTCC & DGM(A) Inspection Circle, Jabalpur. For information please.
2. The Sr.G.M(N), Inspection Circle, New Delhi.
3. The Director(PTCC) O/o the CEA, New Delhi. For information and necessary action please.
4. The DGM (NWO- CFA), BSNL, Maharashtra Telecom Circle, Santacruz(W),Mumbai-54.
5. The Secretary SLPTCC/ SDE(PTCC) ,Mumbai. For necessary action.

Annex - III

BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)
INSPECTION CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange
1st Floor, No.26, Sardar Patel Road, Guindy, Chennai-32.
Phone 044/22355550 Emailid: deptccchi@gmail.com

To
AGM PTCC
BSNL, Inspection Circle
Jabalpur 482 001.

No:SR-PTCC/CM/13-15/42

dtd. @ CNI-32 the

23/10/2014

Sub : Follow-up action for the minutes of 98th CLPTCC meeting held on
30/05/2014 at Shillong-reg

Kindly find enclosed herewith item wise compliance for the Draft agenda points
of 99th CLPTCC meeting further necessary action.

Recd
23/10/2014
Divisional Engineer Telecom PTCC,
Inspection Circle, Southern Region
Chennai - 32.

Copy to:

1. Dy.G.M. A/T, Inspection Circle, Chennai. For infn. Pl.

Follow-up action on decision taken in the 98th CLPTCC meeting

B1: Ensuring "Zero level" on unguarded power crossings

No case of unguarded power crossing in Southern region.

B2: Computerisation of PTCC Route Approval Process:

B.2.1 Present status of the Project:

No comments.

B.2.2 Collection of Legacy data for Computerization of PTCC Route Approval Process:

- 1) Regarding Phase I for submission of latitude longitude details of all BSNL exchanges this office has sent proforma to CGMs of Southern Region vide this office letter no. SR-PTCC/CM/13-14/36 dtd. 24/09/2014. Some of the SSAs of Tamilnadu Circle have sent the details and is being processed by Tamilnadu Circle office for forwarding to Inspection Circle, Jabalpur.
- 2) Regarding Phase-II- to collect the route details of Telecom cables emanating from BSNL Exchange from Bangalore, Shri N.K.Ananda Rao SDE PTCC, Inspection Circle, Bangalore has been nominated from this office and the same has been intimated to CEA New Delhi.

B.3 Supply of Software for calculation of Induced Voltage and related Technical guidance:

No comments

B.4 Charging of fee from Private utilities:

No comments

B.5 Arranging SLPTCC meetings at regular intervals:

No compliance by Andhra Pradesh and Karnataka Telecom Circle in spite of repeated reminders from this office.

B.6 Issues raised by DE(PTCC), BSNL, Chennai

a) EPR Submission Time limit:

No comments

b) Decentralization of IV calculation for 220 KV power line to respective SEB

As per the latest instructions received from Dy. Director PTCC, CEA New Delhi vide Ir.no. CEA/LD & T/1/PTCC/2013-723 dtd. 10-Sep-2014, PTCC cases of 220 KV and above for all the states of Southern Region are being forwarded to CEA, New Delhi for Induced voltage calculation. TANTRANSOCO & KPTCL have been directed by this office to submit all cases of 220 KV and above to CEA, New Delhi. Also they have been directed to forward the BSNL TD and Topomap for PTCC cases of 220 KV already submitted from this office and pending with them for Induced Voltage calculation to CEA New Delhi along with copy of the proposals.

B.7 Nomination of members from DISCOMs for SLPTCC meetings

No comments

B.8 Non submission of PTCC Proposals to SLPTCC/CLPTCC by PTCUL:


No comments

B.9 Pending PTCC approval cases in CEA:

List of pending cases with CEA for IV computation will be furnished before the meeting.

B.10 AP Telecom Circle, Hyderabad:

AP Telecom Circle is being addressed by this office based on the intimation received from CEA New Delhi vide Ir.no. CEA/LD & T/1/PTCC/2013-736 dtd. 10-SEP-2014, to represent the ensuing 99th CLPTCC meeting without fail.


DIVISIONAL ENGINEER
PTCC, Southern Region
Inspection Circle, BSNL
Raj Bhavan Telephone Exchange
I Floor, 29, Sarani, Patel Road,
Chennai - 600 032

Annex - III/1

BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)
INSPECTION CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange
Ist Floor, No.26, Sardar Patel Road, Guindy, Chennai-32.
Emailid: deptccchi@gmail.com Tel: 044-22355550

To
The Deputy Director PTCC
CEA, New Delhi.

No:SR-PTCC/CM/13-14/37

dtd. @ CNI-32 the


24/09/2014

Sub : Collection of BSNL Legacy data for Project of PTCC computerization-reg
Ref : Dy. Director PTCC, CEA, ND Ir.no. CEA/LD & T/1/PTCC/2013-732
dtd. 07/09/2014

With reference to letter cited above, requesting to nominate one member from Southern Zone of BSNL for working group to collect the route details of Telecom cables emanating from each Exchange under 2nd Phase, ~~Shri.N.K. Ananda Rao~~ SDE PTCC, Inspection Circle, Bangalore whose address is given below, is hereby nominated who shall co-ordinate in this matter.

Address:

Shri.N.K.Ananda Rao
SDE PTCC, Inspection Circle
City Telephone Exchange, 2nd Floor
S R Nagar, Bangalore 560 027
Contact No.: Office: 080 2248 3088
Mobile : 09449858808


Divisional Engineer (PTCC)
Southern Region, Inspection Circle
Chennai-32.

Copy to:

1. CGM Inspection Circle, Jabalpur/AGM (PTCC), Inspection Circle, Jabalpur for infn pl.
2. Dy.G.M. A/T, Inspection Circle, Chennai. For infn. Pl.
3. Shri.N.K.Ananda Rao (Copy of CEA letter enclosed) with instruction to co-ordinate in this matter.

Annex III/2

BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)
INSPECTION CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange
1st Floor, No.26, Sardar Patel Road, Guindy, Chennai-32.
Phone 044/22355550 Emailid: deptccchi@gmail.com

To
AGM PTCC
BSNL, Inspection Circle
Jabalpur 482 001.

No:SR-PTCC/CM/13-15/47


dtd. @ CNI-32 the

12/11/2014

Sub : Follow-up action for the minutes of 98th CLPTCC meeting held on
30/05/2014 at Shillong- item B-15-reg

In continuation of this office letter dated 23-10-2014, the follow up action on
item B-15 of the minutes of the 98th CLPTCC meeting is submitted below please.

Item B-15: DGM (CP & MM) ^{CUTD} has forwarded all the details pertaining to the same
to CEA New Delhi vide their lr dtd 01-09-2014 (copy enclosed)


Divisional Engineer Telecom PTCC,
Inspection Circle, Southern Region
Chennai - 32.

Copy to:

1. Dy.G.M. A/T, Inspection Circle, Chennai. For infn. Pl.

Annex - III/2-1

**BHARAT SANCHAR NIGAM LIMITED
CHENNAI TELEPHONES
O/o PGM, NW(P & D)CFA,
No.2, KUSH KUMAR ROAD, CHENNAI-34.**

DE CP/PTCC Corres./2014-15 / 7

dtd 01-09-14

*Sub: Details of Conversion of 230KV DC OH line into 230KV DC 1X 1200Sq,
mm XLPE UG Cable-Reg.*

Ref: Minutes of 98th CLPTCC meeting held on 30.05.2014 at Shillong.

With reference to the minutes of the 98th CLPTCC meeting held on 30.05.2014, at Shillong, all the details pertaining to the above mentioned power line (Sl.No. B.15 in the minutes of the CLPTCC meeting) is sending herewith for further necessary action at your end please.

Encl: As above

M. R. 1.9.14
DGM (CP&MM)
Chennai Telephones

To
Director, PTCC,
Central Electricity Authority,
(Ministry Of Power),
Sewa Bhavan,
Ramakrishnapuram,
New delhi-110 066

Annex III / 2

182

BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)
INSPECTION CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange, 1st Floor
No. 26, Sardar Patel Road, Guindy, Chennai-32.
Fax: 044/22354646. emailid: deptccchi@gmail.com

To

CE TRANS,
TANTRANSCO,
Chennai-600 002.

SR-PTCC/TN-1585/ 33

dtd. @ Chennai-32, the 20.9.2014.

Sub: Conversion of 230 KV DC OH line in to 230 KV DC U/G cable-reg.

Ref: B15 of minutes of 98th CLPTCC meeting.

-x-x-x-

With reference to the above subject Director,PTCC CEA Newdelhi has directed this office vide letter no. CEA/LD&T/1/PTCC/2013/744 dated 10.9.2014. (Copy of which is enclosed) to furnish additional information regarding protection to affected BSNL telecom cable due to conversion of 230 KV DC OH line to 230 KV DC UG cable

You are therefore requested to furnish the following at the earliest and further processing the case..

1. Original PTCC RA for overhead line along with complete route marking on topomap and full details of IV computation.
2. Revised route marking on topo map including changed route wherein over head portion has been converted in to under ground along with complete IV computations.

Divisional Engineer Telecom
PTCC, Southern Region,
Chennai-32.

Encl: a/a

Annex III/3

SOUTHERN REGION PTCC-TOTAL PENDING CASES	SPLIT UP				TOTAL	
	ANDH	TELENG	KARNATAKA	TAMILNADU		
	RA	ANA	AP	KERALA	ADU	TOTAL
Pending for Railway clearance /Railway details	11	0	0	0	8	27
Pending for both BSNL and Railway details	21	7	1	4	2	52
Pending for Telecom details from BSNL	24	0	1	6	8	55
Pending for IV comments from EB	10	0	7	4	10	31
Pending for IV comments from CEA	5	0	2	1	2	10
Pending with DE PTCC	0	0	0	0	0	0
TOTAL PENDING CASES	71	7	52	15	30	175

Annex III/4

38

BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)
INSPECTION CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange, 1st Floor
No. 26, Sardar Patel Road, Guindy, Chennai-32
Phone: 044-22355550 Email:deptccchi@gmail.com

To

AGM (PTCC)
% CGM Inspection Circle
Jabalpur.

SR-PTCC/CM/2013-15/ 38

dtd. @ Chennai-32, the 25.09.2014

Sub: 99th All India CLPTCC meeting -reg.

Please find herewith enclosed the new agenda points to be taken up in the forthcoming 99th CLPTCC meeting .

[Handwritten Signature]

Divisional Engineer (PTCC)
Southern Region
Inspection Circle
Guindy, Chennai-32.

Copy to:

1. Director (PTCC), CEA New Delhi.
2. The DGM A/T Inspection Circle, Chennai for infn.

P.T.O.

Proposed Agenda for 99th CLPTCC meeting:

1. Conversion of a portion the existing O/H Power line into U/G cable:

Of late many proposals are being received from State Electricity boards , seeking PTCC clearance for converting a portion of the existing O/H power line into u/g cable, due to Metro Rail works or otherwise. In one such earlier case, CEA has clarified that if due protections have been considered in the original overhead line, then even if part of it is converted into u/g cable, further protection may not be required. Since this may not be applicable in all cases as there is a possibility of route change, all SEBs may be directed to submit the proposal for such cases along with original RA details of overhead line and the original map marking the changed route wherein overhead portion has been converted, for quick processing of the case. Guideline for processing such cases may be issued.

In such cases, if GD tube protection is warranted for the affected Telecom cable, Field units are facing difficulty in mounting more number of GD tubes in shorter span of ug cables. Alternative protection may be suggested.

2. Non conducting of SLPTCC meeting in Karnataka and Andhra Pradesh Circle:
Instructions as per agenda item B.6 (98th CLPTCC Meeting) to conduct SLPTCC meeting at regular intervals is not being complied with , by Karnataka and Andhra Pradesh Circles.

Annex - III/5

BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)
INSPECTION CIRCLE
Office of the Divisional Engineer Telecom (PTCC)
Raj Bhavan Telephone Exchange
1st Floor, No.26, Sardar Patel Road, Guindy, Chennai-32.
Phone 044/22355550 Emailid: deptccchi@gmail.com

To
The GM (NWO-CFA) and Member Telecom SLPTCC
AP Telecom Circle
BSNL, Hyderabad.


No:SR-PTCC/CM/13-15/43 dtd. @ CNI-32 the 23/10/2014

Sub : Item no. B.11 of 98th CLPTCC meeting minutes- AP Telecom Circle,
BSNL Hyderabad -reg

Ref : Dy. Director PTCC, CEA, New Delhi office lr.no. CEA/LD & T/1/PTCC/
2013-736 dtd. 10-SEP-2014

Kindly refer to the letter under reference above received from CEA New Delhi (Copy enclosed). It is requested that necessary action may be taken to attend ensuing 99th CLPTCC meeting without fail for resolving the above issue.

Encl: a/a


Divisional Engineer Telecom PTCC,
Inspection Circle, Southern Region
Chennai - 32.

Copy to:

1. The CGM/AGM (PTCC) Inspection Circle, Jabalpur for infn. Pl.
2. The Dy.G.M. A/T, Inspection Circle, Chennai for infn. Pl.

केन्द्रीय विद्युत प्राधिकरण
 Central Electricity Authority [ISO: 9001: 2008]
 भार प्रेषण एवं दूर संचार विभाग



Load Despatch & Telecommunication Division
 एन.आर.ई.सी. परिसर, 18-ए, शहीद जीत सिंह सनसनवाल मार्ग, कटवारिया सराय
 NRPC Complex, 18-A, Shaheed Jeet Singh S. Marg, Katwaria Sarai,
 नई दिल्ली-110016
 New Delhi - 110 016



No. CEA/LD&T/PTCC/2013-736

Date: 10-SEP-2014


- | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>1. DET (PTCC), BSNL
 Raj Bhavan Telephone Exchange,
 1st Floor, No. 26, Sardar Patel Road,
 Guindy, Chennai-32</p> | <p>2. CMD, M/s APDCL
 Corporate office, P&T Colony
 Seetammadhara,
 Vishakapatnam-530 013</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|

Sir,

The issue of compensation in regard to the incident occurred in year 1992 had first come up in Central PTCC in year 2009. Subsequently, a subcommittee was formed. The Sub-Committee discussed the matter in two meetings but the later entrant could not be established because the dates of PTCC approval of the 11 kV line and the BSNL telecom lines were not traceable. Looking at the information / details available, CEA has also carried out analysis of the case and it was noted that the claim case may not sustainable since both power and BSNL authorities have failed to produce PTCC approval documents and thereby lateral entrant could not be established.

In the meeting, it was observed that representative of neither A P Telecom Circle nor APEDCL were present. Accordingly, it was decided that the matter may be taken up in the next PTCC meeting.

You are requested to ensure that in the next meeting, representation from AP telecom circle and M/s APDCL should take place to give finality to the long pending issue.



RP
 (RP Pandey)
 Dy. Director (PTCC)

Copy for kind information to:

- | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------|
| <p>✓ 1. CGM, BSNL, Inspection Circle,
 Sanchar Vikas Bhawan, Residency
 Road, Jabalpur - 482001
 (Madhya Pradesh)</p> | <p>2. CMD, M/s APTRANSCO
 Vidyut Souda,
 Khairatabad
 Hyderabad-500 082</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------|

*Copy to DE PSC Chennai
 for early action pl.*

RP

R. P. Pandey
 (RP Pandey)
 Dy. Director (PTCC) 10/9/14

No.: -DET/PTCC -ER/14-15/ 03

Dated at Kolkata, the 12th Nov' 2014

To
The A.G.M./ PTCC,
Inspection circle, Jabalpur

Sub:- Agenda items for 99th CLPTCC meeting from PTCC/ER/Kol.(Modified)

Sir,

As per the instruction of AGM/PTCC, Inspection circle, Jabalpur, the agenda items of Eastern zone for 99th CLPTCC meeting, are mentioned below for your kind information and n/a pl.

1. Ensuring "zero level" on unguarded power crossings- From the Telecom circles of Eastern zone – Since couple of years no report till yet received (Latest Ref. letters are 1.DET/PTCC-ER/13-14/23 dated 6.8.2013, 2. DET/PTCC-ER/13-14/42 dated 19.12.2013, 3. CGM, Inspection circle, Jabalpur D.O. letter no. TD/LP-2015/97th CLPTCC /PART dated 30th Nov'2013..4.DET/PTCC-ER/14-15/01 dated 01.04.2014, 5.DET/PTCC-ER/14-15/02 dated 30.06.2014, 6. DET/PTCC-ER/14-15/03 dated 30.08.2014.

2. Arranging SLPTCC meeting- Several times, since the last three years, it was pursued to all Telecom circles and State power authorities of Eastern zone under DET/PTCC(ER), Kolkata for conducting SLPTCC meeting, but till yet no action has been taken from any Telecom circle in Eastern zone.

3. Nomination of members from DISCOM- Only 2 nominations were received from DISCOM- DVC, Kolkata and Power Grid, NE zone, Shillong.

Several times, it was pursued to all power authorities in eastern zone.

4. Shortage of technical staff in eastern zone- There is no technical staff under PTCC unit, Eastern zone, Kolkata except the DET at Kolkata, where 7 nos. Telecom circles are involved in this jurisdiction.

5. PTCC pending status in Eastern zone with Break Up

A. Pending with CEA ND for IV Computations	= 32
B. Pending with SEBs for IV Computations	= 14
C. Pending with BSNL/Railway for Telecom/ Railway Circuits	= 0
D. Pending with BSNL for Telecom details	= 26
E. Total pending cases up to 31.10.2014	= 72

The total Pending List is attached herewith as under:

DET/PTCC/ER/KOL

A. LIST OF PENDING CASES FOR IV CALCULATION TO BE APPROVED BY CEA, New Delhi.
(>33kv)

To
The A.G.M./ PTCC,
Inspection circle, Jabalpur

Sub.-: Agenda items for 99th CLPTCC meeting from PTCC/ER/Kol. (Modified)

Sir,

As per the instruction of AGM/PTCC, Inspection circle, Jabalpur, the agenda items of Eastern zone for 99th CLPTCC meeting, are mentioned below for your kind information and n/a pl.

1. Ensuring "zero level" on unguarded power crossings- From the Telecom circles of Eastern zone - Since couple of years no report till yet received (Latest Ref. letters are 1. DET/PTCC-ER/13-14/23 dated 6.8.2013, 2. DET/PTCC-ER/13-14/42 dated 19.12.2013, 3. CGM, Inspection circle, Jabalpur D.O. letter no. TD/LP-2015/97th CLPTCC /PART dated 30th Nov'2013..4. DET/PTCC-ER/14-15/01 dated 01.04.2014, 5. DET/PTCC-ER/14-15/02 dated 30.06.2014, 6. DET/PTCC-ER/14-15/03 dated 30.08.2014.

2. Arranging SLP TCC meeting- Several times, since the last three years, it was pursued to all Telecom circles and State power authorities of Eastern zone under DET/PTCC(ER), Kolkata

for conducting SLP TCC meeting, but till yet no action has been taken from any Telecom circle in Eastern zone.

3. Nomination of members from DISCOM- Only 2 nominations were received from DISCOM- DVC, Kolkata and Power Grid, NE zone, Shillong.

Several times, it was pursued to all power authorities in eastern zone.

4. Shortage of technical staff in eastern zone- There is no technical staff under PTCC unit, Eastern zone, Kolkata except the DET at Kolkata, where 7 nos. Telecom circles are involved in this jurisdiction.

5. PTCC pending status in Eastern zone with Break Up

A. Pending with CEA ND for IV Computations	= 32
B. Pending with SEBs for IV Computations	= 14
C. Pending with BSNL/Railway for Telecom/ Railway Circuits	= 0
D. Pending with BSNL for Telecom details	= 26
E. Total pending cases up to 31.10.2014	= 72

The total Pending List is attached herewith as under:

DET/PTCC/ER/KOL

O/o Divisional Engineer, PTCC(ER)
 Inspection (T&D) Circle, Kolkata
 P&T, Housing, Qtr. 12, Type-III
 11/1 Ultadanga Main Road, Kolkata-67



भारत संचार निगम लिमिटेड
 (भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
 (A Govt. of India Enterprise)

No.: -DET/PTCC -ER/14-15/06

Dated at Kolkata, the 22nd Oct' 2014

To The DGM/PTCC,
 Inspection circle,
 Jabalpur.

Sub:- Follow up action of Eastern Zone on decision taken in 98th CLPTCC meeting.

Sir,
 The present PTCC status of Eastern Zone as per agenda of 98th CLPTCC held on 30.05.2014 are mentioned below-


Sl.no.	Agenda item no.	Agenda	Present status as on 22.10.2014
1.	B.1	Ensuring "zero level" on unguarded power crossings	From the Telecom circles of Eastern zone - Since couple of years no report till yet received (Latest Ref.letters are 1.DET/PTCC-ER/13-14/23 dated 6.8.2013, 2. DET/PTCC-ER/13-14/42 dated 19.12.2013, 3. CGM, Inspection circle, Jabalpur D.O.letter no. TD/LP-2015/97 th CLPTCC /PART dated 30 th Nov'2013..4.DET/PTCC-ER/14-15/01 dated 01.04.2014, 5.DET/PTCC-ER/14-15/02 dated 30.06.2014, 6. DET/PTCC-ER/14-15/03 dated 30.08.2014.
2.	B. 2.2	Collection of legacy data for computerization of PTCC route approval process	From the Telecom circles of Eastern zone -no data till yet received. (Ref.letters from this unit to all Telecom circles of eastern zone - 1. DET/PTCC-ER/13-14/13 dtd.13.5.2013, 2.DET/PTCC-ER/13-14/30 dtd.9.9.2013. 3. DET/PTCC-ER/13-14/43 dated 19.12.2013 4. DET/PTCC-ER/13-14/55 dated 28.02.2014) 5) DET/PTCC-ER/14-15/01 dated 30.06.2014)
3.	B.5	Arranging SLPTCC meeting at regular intervals	No SLPTCC meeting held in Eastern zone since the couple of years though persuasion was done several times to all Telecom circles and State power authorities.(Latest Ref.letters are 1.DET/PTCC-ER/13-14/23 dated 6.8.2013, 2. DET/PTCC-ER/13-14/42 dated 19.12.2013 . 3. CGM, Inspection circle, Jabalpur D.O.letter no. TD/LP-2015/97 th CLPTCC /PART dated 30 th Nov'2013. 4. DET/PTCC-ER/14-15/01 dated 01.04.2014) 5. DET/PTCC-ER/14-15/02 dated 01.07.2014) 6. DET/PTCC-ER/14-15/03 dated 01.09.2014)
4.	B.7	Nomination of members from DISCOM	Only 2 nominations were received from Power Grid(N.E.)& DVC Though several times it was pursued to all power authorities.
5.	B.8	Pending PTCC approval cases in CEA	Pending PTCC approval cases in CEA=36 Nos.

DE(PTCC,ER.)
 INSPECTION CIRCLE,
 KOLKATA

Annex V

38/L

निरीक्षण परिमन्डल
संचार विकास भवन , रेसिडेन्सी रोड
जबलपुर - 482 001
(आई. एस.ओ. 9001:2008 प्रमाणित)
INSPECTION CIRCLE,
SANCHAR VIKAS BHAVAN,
RESIDENCY ROAD, JABALPUR 482 001



TD/LP-2014/13-14
To,

Dated:- 13/08/2014

All DET PTCC
Chennai/Mumbai/New Delhi/Kolkata

Subject:-Pending CLPTCC cases for IV calculation and training at CEA (ND) office.

As per draft minutes received of 98th CLPTCC held at Shillong on 30th may 2014, you are requested to kindly intimate Director PTCC ND (CEA) and asking suitable date for training so that IV calculation of pending RA cases in co-ordination with Power Authority can be resolved shortly & training for IV calculation can be obtained accordingly. Same may be intimate to this office also.

This is issued with the approval of competent authority.

[Signature]
13/8/14
AGM (PTCC)

O/o CGM Inspection Circle Jabalpur

Copy to :

1. PA to Sr. GM (HQ) for kind information please
2. Sr. GM (S&E) & Sr. GM (N&W) for kind information please
3. All field Addl GMs/DGMs for kind information and n/a please

FROM : DEM APT CHENNAI

FAX NO. : 24314894

Aug. 17 2005 11:57PM P.


Sri. Nagary. PTC

Central Electricity Authority
LD&T Division, NREB Complex
18-A Shaheed Jeeb Singh Marg
Katwaria Sarai
New Delhi-110016

No. Telecom/1/98-PTCC/ 3227

Date: 12.11.98

The Divisional Engineer (T)
PTCC, Southern Region,
50, No. 1, Usman Road,
MADRAS - 600 017



KIND ATTN. OF:-
DE (T), PTCC,
Chennai.

The Divisional Engineer (T)
PTCC, Western Region,
1st Floor, 462, S.B. Marg,
Phoenix Mill Compound
Lower Parel,
MUMBAI-400 013

Subject:- Follow-up action on minutes of 71st Central
PTCC Meeting held on 3rd September, 1998 at
Bhubaneswar - reg. entrusting the task of
Calculation of induced voltage in respect of
220 KV lines to SEBs/Power Utilities

Sir,


Please refer to Item No. 3.5(III) of the minutes of the 71st
Central PTCC Meeting held on 3rd September, 1998 at Bhubaneswar on
the subject cited above. After discussion it was decided that CEA
may entrust the work of I.V. computation in respect of 220 KV Tap/
LIL0 lines and Radial lines, where there is no effect of inter-state
line, on case by case basis against formal request from concerned
State Electricity Board/Power Utilities. CEA has no objection in
transferring this work to SEBs/Power Utilities.

We have received formal request from KEB, TNES & MSES, who
are willing to undertake the work of calculation of induced voltages
I.r.o. all 220 KV Tap/LIL0 lines and Radial lines. You are, therefore,
requested to please furnish telecom details of DOT circuits in
respect of such power lines to the concerned State Electricity Board
to enable them to calculate induced voltages on the parallel telecom
lines affected by these lines.

Yours-faithfully

(RAM SWARUP)
Director
Ph. 6565214
6565183

Circular file



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority [ISO: 9001: 2008]
भार प्रेषण एवं दूर संचार प्रभाग



Load Despatch & Telecommunication Division
एन.आर.ई.बी. परिसर, 18-ए, शहीद जौत सिंह सनसनवाल मार्ग, कटवारिया सराय
NRPC Complex, 18-A, Shaheed Jeet Singh S. Marg, Katwaria Sarai,
नई दिल्ली-110016
New Delhi - 110 016

No. CEA/LD&T/1/PTCC/2013-738-712

Date: 10-SEP-2014

- | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|
| <p>1. Chief Engineer (Project & Design),
Maharashtra State Power
Transmission Corporation Ltd.,
Prakashganga, Plot no. C-19, E-
Block, Bandra Kurla Complex,
Mumbai-400 051</p> | <p>2. Chief Engineer (SO)
State Load Despatch Centre,
KPTCL,
#28, RC Cross Road,
Bangalore-560 009</p> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|

Subject:- Charging of fee from Private utilities

Sir,

The issue of charging of fee from private utilities for processing of their PTCC cases was discussed in the past in central PTCC meetings. In 97th CLPTCC meeting, a Sub-Committee consisting of members from RRVPNL, CEA and BSNL was formed. The Sub-committee submitted its report in the last CLPTCC meeting wherein CEA and BSNL members had opposed charging of any fee, but RRVPNL was in favour of fee charging from private players.

During discussion in 98th Central PTCC meeting held on 30.05.2014, CEA stated that charging of fee from only private agencies would be a discriminatory decision. CEA also stated that BSNL, CEA and Railways are Central Govt. agencies and at present there is no provision in Electricity Act for charging of any fee, irrespective of any agency.

After detailed deliberations, it was decided that the strength of existing sub-committee may be enhanced by having representative from Karnataka and Maharashtra power utilities also. Thereafter, the issue of fee charging be again discussed in detail considering existing provisions in the Electricity Act and other related aspects.

You are therefore requested to send nomination from your organization on urgent basis.

RP Pandey
10/9/14

(RP Pandey)
Dy. Director (PTCC)



केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
भार प्रेषण एवं दूर संचार प्रभाग

[ISO: 9001: 2008]

**Load Despatch & Telecommunication Division**

एन.आर.ई.बी. परिसर, 18-ए, शहीद जीत सिंह सनसनवाल मार्ग, कटवारिया सराय
NRPC Complex, 18-A, Shaheed Jeet Singh S. Marg, Katwaria Sarai,
नई दिल्ली-110016
New Delhi - 110 016

No. CEA/LD&T/1/PTCC/2013-

723-724

Date: 10-SEP-2014

DET (PTCC), BSNL
Raj Bhavan Telephone Exchange,
1st Floor, No. 26, Sardar Patel Road,
Guindy, Chennai-32

Subject:- Decentralization of IV calculation for 220 KV power line to respective SEB

Sir,

During discussion in the last Central PTCC meeting, DET (PTCC), BSNL, Chennai informed that based on decision of 71st CLPTCC, two state power authorities are computing IV for 220 kV transmission lines. He desired the similar permission should be extended to other states of Southern region as well.

During discussion, DET (PTCC), BSNL, Chennai could not produce the copy of minutes of meeting of 71st CLPTCC and therefore further discussions in the matter could not be deliberated. Though the matter would be again taken up in the next meeting but it is pertinent to inform that during discussion in the last CLPTCC meeting, CEA stated that they have taken up a special drive to minimize the list of all pending PTCC cases from all the regions. As such, any specific provision for states from southern region will be inappropriate and desired that the PTCC cases of 220 kV & above transmission lines from all states including southern region should invariably be sent to CEA.

It was also pointed out that it has been observed that in some cases where there are NOC from both BSNL and the concerned Railways, the concerned DET, BSNL without taking comments from CEA, issue PTCC RA. He stated that though these cases have been cleared by DET, BSNL but remain pending in CEA database. The Committee decided that all DETs of BSNL should always take into consideration the CEA's comments before issuing PTCC RA of any case of 220 kV and above.

bsnl
10/9/14

Copy for kind information to:

CGM, BSNL, Inspection Circle, Sanchar Vikas Bhawan, Residency Road, Jabalpur - 482001
(Madhya Pradesh)

sd/-
(RP Pandey)
Dy. Director (PTCC)

R. P. Pandey
(RP Pandey)
Dy. Director (PTCC)

Annex VI/2

**Gist of Discussions of Sub-group for information of
Norms for PTCC clearance of HVDC lines**

Date/Time of Meeting: 10th November, 2014 at 15:00Hrs

Location of Meeting: Office of Director (PTCC), CEA, NRPC Complex, Katwaria Sarai, New Delhi-110016

Officers Present:

1. Sh. Naresh Bhandari, Director (PTCC), CEA
2. Sh. RP Pandey, Dy. Director (PTCC), CEA
3. Sh. S. Chandran, DET (North), BSNL
4. Sh. SK Singh, SDO (Telecom), North, BSNL
5. Sh. MR Chauhan AGM (HVDC), POWERGRID

Giving background, Director (PTCC), CEA stated that subsequent to discussion on the issue of PTCC route approval of HVDC line i.e. \pm 800kV Bishwanath Chariali - Agra in the last Central PTCC meeting, a sub-group having members from CEA, BSNL and Powergrid was formed.

The Terms of Reference for the Sub-group are as under:

- a) To study/ discuss in detail the impact of Induction during switching/ transient states of HVDC lines
- b) Recommend the detailed guidelines/ procedure to be adopted for PTCC clearance of HVDC lines, if required

Powergrid was requested to explain the existing system. Powergrid stated that in respect of \pm 800kV Bishwanath Chariali - Agra NR, the AC power at Bishwanath Chariali end is converted into DC power. There is provision of smoothing reactor to block ripple effect of harmonics. Three heavy filter banks are also provided to further avoid travel of any size of harmonic component. In other words, flow of DC power without any harmonic (s) is ensured. At receiving end i.e. Agra, again smoothing reactor coupled with three filter banks are provided. Besides this, there is additional provision of Blocking Filter whose purpose is to block induction in case it has been acquired due to parallel ac lines in the vicinity. Powergrid informed that all filter banks, smoothing reactor and blocking filter are properly earthed. Powergrid also informed that in the given conditions, there is no possibility of induction effects during switching / transient states of HVDC lines. **At the end of discussion, it was concluded that being DC power there is no possibility of electrical induction in the nearby underground telecom cables.** However, the committee members felt that Powergrid may supply relevant documents / papers for further study, for which Powergrid agreed.

In regard to HVDC, PTCC manual at page 134 has a copy of minutes of sub-committee meeting circulated on 03/02/1987 (a copy is enclosed for reference). In this also, the committee members had concluded no hazard due to induced voltage. However, stringent norms for taking care of induced noise voltage due to DC harmonic were considered due to absence of actual values of Rihand-Dadri 500 kV HVDC line. In last 27 years, the technology has evolved and Powergrid has confirmed complete blocking of harmonic components with installation of adequate filter banks at both ends in case of \pm 800kV line from Bishwanath Chariali to Agra.

Annexure - VII



MADHYA PRADESH POWER TRANSMISSION CO.LTD.
(A wholly owned Govt. of Madhya Pradesh Undertaking)
CIN: U40109MP2001SGC014880

Block No.3 Shakti Bhawan, Rampur, Jabalpur (M.P.)482008
Phone : (0761) 270-2164, 2135, 2134 Fax:(0761)2665593, e-mail:mptransco@nic.in

No.04-01/PTCC/1202/TRIV/ 7459

Dt. 29 SEP 2014

To,

**The Chief General Manager,
Inspection Circle,
Bharat Sanchar Nigam Ltd.,
Sanchar Vikas Bhawan,
Residency Road,
Jabalpur 482 001**

Sub: 99th Central PTCC meeting

Ref: Your letter No. CEA/LD&T/2014/PTCC/668 dt. 03.09.2014.

Dear Sir,

In reference to the letter dt. 03.09.2014 from CEA, New Delhi, please find enclosed herewith the Agenda item of MPPTCL, Jabalpur to be discussed during 99th Central PTCC meeting. It is requested to include our agenda for discussion in 99th Central PTCC meeting, so that pending PTCC approval could be discussed with the concerned officials and addressed by the Central PTCC.

Encl: As above.

Yours Sincerely,

Chief Engineer (Procurement)

Copy to:

1. The Director (PTCC), Central PTCC NRPC complex, 18A, Shaheed Jeet Singh Marg, Katwaria Sarai New Delhi 110016
- ✓ 2. The AGM, PTCC, T&D Circle, BSNL Sanchar Bhawan, Residency Road, Jabalpur-482001- It is requested to include our agenda for discussion in 99th Central PTCC meeting.
3. The Divisional Engineer (PTCC), Bharat Sanchar Nigam Limited, Juhudanda Administrative Building, 3rd floor, Juhutara Road, Santacruz (W) Mumbai 54
4. The CSTE, West Central Railway, 1st floor, Annex-II Building, Jabalpur 482001
5. The CSTE, Western Railway, 5th floor, Station Building, Church Gate, Mumbai
6. The CSTE, South Eastern Central Railway, Bilaspur 495004
7. The CSTE, North Central Railway, Gangaparisar, Allahabad 211001
8. The CSTE, Central Railway Annex Building, 3rd floor, CST, Mumbai 400001
9. The SDE (PTCC) Bharat Sanchar Nigam Limited, Room No.15, Annex Building, Door Sanchar Bhawan, Hoshangabad Road, Bhopal

AGENDA POINTS FROM M P POWER TRANSMISSION CO. LTD. JABALPUR FOR 99th CENTRAL PTCC MEETING IN REFERENCE TO LETTE NO. 668 DATED 03.09.2014 FROM DIRECTOR (PTCC) NEW DELHI

1) Computerization / digitalization of transmission lines, marking of telecom details by BSNL / Railways on the digital map of Survey of India:

As desired by the CEA, information regarding ratings of existing generating plants & substations up to 220kV has already been submitted to the CEA. Regarding coordinates of existing substations and the towers of existing lines, suitable instructions to our field officers have been issued for collecting the same at the earliest. Considering the huge network of MPPTCL, it is expected that considerable time will be required in collecting such data and the same shall be furnished at the earliest as possible.

2) PTCC ROUTE APPROVAL FOR 400KV & 220 KV LINES:

A) PTCC ROUTE APPROVAL FOR 400 KV LINES:

a. 400 line from 400kVS/s Chhegon to 400kV S/s Julwania (Case Mark No. MP-342):-

This case submitted vide letter No. 3098 dt. 28.4.12 has been registered by the DET(PTCC) Mumbai on dated 15.05.12. WR have submitted TCD to CEA for IV calculation. In the last meeting the SDE (PTCC) Bhopal has informed that the telecom details of BSNL has been sent to DET(PTCC) Mumbai vide the letter dt. 8.1.13 and the DET (PTCC) Mumbai has also forwarded the same to Director (PTCC) New Delhi for IV calculation vide letter dt. 14.8.14. Action in this regard has to be taken by the Director (PTCC), New Delhi.

The Central PTCC is requested to issue necessary directives for an early action in the matter.

b. PTCC Route approval for construction of 400 DCDS line from Malwa (Singhaji) TPH to 400kVS/s Pithampur (Case Mark No. MP-343):-

This case submitted vide letter No. 3120 dt. 30.04.12 has been registered by the DET(PTCC) Mumbai vide letter dated 15.05.12. The Dy. CSTE(WR) vide letter dated 20.06.12 has furnished WR telecom route details to the Director (PTCC) New Delhi. The SDE(PTCC) Bhopal vide letter dated 27.12.12 has

forwarded BSNL telecom details to the DET(PTCC) Mumbai for further submission to the Director(PTCC) New Delhi. The DET (PTCC), Mumbai has informed that the telecom details have already been sent to CEA, New Delhi vide letter dt. 14.8.14 for IV. Accordingly, Director (PTCC) New Delhi has issued IV on dt. 12.09.14. Regarding the telecom details of WCR, the railway authorities has issued NOC. Comments/NOC from WR and BSNL are awaited.

The Central PTCC is requested to issue necessary instructions in the matter.

B) PTCC ROUTE APPROVAL FOR 220 KV LINES:

a. 220 KV Chhindwara Betul DCDS line (Case Mark no. MP-258):

Date of proposal : 07.10.2006.

SEC Railway telecom circuits and BSNL telecom circuits were forwarded to the Director(PTCC) New Delhi vide letter no. SECR/S&T/PTCC/MP-CG/1689 dated 26.10.06 and letter dated 08.03.07 of DET(PTCC) Mumbai for calculation of induced voltage. CR telecom circuits was also forwarded to the Director (PTCC) New Delhi vide letter no. 153/PTCC/220KV/187 dated 26.10.09 or AESTE(Tele)HQ, CR, Mumbai. Subsequently, the Director (PTCC) New Delhi vide their letter No. CEA/LD&T/PTCC/2012/MP-316/587 dt. 02.07.12 on BSNL & SECR Telecom Circuits and vide letter dt. 25.6.14 on CR Telecom Circuit Details has been forwarded the calculation of IV on both BSNL and Railway Telecom Circuits. NOC has been issued by CR vide letter dt. 14.7.14 on IV. The case is pending due to NOC/Comments of BSNL and SECR on IV.

The Central PTCC is requested to issue necessary instructions in the matter.

b. PTCC route approval for LILO of one circuit of 220KV DCSS Bhopal-Ashok line at proposed 220KV Mungalia Chhap (MP-390)

This case was submitted vide letter no. 16 dated 01.01.2014 for registration to DET (PTCC) Mumbai & for telecom circuit details to SDE (PTCC) Bhopal and CSTE, WR, Mumbai. The case has been registered by DET (PTCC) Mumbai. TCD of BSNL has been forwarded by DET (PTCC) Inspection Circle Mumbai vide letter dt. 14.8.14. Submission of telecom details from WR is awaited.

The Central PTCC is requested to issue suitable instructions in the matter.

- c. **220KV DCSS line from 220KV S/s Daloda to 100.50MW Wind Energy Generation Power Plant at Daloda Distt. Mandsaur of M/s Renewable Energy Generation Pvt. Ltd. (MP-396)**

This case was submitted vide letter dt. 17.5.14 for registration to DET (PTCC), Mumbai and for telecom circuit details to SDE (PTCC), Bhopal and CSTE, WK, Mumbai. The Case has been registered by DET (PTCC) vide letter dt.9.6.14. Telecom circuit details of BSNL and WR has been forwarded by DET (PTCC) Inspection Circle, Mumbai for IV calculation to CEA vide letter dt. 14.8.14.
The Central PTCC is requested to issue suitable instructions in the matter.

- d. **LILO of one circuit 220KV DCDS Bhopal-Bina line at S/s Ganjbasoda (Case Mark No.MP-404)**

The case is submitted recently vide letter No.5914 dt. 02.08.2014 for registration of DET (PTCC) Mumbai & submission of Telecom circuit details from SDE (PTCC),Bhopal & WCR. The case has been registered by DET (PTCC) vide letter dt 13.08.14. Telecom circuit details awaited from BSNL and WCR. The Central PTCC is requested to issue suitable instructions in the matter.


C) PTCC ROUTE APPROVAL FOR 132 KV LINES (PENDING CASES):

The PTCC route approval cases upto the level of 132kV are generally in the scope of in State Level PTCC meetings. However, a list indicating the present status and action to be required from various offices is attached herewith as Annexure-I for reference of Central PTCC. It may be observed from the list that 06 No. with Railways (with WCR 02, with NCR 01, with CR 01, with WR 02) and 14 cases with BSNL are pending due to non submission of relevant documents and need to be expedited. The Central PTCC may issue suitable instructions to all concern for early disposal of these cases also.


**SUPERINTENDING ENGINEER (TRANS)
O/O CHIEF ENGINEER (PROCUREMENT)**

Pending route approval cases of 132KV lines (MPPTCL)99th PTCC meeting

Sr. No	Name of line	Case mark No.	Status	Action require d
1	132KV DCSS line for Narmada Phase-III water supply project at Baklai from 220KV S/s Barwaha	MP-315	IV submitted on 29.11.12	Comment on IV from WR awaited
2	132kv Sabalgarg(220kv)- Vijaypur single Ckt line	MP-337	IV submitted on 30.01.14	Comments on IV from NCR awaited.
3	132kv DCSS line from 400KV S/s Chhegaon to 132KV S/s Moondi	MP-377	IV submitted. NOC of WCR received.	Comments on IV from WR awaited.
4	132KV DCSS line from 220kv Mandideep to 132kv S/s plant of M/s Procter & Gamble Ltd., Mandideep	MP-366	IV submitted on 31.1.14. NOC of WCR received vide letter dt. 3.3.14	RA awaited from DET (PTCC), Mumbai
5	132kv LILO line from Indore-Barwaha for proposed 132kv S/s Simrol	MP-365	IV submitted on 27.7.14. NOC issued by WR.	RA awaited from DET (PTCC), Mumbai.
6	132KV DCSS line from 220KV S/s Sujalpur to 132KV S/s Pachhor	MP-388	TCD received from WR & WCR on 26.2.14 & 8.1.14	TCD awaited from BSNL.
7	132Kv DCSS line from 220KV S/s Pipariya to 132KV S/s Semri Harchan	MP-383	IV submitted vide letter dt. 17.7.14	NOC/comments from BSNL /WCR awaited.
8	132KV DCSS line from 220KV Handiya to 132K S/s Satwas	MP-386	TCD received from WCR	TCD awaited from BSNL
9	132KV DCSS line from Ghatabillod to 132KV S/s Betma	MP-387	TCD received from WR vide letter dt. 17.1.14	TCD from BSNL awaited
10	132KV DCSS line from 220KV S/s Itarsi to 132KV S/s Nasrullaganj	MP-389	TCD received from CR & WCR	TCD from BSNL awaited
11	132KV DCSS line from Rajgarh 220KV S/s to 50 MW SPV plant being setup by NTPC	MP-391	NOC issued by WCR	TCD awaited from BSNL
12	132KV DCDS line for LILO of 132KV Pandurna-Boregaon S/c line at proposed 132KV S/s at M/s CLC Textile Park Pvt.Ltd. near village Hiwarasendwar, Teh. Pandurna Distt. Chhindwara.	MP-392	TCD received from BSNL	Letter of registration awaited from DET (PTCC). TCD awaited from CR.
13	132KV DCSS line from 132KV S/s Lahar to 132KV S/s Seondha line	MP-400	TCD received from NCR	TCD awaited from BSNL
14	132KV DCDS line for LILO 132KV Sironj-Maksudangarh line at proposed 132KV S/s Lateri	MP-401	TCD received from WCR	TCD awaited from BSNL
15	Construction of 132KV DCSS line from 132KV S/s Porsa to 132KV S/s Ambha.	MP-402	TCD received from NCR	TCD awaited from BSNL.
16	Construction of 132KV DCDS line from 132KVS/s Ganjbasoda to Saharwasa)	MP-403	Case registered by DET (PTCC)	TCD from BSNL and WCR is awaited.
17	Construction of 132KV DCSS Badod-A lot line	New Case	Registration awaited from DET (PTC), TCD awaited from WCR & BSNL	Registration from DET (PTCC), Mumbai awaited. TCD awaited from BSNL & WCR
18	Construction of 132KV DCSS line from proposed 220KV S/s Datia to proposed 132KVS/s Indergarh	New case	TCD from NCR received	TCD from BSNL and registration from DET (PTCC) Mumbai awaited.


EXECUTIVE ENGINEER (TRANSMISSION)
O/O CHIEF ENGINEER (PROCUREMENT)
MPPTCL - JABAI DIV

Annex - VII/2

BHARAT SANCHAR NIGAM LIMITED

O/o D.E.T.(PTCC), Inspection Circle ,
Santacruz (W),Mumbai -400054.

Phone No.-022-26611530,26608521

To,
The A.G.M.(PTCC)
O/o C.G.M., Inspection Circle,
Jabalpur.

No. IC/ MBI/PTCC/CLPTCC /Meeting / 46

dated 16.10.2014.

Sub: Compliance on agenda for the 99th Central PTCC meeting submitted by MPPTCL, Jabalpur .

Ref. Chief Engineer (Procurement),MPPTCL, Jabalpur office letter no. 04-01/PTCC/1202/TR IV/7459
Date 29.09.14.

With reference to the subject cited above, please find herewith the compliance on agenda for the 99th Central PTCC meeting submitted by MPPTCL, Jabalpur.

This is for kind information & needful action please.

DET(PTCC)
Inspection Circle ,
Mumbai -54.

Copy to

1. The Director (PTCC), CEA, New Delhi-16.
2. The D.G.M., A/T, Mumbai.
3. The Chief Engineer (Procurement), MPPTCL, Jabalpur.

Compliance for the agenda submitted by MPPTCL, Jabalpur for 99th CLPTCC meeting

1. Computerization/Digitalization of transmission line - To be discussed in the meeting

2) PTCC Route approval for 400KV & 220KV lines

A) PTCC Route approval for 400KV lines

Sl. No.	Name of the power line	Date of reference	DET(PTCC) File No.	Pending for	Remark
a	400KV DCSS line from Chhegaon TPH - Jhulwania	28.04.12	342	IV from CEA	IV detail called from CEA on 14.08.14
b	400KV DCDS line from Malwa (Singhaji) TPH - Pithampur	30.04.12	343	NOC from WR	NOC called from WR on 16.09.14

B) PTCC Route approval for 220KV lines

a	220KV D/C Chhindwara -Betul	07.10.06	258	NOC for CR	NOC from CR called on 25.06.14
b	220KV DCDS LILO line on Bhopal -Ashta line for 220KV Mungaliya Chhap	01.01.14	390	IV from CEA	IV detail called from CEA on 14.08.14
c	220KV DCSS line from 220KV Daloda s/s - 110MW Wind Energy Generation power plant at Daloda	17.05.14	396	IV from CEA	IV detail called from CEA on 14.08.14
d	220KV DCS LILO line from Bhopal - Bina line for Ganjbasoda	02.08.14	404	TD from BSNL & RD from WCR	TD from BSNL & RD from WCR called on 13.08.14

C) PTCC Route approval for 132KV lines

Sl. No.	Name of the power line	Date of reference	DET(PTCC) File No.	Pending for	Remark
1	132KV D/C line for Narmada Phase -III Water Supply project at Baklai from 220KV Barwaha s/s	22.02.11	315	NOC from WR	NOC / Comments from WR called on 29.11.12.
2	132KV DCSS line from Sabalgarh - Vijaypur	02.03.12	337	NOC from NCR	NOC from NCR called on 30.01.14
3	132KV DCSS line from 400KV Chhegaon - 132KV Moondi s/s	27.04.12 08.03.13	377	RD from WCR / WR as well as TD from BSNL	RD / NOC from WR/WCR called on 26.04.13 .Incomplete TD received.Revised TD /Check list called on 03.05.13
4	132KV DCSS line from Mandideep - M/s Procter & Gamble Ltd., Madideep		366		RAC issued on 09.04.2014
5	132KV DCDS LILO line on 132KV Indore - Barwaha line for 132KV Simrol s/s	04.12.12	365	NOC from WR	NOC from WR called on 25.07.14.

6	132KV DCSS line from Shujaipur - Pachor	31.10.13	388	RD from WCR as well as TD from BSNL	TD from BSNL, RD from WCR called on 13.11.13
7	132KV DCSS line from 220KV Pipariya s/s-132KV Semri Harchan s/s.	07.08.13	383	NOC from WCR	NOC from WCR called on 17.07.14
8	132KV DCSS line from 220KV Handiya - 132KV Satwas	30.09.13	386	TD from BSNL	TD from BSNL called on 21.10.13
9	132KV DCSS line from Ghatabillod - Betma	31.10.13	387	TD from BSNL	TD from BSNL called on 13.11.13
10	132KV DCSS line from 220KV Itarsi - 132KV Nasurallaganj	10.12.13	389	RD from CR / WCR as well as TD from BSNL	TD from BSNL, RD from CR / WCR called on 28.12.13
11	132KV DCDS line from Raigarh - 50MW Photo Votac Plant of M/s NTPC Ltd. At village Ganeshpura	24.01.14	391	TD from BSNL	TD from BSNL called on 22.02.14
12	132KV DCDS LILO line on Pandurna- Boregaon line for proposed 132KV s/s at M/s CLC Textile Park Ltd.near Hiwarasenadwar	12.02.14	392	IV from MPPTCL	IV from MPPTCL called on 10.07.14
13	132KV DCSS line from 132KV Lahar - 132KV Seondha	16.07.14	400	TD from BSNL & RD from NCR	TD from BSNL & RD from NCR called on 01.08.14
14	132KV DCDS LILO line for Lateri from 132KV Sironj - Maksudangarh	19.07.14	401	TD from BSNL	TD from BSNL called on 08.08.14
15	132KV DCSS line from 132KV Porsa - Ambha	22.07.14	402	TD from BSNL & RD from NCR	TD from BSNL & RD from NCR called on 08.08.14
16	132KV DCSS line from Ganjbasoda - Saharwasa	31.07.14	403	TD from BSNL & RD from WCR	TD from BSNL & RD from WCR called on 13.08.14
17	132KV DCSS line from Badod - Alot	14.08.14	406	TD from BSNL & RD from WCR	TD from BSNL & RD from WCR called on 09.09.14
18	132KV DCSS line from Datia - Indergarh	21.08.14	407	TD from BSNL & RD from NCR	TD from BSNL & RD from NCR called on 09.09.14

Abbreviations TD-Telecom detail from BSNL

IV-Induced Voltage calculation

RD-Railway Telecom detail from concerned railways

CR- Central Railway,Mumbai

WR- Western Railway,Mumbai

WCR- West Central Railway,Jabalpur

NCR-North Central Railway,Allahabad

VII/3

No: AEGCL/GM(P&E)/PTCC/GT09/Pat-II / 399

DIU. 14.10.14

To,

The Assistant General Manager, (PTCC)
O/o The CGM, Inspection Circle,
Sanchar Vikas Bhawan,
Residency road, Jabalpur – 482001
E-mail : agmsw@rediffmail.com

Sub : Agenda items for the 99th CLPTCC meeting.

Ref : Letter No. TD/LP/2015/CLPTCC meeting/98-99th Dtd. 16.09.2014

Dear Sir,

In inviting reference to above, furnished herewith the Agenda items for 99th CLPTCC meeting.


Agenda Items for the 99th CL PTCC meeting:

PTCC Route Approval for the following Power Lines are awaited.

1. 132 kV DC LILO transmission line to Rupai GSS.
2. 132 kV transmission line from Samaguri GSS to Nagaon (Khaloi Gaon) SS.
3. 400 kV DC LILO of 400 kV Palatona-Bongaigaon transmission line at Azara (Gohaihat, Mirza).
4. 132 kV LILO transmission line for Jorhat (West) SS from existing Bokakhat-Jorhat (Gormur) line.
5. 220 kV LILO transmission line at Namrup from Tinsukia-Namrup existing line.
6.
 - a. 132 kV DC Chandrapur-Kahilipara transmission line LILO at Sonapur SS.
 - b. 132 kV DC Sonapur- Baghjap (Jagiroad) transmission line.

Thanking you,


Sincerely Yours,



General Manager, (P&E)
Assam Electricity Grid Corp. Ltd.
Narangi, Guwahati – 781026

VII/4

Inbox : Read Mail [[Back to Inbox](#)]

 [Printable Format](#) | [Show full Headers](#)

From: DETPTCCERKOLKATA <detptccer@gmail.com> | [Add to Address book](#) **This is spam**
To: agm sw <agmsw@rediffmail.com>, Ganesan V <dgmatgh@gmail.com>
Subject: Re: Agenda for 99th CLPTCC Meeting
Date: Wed, 15 Oct 2014 23:54:49 IST

Note: To help protect your privacy, images from this message have been blocked. [View images](#) | [What is this?](#)

Regarding Compliance of Agenda Points of GM(P&E), Assam Elect. Grid COR, Guwahati, vide letter No. AEGCL/GM(P&E)/PTCC/G109/Part-II/399, dated 14-10-14 the following Update is hereby submitted as :

- 1) 132 KV DC LILO transmission line to Rupai GSS---Railway NOC is awaiting
- 2) 132 KV transmission line from Samaguri GSS to Nagaon(Khaloi Gaon)SS---IV is beyond the limit
- 3) 400 KV DC LILO of 400 KV Palatona-Bongaigaon transmission line at Azara--- Certificate issued on 08-10-14 is to be collected
- 4) 132 KV LILO transmission line for Jorhat (West) SS from existing Bakahat-Jorhat(Gormur)----Sent for Telecom Survey on 24-09-14
- 5) 220KV LILO transmission line at Namrup from Tinsukia-Namrup existing Line----Railway NOC awaiting

And regarding rest Sl. No. 6a & 6b ,the files are not with the PTCC ER Division as per record.

This is for kind information and necessary action pl

with regards

DET/PTCC/ER

Inspection Circle Kolkata

On Tue, Oct 14, 2014 at 6:01 PM, agm sw <agmsw@rediffmail.com> wrote:



DAMODAR VALLEY CORPORATION

(ESTABLISHED BY THE ACT XIV OF 1948)

ELECTRICITY DEPARTMENT, **SPE Section** (Formerly PSR Section)

9th Floor, DVC TOWERS, VIP ROAD, KOLKATA - 700 054

FAX: (033) 2355-9618

PHONE: (033) 66072932/38/2355-6043

Website: www.portal.dvc.gov.in

No. EDCON/SPM/PTCC/998

Date: 13.10.14

To,
The Chief General Manager
Inspection Circle
Bharat Sanchar Nigam Ltd
Sanchar Vikas Bhawan,
Recidency Road, Jabalpur-482001

Sub: - Agenda items for the 99th Central PTCC meeting in respect of DVC


Ref: - Letter No : LD & T/2014-PTCC/661 dtd. 03.09.14

Dear Sirs,

Reference above, we are enclosing herewith Annexure-1(2 sheets) indicating the transmission lines pertaining to DVC for which PTCC proposals have already been submitted but PTCC clearances for the said transmission lines have not yet received.

You are requested to please take necessary action for inclusion of the above in the Agenda items for discussion in the 99th Central PTCC meeting.

Encl.: As stated



Yours faithfully,

(P. K. Das)

DY. Chief Engineer (SPE)

Copy to:

The Director (PTCC), Central PTCC, Load Despatch & Telecommunication Division, Central Electricity Authority, NREB Complex, 18A, Shaheed Jeeb Singh S Marg, New Delhi-110016 ----- along with enclosure as above.

Red on 31/10/14

Forwarded to DE PTCC Kolkata for n/a pl.

MHE

31/10/14


AGENDA ITEMS FROM DVC FOR 99th CENTRAL PTCC MEETING TO BE HELD

Annexure-I

Sl. No.	Name of the DVC Line	PTCC Proposal submitted to			Remarks
		The DE(T), PTCC, Kolkata	The Director (PTCC), CEA, New Delhi	Eastern / East Central / South Eastern Railway	
1	132KV D/C from Northkarapura to NTPC, Tandwa	No. EDCON/EHV/PTCC/1925 dated 21.10.2009.	No. EDCON/EHV/PTCC/1925 dated 21.10.2009.	No. SET/Wks/104/573 dated 17.10.2009.	Marked topsheet resubmitted as original could not be located by DET, PTCC, ER
2	132KV D/C LILO of Barhi-Konar line at Koderma TPS S/s.	No. EDCON/EHV/Koderma/214 7 dated 17.11.2009.	No. EDCON/EHV/Koderma/2147 dated 17.11.2009.	No. SET/Wks/104/581 dated 04.11.2009.	Clearance awaited from CEA, PTCC Delhi / DET, PTCC ER, Kolkata
3	132KV S/C Line for Maithon Alloy Ltd. and Impex Ferro Alloy Ltd.	No. EDCON/EHV/PTCC/876 dated 02.01.2009.	No. EDCON/EHV/PTCC/876 dated 02.01.2009.	No. EDCON/EHV/PTCC/876 dated 02.01.2009.	Clearance awaited
4	132KV S/C Line for Ispat Damodar Ltd. (S/C LILO from Ramkanali-DTPS line)	No. EDCON/EHV/PTCC/122 dated 18.09.2008.	No. EDCON/EHV/PTCC/122 dated 18.09.2008.	No. EDCON/EHV/PTCC/122 dated 18.09.2008.	-Do- IV calculation sent to DET, PTCC ER on 18.09.08
5	132KV S/C LILO of Ramkanali-DTPS line at Jamuria	No. EDCON/EHV/PTCC/139 dated 18.03.2009.	No. EDCON/EHV/PTCC/139 dated 18.03.2009.	No. EDCON/EHV/PTCC/139 dated 18.03.2009.	Clearance awaited from CEA, PTCC Delhi / DET, PTCC ER, Kolkata
6	132KV D/C CTPS-BIADA line (presently charged at 33KV level)	No. EDCON/EHV/PTCC/139 dated 18.03.2009.	No. EDCON/EHV/PTCC/139 dated 18.03.2009.	No. EDCON/EHV/PTCC/139 dated 18.03.2009.	-Do-

<p>220KV D C Kalyanswari- Pithakari</p>	<p>No. TSC-II/W-8/1091 date 18.09.2010 No. TSC-II/W-8/105 date 18.01.2011</p>	<p>No. TSC-II/W-8/1051 date 18.09.2010 No. TSC-II/W-8/105 date 18.01.2011</p>	<p>No. TSC-II/W-8/1091 date 18.09.2010 No. SC-II/W-8/105 date 18.01.2011 (RK; compliance done by DVC)</p>	<p>-Do- I DET/PTCC. ER sent letter to PTCC, Delhi New Delhi on 06.10.10 requesting comments of LF induction. 2) E Rail Authority Sent letter to PTCC, Delhi on 28.01.11 to furnish IV & subsequently Railway has forwarded clearance to PTCC ER, Kolkata</p>
-----------------------------------------------------	-------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Inbox : Read Mail [[Back to Inbox](#)]

 [Printable Format](#) | [Show full Headers](#)

From: DETPTCCERKOLKATA <detptccer@gmail.com> | [Add to Address book](#) **[This is spam]**

To: agm sw <agmsw@rediffmail.com>

Subject: Re: Agenda items for 99th CLPTCC from DVC Kolkatta

Date: Sat, 01 Nov 2014 11:37:32 IST

Note: To help protect your privacy, images from this message have been blocked. [View images](#) | [What is this?](#)

Regarding Agenda items for the Central PTCC meeting in respect of DVC, the compliance is hereby sending as per following details recorded:

- 1) 132 KV D/C from Northkaronpura to NTPC, Tandwa----- IV not received from DVC
- 2) 132 KV D/C LILO of Barhi-Konar line at Koderma TPS S/s----- Railway NOC not Received
- 3) 132 KV S/C Line for Mithon Alloy Ltd. and Impex Ferro Alloy Ltd.---- -Do-
- 4) 132 KV S/C Line for Ipsat Damodor Ltd. ----- -Do-
- 5) 132 KV S/C LILO of Ramkanali DTPS line at Jamuria----- -Do-
- 7) 220 KV D/C Kalyaneswari-Pithakari----- -Do-

and regarding Sl. No. 6 the file is not with the office of DET/PTCC/ER/Kol as per record.

This is for your kind information and necessary compliance.


With Thanks,

DET/PTCC/ER
Inspection Circle Kolkata

On Fri, Oct 31, 2014 at 3:35 PM, agm sw <agmsw@rediffmail.com> wrote:

 Get your own **FREE** website, **FREE** domain & **FREE** mobile app with Company email. [Know More](#)
≥

With regards,
DET PTCC (E/R), KOLKATA
Email: detptccer@gmail.com

	<p align="center">RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED (An ISO 9001-2008 Certified Company) [Corporate Identity Number(CIN): U40109RJ2000SGC016485] Regd. Office: Vidyut Bhawan, Jyoti Nagar, Jaipur-302005 OFFICE OF EXECUTIVE ENGINEER (PTCC), JAIPUR PRASARAN BHAWAN, AJMER ROAD, JAIPUR -302020 (Tel: 0141-2250700 Extn: 118 & Fax: 0141-2250087) Email: xen_ptcc@rvpn.co.in ; Website: www.rvpn.co.in</p>
-----------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

No. RVPN/ZCE(T&C-JPZ)/XEN(PTCC)/JPR/F.501-XI/D. 320 Dated 05.11.2014

The Chief General Manager,
Inspection Circle,
Bharat Sanchar Nigam Ltd.,
Sanchar Vikas Bhawan,
Residency Road,
Jabalpur-482001

SUB: Agenda items for 99th Central PTCC meeting to be held on November 27, 2014 at Jabalpur (MP).

REF: i) letter no. LD&T/PTCC/2014/850 dated 28/10/2014 of Dir (PTCC), CEA, New Delhi.

With reference to the above kindly find enclosed herewith agenda items for 99th Central PTCC Meeting to be held on November 27, 2014 at Jabalpur (MP) for your kind information & necessary action.

Encl: As above

[Signature]
05.11.14

(D.S. Jangid)
Chief Engineer (T&C),
RVPN, Jaipur

Copy submitted/forwarded to the following with a copy of Agenda Items for kind information & necessary action:

1. The Director (Telecom), Room No. 123, Railway Board, Rail Bhawan, New Delhi-110001.
2. The Director(PTCC) & Secretary Power, Central Electricity Authority, LD&T Division, NREB Complex, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110016.
3. The Addl. General Manager (NWO- CEA), BSNL O/O chief General Manager, Sardar Patel Marg, C-Scheme, Jaipur.
4. The Divisional Engineer Telegraph (PTCC), O/o GM (North), Inspection circle, CTS compound, Nataji nagar, New Delhi-110023.
5. The Sub Divisional Engineer(PTCC), Inspection circle(T&D), Q. No.1, Ground Floor, Sanganeji Gate Telephone Exchange, Jaipur- 302003.

Encl: As above

[Signature]

PE incorporate in agenda items.

[Signature]
Sr GM (HA)

[Signature]
13/11/14

[Signature]

(A.K.Verma)
Executive Engineer (PTCC),
RVPN, Jaipur

AGM (PTCC)

[Handwritten notes]
DGM (T)
28/11/14
Lal Singh
13/11/14

11 incorporate 15/11

**AGENDA ITEMS FOR THE CENTRAL LEVEL PTCC MEETING TO BE HELD
ON 27.11.2014**

1. PTCC case of EHV power lines of RVPN, Jaipur pending with DET (PTCC), New Delhi for want of PTCC route approval certificate.

S. No.	Name of Power Lines
1	400KV S/C Bikaner-Merta.
2	220 KV D/C Jaipur(South PG)-Vatika.
3	220 KV D/C LILO to 400 KV Ajmer from Kishangarh-Ajmer line.
4	220 KV D/C Bali-Falna TSS of M/s DFCC Line.
5	220 KV LILO to Deedwana from Khuchaman-Dhod line.

The DET (PTCC), BSNL, New Delhi is requested to issue the PTCC route approval certificate for the above power lines at the earliest.

2. Telecom details of the following EHV power lines are awaited from the DET (PTCC), Northern Region, BSNL, New Delhi.

S. No	Name of Power Lines	Ref. which sent	vide case	Pending At
	[I] 400 KV Lines			
1	400 KV LILO TO JODHPUR (NEW) FROM Merta-JODHPUR.	D.201 dated 01.08.2014		AGM(Outdoor),Jodhpur/SDOT,Jodhpur
	[II] 220 KV Lines			
2	220 KV D/C Bilara-Haripura line for DFCCIL.	D.226 dated 13.08.2014		AGM(Outdoor),Jodhpur/SDOT,Bilara
3	220 KV D/C Pali-Kharchi(Marwar Jn.) for DFCCIL.	D.270 dated 18.09.2014		DE,Pali/SDOT,Pali/SDOT,Kharchi(Marwar Jn.)
4	Shifting of 220 KV Ratangarh-STPS line passing through proposed 2x 660 MW unit no. 7 & 8 of STPS	D.289 dated 07.10.2014		DE,Suratgarh/SDOT,Suratgarh
5	220 KV S/C Nawalgarh(PPP)-Jhunjhunu .	D.306 dated 20.10.2014		DE(Phones),Nawalgarh/SDE(Phones), Nawalgarh

[III] 132 KV Lines			
6	132 KV LILO to Niwana from Chomu-Markhi line.	D.213 dated 06.08.2014	DE(Rural),Jaipur/ SDOP,Chomu
7	132 KV D/C line from 220 KV GSS Nawalgarh(PPP) to Nawalgarh line.	D.249 dated 02.09.2014	DEP,Nawalgarh/SDOP,Nawalgarh
8	132 KV D/C Niwana-Govindgarh.	D.267 dated 12.09.2014	DE(Rural),Jaipur/ SDOP,Chomu

Therefore, DET (PTCC) may kindly be requested to expedite the telecom details from the concerned telecom authorities.

3. IV calculation of the following EHV power lines are awaited from DIR (PTCC), CEA, New Delhi.

S.No.	Name of Power Lines	Case processed on dtd.	Details sent to DET(PTC C), BSNL, New Delhi	Case pending with Dir(PTCC), CEA for I.V computation
1	400 KV LILO to Jodhpur (New) from Rajwest -Jodhpur.	02.07.2014	10.10.2014	
2	220 KV LILO to Udaipur from Debari-Chhitorgarh.	14.06.2013	31.03.2014	16.04.2014
3	220 KV D/C Pratapgarh-Banswara.	29.10.2013	22.09.2014	
4	220 KV D/ C Pindwara-Pindwara TSS for DFCC.	19.05.2014	27.06.2014	
5	220 KV LILO to Behror from Kotputli-Neemrana.	19.05.2014	01.10.2014	
6	220 KV LILO to Kotputli(PGCIL) from Kotputli-Manoharpur	27.05.2014	07.10.2014	