



Government of India
Central Electricity Authority
SP&PA Division
R.K. Puram, New Delhi -110066



No.-1/9/2011-SP&PA/

dated 04.08.2011

To

As per list

Subject: Corrigendum to Minutes of 27th Standing Committee Meeting of Power System Planning of Northern Region Held on 30.5.2009

Sir,

It is intimated that BBMB had pointed out that in last para of item no. 12, LILO of 400 kV Bahadurgarh- Hissar line has been mentioned whereas no such line exists. In this regard it is clarified that the above error has been acknowledged and corrigendum for the same is enclosed herewith at Annex.

As mentioned in the enclosed corrigendum, LILO of Bahadurgarh- Hissar 400 kV line mentioned in the last para of item no. 12 of the minutes is in fact **LILO of Bahadurgarh – Bhiwani(BBMB)-Hissar 400 KV** line. It is also mentioned that direct interconnection of 400 kV Mohindergarh- Bhiwani (PG) D/c line with the **LILO of Bahadurgarh – Bhiwani(BBMB) 400 kV line** is an interim arrangement till Bhiwani(PG) substation is commissioned.

Regarding commercial issues, if any, the same may be discussed and sorted out separately at an appropriate forum such as NRPC or CERC as necessary as per relevant regulations.

This issues with the approval of Member (PS), CEA.

(B.K.SHARMA)
Director (SP&PA)

Copy to:

1. Shri Y.K.Sehgal, E.D.(SEF), PGCIL, Saudamini,Plot No.2, Sector-29, Gurgaon-122001
2. Shri R.S. Lamba, Chief Engineer (Power Regulation),BBMB,SLDC complex,Industrial Area, Chandigarh-160002
3. Shri V.K.Agrawal, G.M., NRLDC, 18/1, S.J.S.S.Marg, Katwaria Sarai, N.Delhi-110015

Corrigendum to Minutes of 27th Standing Committee Meeting of Power System Planning of Northern Region Held on 30.5.2009

The last para of item no. 12 may be re-read as follows:-

“Powergrid stated that investment approval & award of Bhiwani S/S was in process and it would take around 3 years for the new S/S. Member (PS) stated that Bhiwani (new) S/S of Powergrid is also to be connected through LILO of **Bahadurgarh – Bhiwani(BBMB)-Hissar 400 KV line**. It was suggested that Powergrid should take up **the works for LILO of Bahadurgarh-Bhiwani(BBMB) 400 kV line** on priority so as to provide connectivity to Mohindergarh – Bhiwani(PG) line of APL directly by connecting to **the LILO of 400 kV Bahadurgarh-Bhiwani(BBMB) line**. With this arrangement, M/s Adani would get reliable connectivity to the grid for safe operation of their HVDC line in the event of outage of Mohindergarh-Mohindergarh (HVDC) line. Subsequently, when Powergrid’s Bhiwani substation was completed, the arrangement as per the planned system may be implemented.”

List of Addressee:-

1. Member Secretary NRPC, 18-A Shajeed Jeet Singh Sansanwal Marg, Katwaria Sarai, New Delhi – 110016 (Fax-011-26865206)	6. Director (Transmission) UPPTCL, Shakti Bhawan Extn, 3rd floor, 14, Ashok Marg, Lucknow - 226 001 (Fax-0522-2288410)	11. Development Commissioner(Power), Civil Secretariat, JAMMU - 180 001 (Fax-0191-2545447, 2530265)
2. Director (Projects) NTPC, NTPC Bhawan, Core 7, Scope complex– 6, Institutional Area, Lodhi Road, New Delhi – 110003 (Fax-011-24361018)	7. Director (Transmission) Urja Bhawan, Kawali Road, Dehradun, Uttaranchal-248 001 (Fax-0135-2762460)	12. Member (Power) BBMB, Sectot-19 B Madhya Marg, Chandigarh-160019 (Fax-0172-2549857)
3. Director (Technical) NHPC Office Complex, Sector – 33, NHPC, Faridabad - 121 003 (Fax-0129-2277941)	8. Director (operations) Delhi Transco Ltd. Shakti Sadan, Kotla Marg, New Delhi - 110 002 (Fax-011-23234640)	13. Chief Engineer (Transmission) NPCIL, 9- S-30 Vikram Sarabhai Bhawan, Anushakti Nagar, Mumbai - 400 094 (Fax-022-25993570, 25563350)
4. Director (Projects) POWERGRID, Saudamini, Plot no. 2, Sector - 29, Gurgaon-122 001 (Fax-0124-2571932)	9. Director(Technical) Punjab State Transmission corporation Ltd. (PSTCL), Head Office, The Mall, Patiala - 147 001 (Fax-0175-2304017)	14. Chief Engineer (Operation) Ministry of Power, UT Secretariat, Sector-9 D Chandigarh - 161 009 (Fax-0172-2637880)
5. Sr. Vice President, PTC Ltd, 2nd floor, 15 NBCC Tower, Bhikaji Cama Place, New Delhi – 110066 (Fax-011-41659145)	10. Director (Projects) HVPNL Shakti Bhawan, Sector -6 Panchkula - 134 109 (Fax-0172-2560640)	15. Managing Director, HP Power Transmission Corporation Ltd. Himfed Bhawan, Panjari, old MLA Quarters, SHIMLA-171004 (Fax-0177-2626284, 26262283)