

Annex - Agenda - 16.1

**TAMILNADU TRANSMISSION CORPORATION LTD.**  
(Subsidiary of TNEB Ltd.)

From

T.Senthilvelan, B.E.,  
Director/Transmission Projects,  
TANTRANSCO,  
144, Anna Salai,  
Chennai -2.

To

The Member (Power System),  
Central Electricity Authority,  
Sewa Bhavan, R.K.Puram,  
New Delhi 110 066.

Observations  
40th SCSPSK

Lr.No.CE/Plg.&R.C/SE/SS/EE1/AEE1/F.39<sup>th</sup> StgComm Modification/D.85 dt.27.02.16

Dear Sir,

Sub: 39<sup>th</sup> Standing Committee Meeting on Power System Planning of Southern Region - MOM received - Observation & Modification requested - reg.

\*\*\*\*\*

1.0 The following points are to be included in the minutes of the 39<sup>th</sup> Standing Committee Meeting on Power System Planning of Southern Region.

**2.0 SEPC -1X525MW:**

2.1 In the 38<sup>th</sup> Standing Committee minutes of the meeting, for the evacuation of M/S.SEPC (IPP, 1X525MW), the study results were furnished by TANTRANSCO. In the meeting, SRPC pointed out that the bus voltages were not exhibited in the studies. Further, CEA pointed out that, there is overloading in the Kanarpatty - Tirunelveli 400kV SC line. After deliberation, the following was decided in the meeting.

- i. Prima-facie the transmission system that was earlier agreed for Udangudi Stage I and II, may be sufficient to evacuate power from Udangudi 2X660MW and SEPC 1X525MW.
- ii. TANGEDCO will furnish fresh studies.

C/o Member (Power System)  
Dy. No. 423  
Date: 9/3/16

Ms. Shivan, Dy. Secy  
13/3/2016

CE (PSP & PA - II)  
S

2.2. Based on the outcome of the meeting, the study results with voltage profile were already furnished to CEA. However, the approval was not included in the MoM. Hence, it is requested to include the approval for the ATS of the M/S.SEPC -1x525MW Thermal power project in the minutes.

### **3.0 Evacuation scheme for Uppur -2X800MW:**


3.1 A joint Load Flow Study was conducted with PGCIL/Gurgaon during 30-31<sup>st</sup> October 2015, to decide the evacuation of the Uppur Thermal Power project to be set up in Ramanathapuram district. In the meeting, it has been suggested that since Uppur Generators are proposed to be radially connected to Coimbatore 765kV SS through 350km long line, stability will be an issue for which a proper anchoring is required. As the generation is to be consumed within the state, evacuation through 400kV lines to the nearby substations/load centers could be a feasible alternative. Further study will be conducted to finalise the scheme.

3.2. The above discussion shall be included in the 39<sup>th</sup> MoM. Further, it is requested to give suitable dates for conducting load flow study for finalizing the evacuation scheme for the Uppur – 2X800MW project.

### **4.0 Start-up Power Requirement for ETPS SEZ – 2X600MW:**

4.1. The transmission scheme for the evacuation ETPS SEZ- 2X600MW project has already been approved in the 37<sup>th</sup> Standing committee meeting for which the start up power has been decided by making LILO of one of the existing NCTPS II – SVChatram 400kV DC line by forming a separate new 400kV start up bus. The above point shall also be included in the minutes.

It is requested that corrigendum to the minutes incorporating the above points may be issued.



(M.A. Helen)

(2/2)

Chief Engineer/Planning & R.C  
For Director/Transmission Projects

Annex - Agenda - 16.2

**TANTRANSCO**

(Subsidiary of TNEB Ltd.)

From

T.Senthilvelan, B.E.,  
Director/Transmission Projects,  
TANTRANSCO,  
144, Anna Salai,  
Chennai -2.

To

The Member (Power System),  
Central Electricity Authority,  
Sewa Bhavan, R.K.Puram,  
New Delhi 110 066.

Lr.No.CE/Plg&R.C/SE/SS/EE1/AEE1/F.CEA/D.281/2016 dt.28.07.16

Dear Sir,

Sub: TANGEDCO -Power evacuation scheme for the proposed 2X800MW power project of TANGEDCO at Uppur in Ramnad district and other schemes - Approval-Reg.

- Ref :
1. Lr.No.CE/Plg&RC/SE/SS/EE1/AEE1/F.Uppur ATS/D169/2016 dt.05.05.16.
  2. Lr.No.CE/Plg&RC/SE/SS/EE1/AEE1/F.Stgcommittee/D293/2015 dt.07.08.15.
  3. Lr.No.CE/Plg&RC/SE/SS/EE1/AEE1/F.39<sup>th</sup> Stgcomm Modification/D85/2016 dt.27.02.16.
  4. Lr.No.CE/Plg&RC/SE/SS/EE1/AEE1/F.Edayarpalayam/D 210dt.13.06.16.

\*\*\*\*\*

Transmission system for evacuation of power from Uppur TPS (2X800MW) of TANGEDCO in Tamil Nadu was studied in the joint study meeting of Southern Region held on Bangaluru during 14<sup>th</sup> to 17<sup>th</sup> March, 2016. The detailed study report on the above was furnished to CEA vide TANTRANSCO letter cited under reference (1) and requested to approve the above scheme in the forthcoming Standing Committee meeting on Power System planning on Southern Region.

The following proposals have been evolved in respect of evacuation of Power from Uppur 2x800MW Power project:

M. Shivam, Dy. Secy  
28/7/16

CE (PSPA-II)

903, C.E.PSPA-II

Off Member (Power System)  
Dy. No. 129  
28/7/16  
Date

**(i) Establishment of 765/400KV SS in Virudhunagar (For Uppur ATS and Renewable Generation pooling)**

**765kV Connectivity:**

- a. 765 kV DC connectivity to the Coimbatore 765/400kV SS with 240 MVar, 765 kV switchable line Reactors at each line at both ends.
- b. 765 kV DC connectivity to the Ariyalur 765/400 kV SS with 240 MVar, 765 kV switchable line reactors at each line at both ends. This work will be taken up with the proposal of Udangudi thermal power projects of Stage II & III.
- c. 2X1500MVA, 765/400 kV ICTs at the proposed Virudhunagar 765/400KV SS.

**400kV Connectivity:**

- a. 400 kV DC Quad line from Kayathar 400 kV SS
- b. 400 kV DC Quad line from Kamudhi 400 kV SS
- c. 400 kV DC Twin-Moose line from Thappagundu 400 kV SS

**(ii) Transmission system for evacuation of power from Uppur TPS – 2X800MW.**

For evacuation of Power from Uppur TPS – 2 X 800 MW, the following Associated Transmission System (ATS) has been evolved.

- a. 765kV DC Line from Uppur Switchyard to the proposed Virudhunagar 765/400KV SS
- b. 2X240 MVar, 765 kV Bus Reactors at the Uppur 765 kV Switchyard

The expected year of commissioning for the proposed 2x800MW Uppur power project is 2019-20 and LOA has been awarded for the same.

2. With regard to the start up power for four power projects of TANGEDCO and evacuation scheme for SEPC, the following was informed vide TANTRANSCO letters to CEA cited under references (2) and (3):

**(i) Start up power requirement for ETPS SEZ-2X600MW and Udangudi project**

The start up power requirement of ETPS SEZ-2X600MW and Udangudi project and others are finalised as follows

Sl.No	Name of the Project	Start up power voltage
1	ETPS Expansion -1x660MW	230kV level
2	ETPS SEZ-2X660MW	400kV level
3	NCTPS Stage III-1X800MW	230kV level
4	Udangudi stage-I -2X660MW	400kV level

The transmission scheme for the evacuation ETPS SEZ – 2 X 660 MW project has already been approved in the 37<sup>th</sup> Standing committee meeting for which the start up power has been decided by making LILO of one of the existing NCTPS II – SVChatram 400 KV DC line by forming a separate new 400 KV start up bus.

For the Udangudi stage I - 2X660MW project, the evacuation line planned i.e., Kayathar 400 KV DC line, may be used for the Start up power requirement also.

**(ii) Evacuation Scheme for SEPC – 1X525MW**

In the 38<sup>th</sup> Standing Committee minutes of the meeting, for the evacuation of power from M/s. SEPC (IPP, 1X525MW), the study results were furnished by TANTRANSCO. In the meeting, SRPC pointed out that the bus voltages were not exhibited in the studies. The study results with voltage profile was sent to CEA and once again requested to include the approval for the ATS of the M/s.SEPC -

1X525MW thermal power project in the minutes with the following evacuation scheme.

"400kV D/C line to the proposed Ottapidaram 400/230-110kV substation".

The expected date of requirement of start up Power for the proposed 1X525MW SEPC Thermal power project will be in April – May 2018.

3. Further, the following proposals may be considered in the forthcoming Standing Committee meeting on PSPS:

(i) **Revised connectivity for Edayarpalayam 400/230-110kV substation**

Since, the Edayarpalayam 400/230-110kV SS is used for load dispersal during nil wind season, CEA has been requested vide letter cited under reference(4) that the Edayarpalayam - Myvady 400kV DC quad line which was in the scope of PGCIL may be dropped and instead Edayarpalayam - Anikadavu 400kV DC quad line shall be taken up by TANTRANSCO.

(ii) **Ariyalur – Thiruvalem 765KV Line reactor**

As the line length of Thiruvalem-Ariyalur 765KV DC line is less than 170km, the line reactors at Ariyalur end may not be required for charging the Ariyalur – Thiruvalem 765KV DC line. Hence, erection of 2x240MVAR line reactor at Ariyalur end in Thiruvalem –Ariyalur 765kV DC line may not be required.

Hence, it is requested that the forthcoming 40<sup>th</sup> Standing Committee Meeting on Power System Planning for Southern Region may be convened at the earliest in order to get approval for the above mentioned schemes.

*to be included in 4/0*

*M.A.Helen*  
(M.A.Helen)

Chief Engineer/Planning & RC  
For Director/Transmission Projects

2/2



Annex-Agenda-17-1

From

Dr.M.Saikumar, I.A.S  
Principal secretary,  
Chairman / Tamil Nadu Transmission Corporation,  
144, Anna Salai,  
Chennai - 600002.

To

The Chairman cum Managing Director,  
Nuclear Power Corporation of India Limited,  
Vikram Sarabhai Bhavan, Anushakthinagar,  
Mumbai - 400 094.

Lr.No.CE/Plg.&R.C/SE/SS/EE1/AEE1/Kudankulam/D.321 /2016 dt.06-09-16

Sub: Kudankulam Units 3 & 4 (2X1000MW) - Additional Evacuation lines required by NPCIL - Regarding.

\*\*\*\*\*

The construction work of second phase of Kudankulam Nuclear power project (unit 3 & 4) is to be started. In this regard for the evacuation of power from Kudankulam Nuclear Power Project (KKNPP) - Units 3 & 4, the following Associated Transmission System (ATS) has been evolved in the 36<sup>th</sup> Standing Committee meeting on Power System Planning.

"400 kV Quad D/c line to Koilpatty (Tuticorin) Pooling station (PS) from Units 3 & 4 switchyard and suitable rearrangement at Kudankulam Units 1 & 2 Generation switchyard."

With the final rearrangement, there will be 3 numbers of 400kV lines (2 numbers to Tirunelveli (Abisekapatty) 400kV SS and 1 number to Koilpatty PS) will emanate from both of the plants i.e., KKNPP - 1&2 and KKNPP - 3 &4.

2.0 In this connection, in the 37<sup>th</sup> Standing Committee meeting, NPCIL has stated the following.

"NPCIL opined that under outage of two towers of each circuit of Kudankulam - Tirunelveli D/c line, only one line shall be available for evacuation of power from Units 1,2 & 3,4. Based on the above observations, NPCIL proposed to review the scheme and plan additional lines for safe evacuation of power from Kudankulam units."

CE/PSA-II-613  
15/9/16

C/O Member (Power System)  
15/9/16  
14/9/16

100578-II)

PS Shrivastava Dy. Secy  
1. 12/10/16


Further, in the meeting it was agreed that studies shall be carried out for requirement of additional evacuation lines for Kudankulam 3 & 4 and meanwhile, the earlier agreed scheme may be taken up for implementation.

3.0 In this context, the following are stated,

- i. The existing, under execution and planned substations of Tamil Nadu Transmission Corporation (TANTRANSCO) in the southern part of Tamil Nadu which are nearer to the Kudankulam Atomic Power Station are given below.
  - a. Kayathar (existing) 400/230-110kV SS
  - b. Kanarpatty (under construction) 400/230-110kV SS
  - c. Pavorchatram (Thennampatty) 400/230-110kV SS (under construction).
  - d. Ottapidaram (planned) 400/230-110kV SS
- ii. It is suggested that additional lines which are yet to be planned from Kudankulam units may be terminated in some of the above TANTRANSCO substations. It is assured that TANTRANSCO will construct the above evacuation lines along with bays at both ends and share of power for Tamilnadu from Kudankulam units will be drawn through the above lines.

It is requested to offer your concurrence on the above proposal.

Yours faithfully



CHAIRMAN / TANTRANSCO

Copy to

✓ The Member/Power System,  
Central Electricity Authority,  
Seva Bhawan, R.K Puram,  
New Delhi-110066.

The Chief Operating Officer(CTU),  
Power Grid Corporation of India Ltd.,  
Saudamini, Plot No. 2,  
Sector-29, Gurgaon-122001,  
Haryana.



Annex - Agenda/18.1

Central electricity Authority  
System Planning & Project Appraisal Division  
Sewa Bhawan, R.K Puram, New Delhi -110066

No: 51/4/SP&PA-2015/406-407

Date: 14<sup>th</sup> June, 2016

To

The Director / Projects & LI,  
TSTRANSCO,  
Vidyut Soudha,  
Hyderabad-500082

**Subject:** In principle approval of transmission evacuation scheme of Kaleshwaram Lift Irrigation Project (Dr. BR Ambedkar Pranihita – Chevella Sujala Sravanthi) & Palamuru – Rangareddy Lift Irrigation Schemes, proposed generation evacuation of 2x800MW Telangana.

**Reference:** TS Transco letter no. Dir (Proj)/ SE(PS)/ DE(SS)/ ADE-3/F. Schemes/ D.No. 329/16 dated 04.05.2016.

Sir,

1. TSTRANSCO, vide their letter dated 04.05.2016 has requested CEA to give in-principle approval for the transmission evacuation schemes of Kaleshwaram Lift Irrigation Project (Dr. BR Ambedkar Pranihita – Chevella Sujala Sravanthi) & Palamuru – Rangareddy Lift Irrigation Schemes and proposed generation evacuation of 2x800MW Telangana STPP to facilitate the construction of transmission lines and substations. Further, TSTRANSCO vide their email dated 24.05.2016 and 08.06.2016 proposed following transmission schemes:

2. **Kaleshwaram Lift Irrigation Project (DR.B.R. Ambedkar Pranahitha Chevella Lift Irrigation Project):**

2.1 The above scheme was discussed and agreed in 37th meeting of SCPSPSR held on 31-07-2014. However, Telangana vide their email dated 24.05.2016 has now revised the above scheme and have sought for in-principle approval for the same. TSTRANSCO has also revised the total LI load and capacity of synchronous motors at various LI Substations on 08.06.2016. Following load/motor capacity have been furnished by TSTRANSCO:

SI	Name of LI substation	Capacity, MW	Simultaneous load, MW
1	Ramadugu	7x139=973	834
2	Medaram	7x124.4=871	746
3	Tippapur	4x106=424	318
4	Chandlapur	5x88.5=443	354
5	Tukkapur	8x43=344	258
6	400kV Yellampalli		

SI	Name of LI substation	Capacity, MW	Simultaneous load, MW
8	Sundila	8x40=320	240
9	Yellampalli	9x40=360	280
10	Malakpet(132kV)	2x30=60	60
	<b>Total</b>	<b>4235</b>	<b>3450</b>

2.2 The difference of earlier approved scheme and the proposed scheme are as given below:

Sl. No.	Substations and Lines as approved in the 37 <sup>th</sup> Standing Committee		Revised Proposal of TSTRANSCO
1	Erection of 400 KV SS at Ramadugu, Karimnagar Dist Pkg-8 (Load 670 MW)	1	Erection of 400 KV SS at Ramadugu, Karimnagar Dist Pkg-8
2	Erection of 400 KV SS at Choppadandi, Karimnagar Dist Pkg-7 (Load 123 MW) with 2x315 MVA ICTs		-
3	Erection of 400 KV SS at Myadarm, Karimnagar Dist Pkg-6 (Load 750 MW)	2	Erection of 400 KV SS at Medaram, Karimnagar Dist Pkg-6
4	Erection of 400 KV SS at Tippapur, Karimnagar Dist Pkg-10 (Load 336 MW)		Erection of 400 KV SS at Tippapur, Karimnagar Dist Pkg-10.
5	Erection of 132 KV SS at Malakpet, Karimnagar Dist Pkg-9 (Load 30 MW)		-
		3	Erection of 400 KV SS at Tukkapur, Medak Dist Pkg-12
		4	Erection of 400 KV SS at Chandlapur, Medak Dist Pkg-11
		5	Erection of 400/220 KV SS at Yellampalli, Karimnagar Dist
		6	Erection of 220 KV SS at Yellampalli Pump House, Karimnagar Dist
		7	Erection of 220 KV SS at Sundilla Pump House, Karimnagar Dist
		8	Erection of 220 KV SS at Kaleshwaram Pump House, Karimnagar Dist
		9	Erection of 132 KV SS at Malakpet, Karimnagar Dist Pkg-9
	Erection of 400 KV Quad Moose DC line for making LILO of both the circuits of 400 KV	10	Erection of LILO

		20	Erection of 220 KV Twin Moose DC line from 400/220 KV Yellampalli LI SS to 220/11 KV Kaleshwaram pump house - 60 KM
			Erection of 132 KV DC line from upcoming 220 KV Sircilla SS to the proposed 132 KV Malakpet SS - 15 KM

### 3. **Palamur Ranga Reddy Lift Irrigation Scheme (3635 MW):**

The transmission system for this scheme was discussed in 39<sup>th</sup> meeting of SCPSR held on 28<sup>th</sup> and 29<sup>th</sup> December, 2015. In the meeting TSTRANSCO informed that the locations of the proposed new LI SS, has been changed. So, it was decided that TSTRANSCO will furnish new proposal and the issue will be re-discussed in the next SCPSR. TSTRANSCO has now revised capacity of LI Substations and the associated transmission system, which are given below:

#### 3.1 Following load/motor capacity have been furnished by TSTRANSCO:

SI	Name of LI substation	Capacity, MW	Simultaneous load, MW
1	400 KV Narlapur	8x110=880	660
2	400 KV Yedula	9x120=1080	840
3	400 KV Vattam/ Karvena	9x107=963	749
4	400 KV Uddandapur	5x110=550	440
5	220 KV KP Laxmidevipally	3x54=162	108
	<b>Total</b>	<b>3635</b>	<b>2797</b>

#### 3.2 **Associated transmission system**

- i) 400 KV Quad Moose DC line from Veltor to proposed 400 KV Yedula LISS -50 KM.
- ii) 400 KV Quad Moose DC line from proposed 400 KV Yedula LISS to proposed 400 KV Narlapur LISS -30 KM.
- iii) 400 KV Quad Moose DC line from proposed 400 KV Yedula LISS to proposed 400 KV Vattam /Karvena LISS -60 KM.
- iv) 400 KV Quad Moose DC line from Maheshwaram TStranSCO SS to proposed 400 KV Yedula LISS -130 KM.
- v) LILO of both circuits of 400 KV Suryapet - Manikonda (Kethireddypalli) Quad Moose DC line to proposed 400 KV Uddandapur LISS - 50 KM.

7	Erection of 90 KM 400 KV Twin Moose DC line from 400 KV Dichpally SS to the proposed 400 KV Ramadugu SS.		-
8	Erection of 25 KM 400 KV Quad Moose DC line from 400 KV Ramadugu SS to 400 KV to 400 KV Myadaram SS	11	Erection of 400 KV Quad Moose DC line from 400 KV Ramadugu LI SS to 400 KV Medaram LI SS - 21 KM.
9	Erection of 25 KM 400 KV Quad Moose DC line from 400 KV Ramadugu SS to 400 KV Choppadandi SS		-
10	Erection of 40 KM 400 KV Twin Moose DC line from 400 KV Choppadandi SS to 400 KV Tippapur SS		
11	Erection of 400 KV Twin Moose DC line for making LILO of both the circuits of 400 KV KTPP-Gajwel Twin Moose DC line at the proposed 400 KV Tippapur SS (total 80 KM for two LILO DC lines)		-
12	Erection of 60 KM 400 KV Twin Moose DC line from 400 KV Dichpally SS to the upcoming 400 KV Nirmal SS		-
13	Erection of 30 KM 132 KV DC line from 220 KV Jagityal SS to the proposed 132 KV Malakpet SS.		-
		12	Erection of 400 KV Quad Moose DC line from 400 KV Ramadugu LI SS to 400 KV Tippapur LI SS - 20 KM.
		13	Erection of 400 KV Quad Moose DC line from 400 KV Tippapur LI SS to 400 KV Chandlapur LI SS - 21 KM
		14	Erection of LILO of both circuits of 400 KV Twin Moose DC line from KTPP - Gajwel at Chandlapur LI SS - 41 KM(LILO length)
		15	400 KV Twin Moose DC line from 400 KV Chandlapur LI SS to 400 KV Tukkapur LI SS - 30 KM
		16	400 KV Twin Moose DC line from 400 KV Tukkapur LI SS to 400 KV Narasapur SS - 70 KM
		17	Erection of LILO of both circuits of 400 KV Quad Moose DC line from SCCL Jaipur - Ramadugu at proposed Yellampalli SS - 8 KM (LILO length)
		18	Erection of LILO of both circuits of 400 KV Quad Moose DC line from Telangana STPP- Neddurunu SS at Yellampalli SS - 10 KM (LILO length)
		19	Erection of 220 KV DC line from 400/220 KV Yellampalli SS to 220/11 KV Sundilla pump house - 30 KM

- vi) 400 KV Quad Moose DC line from proposed 400 KV Vatterm LISS to proposed 400 KV Uddandapur LISS -50 KM.
- vii) 220 KV Twin Moose DC line from 220kV Pargi SS to KP Laxmidevipally LISS – 20 KM.

**4. Proposed Telangana STPP 2X800 MW Generation Evacuation Scheme (To be established by NTPC) at Ramagundam**

**4.1 New Substations:**

- A. New 400 kV SS – Nedunuru SS in Karimnagar District  
B. New 400 kV SS – RCPuram SS in Rangareddy District  
C. New 220 kV SS – Borampet SS in Rangareddy District

**4.2** The above scheme was discussed in 39<sup>th</sup> meeting of SCPSPSR held on 28<sup>th</sup> and 29<sup>th</sup> December, 2015. The following revised proposal has been sent by TSTRANSCO:

Associated transmission system

- i) 400 kV Quad Moose DC line from proposed Telangana STPP 2X800 MW to proposed 400/220/132 kV Nedunuru SS - 60 KM.
- ii) LILO of both circuits of 400kV Jangoan – 400 kV Tippapur LI SS Quad Moose DC line to proposed 400 kV Nedunuru SS – 30 KM.
- iii) 400 kV Quad Moose DC line from proposed Telangana STPP 2X800 MW to upcoming 400 kV Narsapur SS (Substation approved in 35<sup>th</sup> Standing Committee Meeting) - 170 KM.
- iv) 400 kV Quad Moose DC line from upcoming 400 kV Narsapur SS to proposed 400 kV RCPuram SS in Rangareddy District – 60 KM.
- v) LILO of 220 kV Durshed – Siddipet DC line to the proposed 400/220/132 kV Nedunuru SS – 10 KM.
- vi) 220 kV UG Cable from proposed 400 kV RCPuram to existing 220 kV Gachibowli SS – 10 KM.
- vii) 220 kV UG Cable from proposed 400 kV RCPuram to upcoming 220 kV Raidurg SS – 20 KM.
- viii) 220 kV Single Moose DC line from upcoming 400 kV Narsapur to proposed 220 kV Borampet SS – 43 KM.
- ix) 220 kV Single Moose DC line from proposed 220 kV Borampet SS to existing 220 KV Miyapur SS– 35 KM
- x) 220 kV Single Moose DC line from proposed 220 kV Borampet SS to existing 220 KV Shapurnagar SS– 35 KM

**5.** Earlier, Joint Studies were carried out with SR constituents and PGCIL in Bangalore on 14-17 March, 2016. Further, the studies were carried out in CEA on 13<sup>th</sup> and 14<sup>th</sup> June, 2016 for evolving the transmission system for above LI schemes of Telangana and the Telangana STPP

For these studies, the total peak load of Telangana was assumed as 12000 MW by 2019-20 additional LI load of 6000 MW. The studies were carried out for three load generation scenarios:


1. 12000 Telangana Load and 6000 LI load.
2. 11000 Telangana Load and 6000 LI load
3. 11000 Telangana Load and 0 LI load.

The load-generation balance scenarios are given at **Annex- I**. The list of generation to serve above load are provided by TSTRANSCO and is given at **Annex II**. The result of studies for the systems (i.e at S.No 2,3 and 4) are depicted at **Annex -III (a,b,c)**.

6. TSTRANSCO has also submitted vide their email dated 08.06.2016 (**Annexure-IV**) that the motor capacity and simultaneous loads at LI substations are tentative only and may change.
7. Considering above we convey our in-principle approval for above transmission schemes. However, these schemes would be finalized in the next meeting of SCPSPSR. Further following is also mentioned:
  - 1- There is requirement of more outlets from SCCL Generation Project.
  - 2- Provision of reactors to prevent high voltages in non-operational season. This requirement would be worked out by TSTRANSCO and submitted to CEA for taking up in next meeting of SCPSPSR.
  - 3- As informed by TSTRANSCO, these machines would be synchronous motors with capability to run at least at 0.95 power factor Lag/Lead.
  - 4- It is observed that Telangana will have to procure additional generation capacity of the order of 4000-5000 MW for the period 2019-20 to meet their load demand as considered in these studies i.e 18000 MW(including 6000 MW for Lift Irrigation)

This issues with the approval of Member (Power System), CEA.

Yours faithfully,

  
12/6/2016

(Pardeep Jindal)

Chief Engineer (PSPA-2)

**Copy to:**

COO(CTU-Plg.),

Power Grid Corp. of India Ltd.,

“Saudamini”, Plot No.-2, Sector -29,

Chennai - 600015

## LGB for Telangana State

	Thermal	Hydro	Total
SS	8763	-2442	11205
CGS	4226	0	4226
IPP	3950	0	3950
Grand Total			19381

## Scenario-1 (12000MW load+ LI 6000 MW)

Multification factor for Thermal (MFT)	Multification factor for Hydro(MFH)		Thermal	Hydro
0.785	0.6	SS	6878.955	1465.2
		CGS	3317.41	0
		IPP	3100.75	0
		Total	13297.115	1465.2
		Generation	14762.315	
		Demand	18000	
		Surplus/Deficit	-3237.685	

## Scenario-2 (11000MW load+ LI 6000 MW)

MFT	MFH		Thermal	Hydro
0.785	0	SS	6878.955	0
		CGS	3317.41	0
		IPP	3100.75	0
		Total	13297.115	0
		Generation	13297.115	
		Demand	17000	
		Surplus/Deficit	-3702.885	

## Scenario-3 (11000 MW load+Nil LI)

MFT	MFH		Thermal	Hydro
0.537	0.3	SS	4705.731	732.6
		CGS	2269.362	0
		IPP	2121.15	0
		Total	9096.243	732.6
		Generation	9828.843	
		Demand	11000	
		Surplus/Deficit	-1171.157	

SS- State Sector

CGS- Share from Central Generating Stations


IPP- Independent Power Producers including Chatishgarh LTA and others

ESTIMATED LOAD GENERATION BALANCE (LGB) Annex-II


Name of The Plant	Installed Capacity in MW	Installed Capacity in MW
Nagarjuna Sagar HES		815.6
Srisailem Left Bank HES		900
Priya darshini Jurala HES		234
Pochampadu PH		36
Nagarjuna Sagar Left Canal PH		60
Nizam sagar PH		10
Singur PH		15
Peddapalli Mini Hydro		9.16
Palair Mini Hydro		2
Pulichintala HES		120
Lower Jurala HES		240
<b>@ Total Hydel</b>		<b>2442</b>
Kothagudem - A,B&C		720
Kothagudem Stage - V		500
Kothagudem Stage-VI		500
Ramagundam TPS - B		62.5
Kakatiya TPP Stage - I		500
Kakatiya TPP Stage - II		600
Kothagudem TPS Stage-VII		800
Bhadradi TPS		1080
Yadadi TPS		4000
<b>Total Thermal</b>		<b>8763</b>
<b>Total Generation</b>		<b>11204</b>
RST I & II	2100	366
RSTIII	500	92
TALCHER STPS II	2000	216
SIMHADRI STAGE I	1000	539
SIMHADRI STAGE II	1000	260
VALLUR TPS	1500	114
MAPS	440	24
KAIGA STAGE 1	440	76
KAIGA STAGE II	440	76
NLC STG II	630	66
NLC STGT	840	114
TUTICORN-CGS	2x500	138
BHAVANI (KALPAKA)	1X500	71
NEYVELI UNIT - I	1X500	36
NEYVELI UNIT - II	1X500	36
KUDIGI UNIT- I	1X800	75
KUDIGI UNIT- II	1X800	75
KUDIGI UNIT- III	1X800	84
KUDIGI UNIT- IV & V	2X800	168
Telangana STPP	2x800	1600
<b>TOTAL CGS</b>		<b>4226</b>
CHATTISGARH-LTOA	2000	2000
SINGARENI UNIT - I & II	2x600	1200
SINGARENI UNIT - III	1x600	600
NAV BHARAT	1X150	150
<b>OTHERS</b>		<b>3950</b>
<b>GRAND TOTAL</b>		<b>19380</b>



TSTRANSCO - Telangana STPP Evacuation and Kaleshwaram Lift Irrigation Schemes Scenario



TSTRANSOO - Telangana STPP Evacuation and Kaleshwaram Lift Irrigation Schemes Scenario II







Shivani Sharma &lt;shivani0004@gmail.com&gt;

**Telangana Lift Irrigation schemes particulars - Reg.**

se\_ps\_transco &lt;se\_ps\_transco@telangana.gov.in&gt;

Wed, Jun 8, 2016 at 3:48 PM

To: Shivani Sharma <shivani0004@gmail.com>; "pjindal@cea.nic.in" <pjindal@cea.nic.in>;  
"jindal\_pardeep@yahoo.co.in" <jindal\_pardeep@yahoo.co.in>

Sir,

The Lift Irrigation scheme wise capacities and simultaneous loads are herewith attached.  
Some of the Substations names are renamed and are mentioned in brackets.

Regards,  
Superintending Engineer,  
Power Systems,  
TSTransco,  
Vidyut Soudha,  
Hyderabad.

**From:** Shivani Sharma <shivani0004@gmail.com>**Sent:** Tuesday, June 7, 2016 5:19 PM**To:** se\_ps\_transco**Subject:** Re: Telangana Lift Irrigation schemes particulars - Reg.

[Quoted text hidden]

 **CEA pdf**  
522K

TRANSMISSION CORPORATION OF TELANGANA LIMITED

From  
The Director/Projects & LI,  
TSTRANSCO,  
Vidyut Soudha,  
Hyderabad.

To  
The Chief Engineer/PS P&A -II,  
Central Electricity Authority(CEA),  
RK Puram, Sewa Bhavan,  
New Delhi-110066

Lr.No. Dir(Proj)/SE(PS)/DE(SS)/ADE-3/F.Schemes/D.No. 329 /16, Dt:04/05/2016

Sir,

Sub: - TSTransco - Revised Study for the Kaleshwaram Lift Irrigation Project (Dr. BR Ambedkar Pranihita - Chevella Sujala Sravanthi) & Palamuru-Rangareddy Lift Irrigation Schemes, Proposed 400 kV Tandur SS and others- Load flow studies - Requested - Reg.

- Ref:-
- 1) Minutes of the 37<sup>th</sup> Standing Committee Meeting dtd:31-07-2014.
  - 2) Lr.No. SE (PS)/DE(SS&LTSS)/ADE3/F.REVISED LI/D.No. 220/15, Dt:30/11/2015
  - 3) Lr.No. SE (PS)/DE(SS&LTSS)/ADE3/F.REVISED LI/D.No. 253/15, Dt:01/02/2016
  - 4) Lr.No. Dir(Proj)/SE(PS)/DE(SS)/ADE3/F.39th SCPSPSR Minutes/ D.No.278/15,Dt.27-02-2016
  - 5) Lr.No. Dir(Proj)/ADE-T/F.TSTPP REVISED/d.No.197/16, Dt:27-04-2016

\*\*\*\*\*

1) We are thankful for arranging the joint studies at your esteemed office as per telephonic discussion on dtd.30-04-2016 regarding the study for the revised proposal for Kaleshwaram Lift Irrigation Project (Dr. BR Ambedkar Pranihita - Chevella Sujala Sravanthi, Lift Irrigation Scheme) and Palamuru-Rangareddy Lift Irrigation Scheme on dtd: 05-05-2016 and 06-05-2016.

2) In this regard, it is to submit that, earlier Kaleshwaram Lift Irrigation Project (Dr. BR Ambedkar Pranihita - Chevella Sujala Sravanthi Lift Irrigation Scheme (1992 MW)) was approved in the Minutes of the 37<sup>th</sup> Standing Committee Meeting dtd:31-07-2014. Now the scheme is revised and Chief Minister has laid the foundation stone on 02-05-2016 at Kaleshwaram, Karimnagar District.The details and the block diagram of the scheme are enclosed as Annexure.

3) The details of Palamuru-Rangareddy the other Lift Irrigation Scheme (3630 MW) is also proposed and communicated vide reference (1) & (2). Copy enclosed for ready reference.

:: 2 ::

4) It is to submit that, the studies for Proposed Generation Evacuation of 2 x 800 MW Telangana STPP, to be established by M/s NTPC at Ramagundam, are carried out along with POWERGRID at Bengaluru during 14-17 March 2016 and the same was accepted .

5) Further, it is proposed for a new 400 kV SS at Tandur, Rangareddy District under system strengthening scheme to meet the industrial load coming up in that area. The detailed connectivity is enclosed herewith.

6) In view of the above, it is requested to arrange for the study of revised Kaleshwaram Lift Irrigation Project (Dr. BR Ambedkar Pranihita - Chevella Sujala Sravanthi) & Palamuru-Rangareddy Lift Irrigation Schemes, Proposed Generation Evacuation of 2 x 800 MW Telangana STPP to be established by NTPC and proposed 400 kV Tandur SS and communicate the approval/in principle approval at the earliest for taking up the works.

Encl: As above

  
4/5/16  
Director/Projects & LI

Copy to

Mrs.Seema Gupta, COO/CTU,CORPORATE CENTRE, Power Grid Corporation of India (PGCIL), Sector - 29, Near IFFCO Chowk, Gurgaon, Haryana - 122001.

## ANNEXURE

### I) DR.B.R.AMBEDKAR PRANAHITHA CHEVELLA LIFT IRRIGATION PROJECT

New 400 KV Substations :

1. *400 KV Medaram 7x160 MVA	1120 -	With a load of 730 MW	875
2. *400 KV Ramadugu 7x160 MVA	1120 -	With a load of 850 MW	977
3. *400 KV Tippapur 4x120 MVA	400 -	With a load of 380 MW	434
4. 400 KV Chandlapur 5x100 MVA	500 -	With a load of 400 MW	446
5. 400 KV Tukkapur 4x50 MVA	200 -	With a load of 350 MW	304
6. *132 KV Malakpet LI SS	-	With a load of 50 MW	

New 400 KV Lines :

1. \*400 KV Quad Moose DC line from 400 KV Ramadugu LI SS to 400 KV Medaram LI SS - 21 KM
2. \*LILO of 400 KV Quad Moose DC line from SCCL Jaipur - Gajwel to Ramadugu SS - 18 KM
3. 400 KV Quad Moose DC line from 400 KV Ramadugu LI SS to 400 KV Tippapur LI SS - 20 KM
4. 400 KV Quad Moose DC line from 400 KV Tippapur LI SS to 400 KV Chandlapur LI SS - 21 KM
5. LILO of 400 KV twin Moose DC line from KTPP - Gajwel to 400 KV Chandlapur LI SS - 2x41 KM
6. 400 KV Quad Moose DC line from 400 KV Chandlapur LI SS to 400 KV Tukkapur LI SS - 30 KM.
7. 400 KV Quad Moose DC line from 400 KV Tukkapur LI SS to 400 KV Narasapur SS - 70 KM
8. 132 KV DC Line from upcoming 220/132 KV Sircilla SS to 132 KV Malakpet LI SS - 15 KM

\* Are approved under 37<sup>th</sup> Standing Committee Meeting on Power System of Southern Region. However there is change in Load.

## ANNEXURE

### II) PALAMUR RANGA REDDY LI SHCEME (3630 MW)

New 400 KV Substations :

1. 400 KV Narlapur in Mahabubnagar District	-	880 MW
2. 400 KV Yedula in Mahabubnagar District	-	1080 MW
3. 400 KV Vatttem in Mahabubnagar District	-	960 MW
4. 400 KV Uddandapur in Mahabubnagar District	-	550 MW
5. 220 KV KP Laxmidevipally in Ranga Reddy District	-	160 MW

New 400 KV Lines :

1. 400 KV Quad Moose DC line from Veltoor to proposed 400 KV Yedula LISS -50 KM.
2. 400 KV Quad Moose DC line from proposed 400 KV Yedula LISS to proposed 400 KV Narlapur LISS -30 KM.
3. 400 KV Quad Moose DC line from proposed 400 KV Yedula LISS to proposed 400 KV Vatttem LISS -60 KM.
4. 400 KV Quad Moose DC line from Maheshwaram TSTransco SS to proposed 400 KV Yedula LISS -130 KM.
5. LILO of both circuits of Suryapet - Shankarpally 400 KV Quad Moose DC line to proposed 400 KV Vatttem LISS - 70 KM.
6. 400 KV Quad Moose DC line from proposed 400 KV Vatttem LISS to proposed 400 KV Uddandapur LISS -50 KM.
7. 220 KV Twin Moose DC line from Pargi to KP Laxmidevipally LISS - 20 KM.



## ANNEXURE

### **III) PROPOSED TELANGANA STPP 2X800 MW GENERATION EVACUATION SCHEME (TO BE ESTABLISHED BY NTPC) AT RAMAGUNDAM**

New 400 KV SS - Nedunuru SS in Karimnagar District  
New 400 KV SS - RCPuram SS in Rangareddy District  
New 220 KV SS - Bowrampet SS in Rangareddy District

1. 400 KV Quad Moose DC line from proposed Telangana STPP 2X800 MW to proposed 400/220/132 KV Nedunuru SS - 60 KM.
2. LILO of both circuits of Jangoan - Tippapur 400 KV Quad Moose DC line to proposed 400 KV Nedunuru SS - 30 KM.
3. 400 KV Quad Moose DC line from proposed Telangana STPP 2X800 MW to upcoming 400 KV Narsapur SS( Substation approved in 35<sup>th</sup> Standing Committee Meeting ) - 170 KM.
4. 400 KV Quad Moose DC line from upcoming 400 kV Narsapur SS to proposed 400 kV RCPuram SS in Rangareddy District - 60 KM.
5. LILO of 220 KV Durshed - Siddipet DC line to the proposed 400/220/132 KV Nedunuru SS - 10 KM.
6. 220 KV UG Cable from proposed 400 kV RCPuram to existing 220 kV Gachibowli SS - 10 KM
7. 220 KV UG Cable from proposed 400 kV RCPuram to upcoming 220 kV Raidurg SS - 20 KM
8. 220 KV Moose DC line from upcoming 400 kV Narsapur to proposed 220 kV Borampet SS - 43 KM
9. 220 KV Moose DC line from proposed 220 kV Borampet SS to existing 220 KV Miyapur SS- 35 KM
10. 220 KV Moose DC line from proposed 220 kV Borampet SS to existing 220 KV Shapurnagar SS- 35 KM


ANNEXURE

IV) PROPOSED 400 KV TANDUR SS IN RANGAREDDY DISTRICT

NEW 400 KV SS - TANDUR SS IN RANGAREDDY District

1. LILO of one circuit of 400 kV QMDC line from <sup>Shankar patil</sup> Mailaram - Manikonda (Kethireddypalli) SS to proposed 400 KV Tandur SS - 70 KM.
2. 220 KV Moose DC line from proposed 400 kV Tandur SS to existing 220 KV Tandur SS- 10 KM
3. 220 KV Moose DC line from proposed 400 kV Tandur SS to upcoming 220 KV Parigi SS- 45 KM

Shankar patil - Suryapeta  
↓  
Main Ronda



**ANNEXURE**

S.No	Name of the Substation	Power Transformer Capacity in MVA	MD reached during 2015-16 in MW
1	220KV Tandur SS	3x100	170
2	220KV Parigi SS (upcoming)	2x100	Idle
3	220KV Kosgi SS (upcoming)		
4	132KV Tandur SS	3x50	115
5	132KV CCI line-I & II		31
6	132KV Penna line		16
7	132KV VCIL line		35
8	132KV Tandur Railway line		9
9	132KV Parigi SS	3x50	52.8
10	132KV Vikarabad SS	1x10/16	Idle
11	132KV Vikarabad Railway SS	1x10/16	24
12	132KV Dharmasagar SS	3x31.5	42
13	Expected load on 220KV Tandur SS after charging the 220KV Parigi SS and 220KV Kosgi SS		150

**Line Lengths in KM:**


- 400KV Shankarpally SS to Proposed 400KV Tandur SS - 75 Km
- 400KV Tandur SS to Proposed 400KV Kethireddypalli (Manikonda) SS - 70 Km
- Proposed 400KV Kethireddypalli (Manikonda) SS to Upcoming 400KV Suryapet SS - 200 Km

**220KV Connectivities**

*[Signature]*  
 Superintending Engineer,  
 400KV/Constn/Metro/Erg/Hyd

SE-400KV CTTI HYD  
 POWER SYSTEMS  
 TRANSMISSION  
 Inward No. *SLE 8*  
 - 4 MAY 2016  
 DE/System Studies  
 DE/System Protection  
*[Signature]*  
 SE/Power Systems

Schematic Diagram showing the details of all existing feeder arrangement for the proposed LIL0 of 400KV QMDC line Suryapet to Shankarpally to the proposed 400KV SS TANDUR



*400KV*  
*70km*  
*QMDC Line*


Proposed  
Existing

*Asst. Executive Engineer*  
400KV/SD- /Constn-ITSTRANSCC  
Metro/Erragadda/Hyderabad-45.

*Executive Engineer*  
400KV/Constn-ITSTRANSCC  
Metro/Erragadda/Hyderabad-45.

*Superintending Engineer*  
10MVAR/CONSTN 10MVAR/CONSTN  
HYDERABAD-50M VAR

**KALIESHWARAM (Pranahitha - Chevella) LIFT IRRIGATION SCHEME FOR PACKAGE Nos. 6,8,10,11 AND 12**



- 1 Rating of Motor : 124.40 MW
- 2 No. of Pumps : 7 Nos X 103.64 MW
- 3 Total input Power required : =730 MW
- 4 No. of PTIRs. : 7 X 160 MVA


**QMDC**

Sl.No	Name of the line	Length in km
1	400 kV QMDC L.L.O line to Ramaddugu from Jaipur to Gajwel 400KV QMDC line (18+18 km)	36
2	400 kV QMDC line from Ramaddugu to Medararam	21
3	400 kV QMDC line from Ramaddugu to Tippapur	20
4	400 kV QMDC line from Tippapur to Chandlapur	21
<b>TOTAL LENGTH OF QMDC LINE</b>		<b>98</b>

**TMDC**

Sl.No	Name of the line	Length in km
1	400 kV TMDC L.L.O. line to Chandlapur from KTRP - Gajwel TMDC Line (41+41 km)	82
2	400 kV TMDC line from Chandlapur to Tukkapur	30
3	400 kV TMDC line from Tukkapur to Narsapur	70
<b>TOTAL LENGTH OF TMDC LINE</b>		<b>182</b>

# PALANQOR-RANGAREDDY LIFT IRRIGATION SCHEME



QMDC LIFO FROM SURYAPET TO SHANKARPALLY LINE

70KM


*Manikonda*

*Suryapet = 20 km*

220KV LINE FROM PARI

*[Signature]*

# NTPC, RAMAGUNDAM



\* Quad Moose lines proposed in view of future expansion of generation





Annex-Agenda-18.3  
Shivani Sharma <shivani0004@gmail.com>

---

## NTPC, Kaleshwaram and Palamur Rangreddy LI Scheme - SAV Files with 6000 MW LI Load

---

se\_ps\_transco <se\_ps\_transco@telangana.gov.in>

Tue, May 24, 2016 at 12:16 PM

To: "jindal\_pardeep@yahoo.co.in" <jindal\_pardeep@yahoo.co.in>, "shivani0004@gmail.com" <shivani0004@gmail.com>

Cc: "desststransco@gmail.com" <desststransco@gmail.com>

Sir/Madam

As per the telephonic discussions had with our Director(Projects&LI), the draft study results along with SAV files(3 Nos.), Single Line diagram and connectivity details are herewith attached for further advice.

It is requested to arrange to communicate in principle approval for the attached schemes at the earliest.

With regards  
Superintending Engineer  
Power Systems

---

 Delhi 230516.rar  
3275K



**Minutes of the meeting to discuss re-routing of existing 400 kV line emanating from Ramagundam STPP in view of Telangana STPP 2x800 MW in the Ramagundam generation complex**

1. A meeting was held on 3<sup>rd</sup> November, 2016 in the office of Chief Engineer (PSPA-II) CEA, to discuss re-routing of existing 400 kV lines emanating from Ramagundam STPP in view of Telangana STPP (2x800 MW), in the Ramagundam generation complex. The meeting was participated by officials from CEA, NTPC, CTU and POWERGRID field office. The list of participants is enclosed at Annex-I.
2. POWERGRID informed that there are four numbers of 400 kV circuits emanating from Ramagundam switchyard towards Hyderabad, two number of circuits towards Chandrapur ,one circuit towards Warangal, two circuits towards Nagarjuna Sagar and one circuit towards Dichpalli. Out of the 4 circuits towards Hyderabad, two circuits i.e. circuit no. 3 and 4 are on double circuit towers and are directly going to Ghanapur (Hyderabad). The circuit number 1 and 2 from Ramagundam to Hyderabad are on single circuit tower and circuit number 1 is LILoed at Gajwel and circuit number 2 is LILoed at Malkaranam.
3. NTPC informed that Telangana Stage I (2x 800 MW) is being set up in the available land inside existing Merry-Go-Round unloading Bulb area near existing Ramagundam Super Thermal Power Project (RSTPP) in District Karimnagar of Telangana. Existing 400kV DC lines of PGCIL namely Hyderabad 3 &4 and Chandrapur 1& 2 are crossing the proposed site identified for Telangana Stage I BOP facilities like railway siding and coal stock pile area.
4. NTPC informed that in view of above re-routing of existing 400 kV Chandrapur-1&2, Warangal and Hyderabad 3&4 lines is required to start enabling work in this area. Considering the limited available corridor and the large number of transmission lines to be routed in close vicinity, available corridor of approx. 200 m inside the plant boundary has been identified for re-routing of above lines and proposed evacuation system Telangana STPP Stage I as well. To accommodate all these lines in available 200 m corridor, Multi-circuit tower has been proposed to be used.
5. They also informed that for this purpose, the Ramagundam-Hyderabad circuit number 3 and 4 and Chandrapur circuit number 1 and 2 will be built in one corridor for about one and a half kilometer length using eight number of multi-circuit towers. Similarly, on the other side of the railway siding, the outgoing circuit of Ramagundam-Chandrapur 1 and 2 and Warangal will be built using another set of ten numbers of multi-circuit tower for the length of about 3 kilometers. Thus, there will be a total requirement of 18 numbers of multi-circuit towers.
6. NTPC stated that they will be paying for all expenses related to re-routing of these lines with use of multi-circuit towers. The same was agreed by POWERGRID. They both informed that they are carrying out a MoU on mutually agreed terms for implementing the same.

7. NTPC also requested CEA and CTU to consider and recommend for providing necessary shut down for implementing this re-routing arrangement. It was discussed that as carrying out this work is essential in nature, in view of establishment of 1600 MW Telangana STPP project and its evacuation system. Therefore, this shutdown may be allowed by SRLDC/POSOCO considering system conditions. For this, NTPC and POWERGRID would coordinate with SRLDC and SRPC. On query from CEA, POWERGRID officials also informed that this shut down may be needed for a period of about 4 days.
  
8. Accordingly, in the meeting, it was in-principally decided to allow NTPC and PGCIL to carry out the above re-routing arrangements. However, as the matter pertains to ISTS networks it was felt that the same should also be discussed and formalized in the forthcoming meeting of the SCPSPSR scheduled to be held on 19<sup>th</sup> November, 2016. The schematic diagram of Ramagundam switchyard/relevant part of Ramagundam generation complex are enclosed at Annex (a), (b) and (c).

TRANSMISSION CORPORATION OF TELANGANA LIMITED

*Annex Agenda - 19.1*

From  
The Director/Projects and Grid Operation,  
TSTRANSCO,  
Vidyut Soudha,  
Hyderabad.

To  
The Member/Power Systems,  
Central Electricity Authority(CEA),  
RK Puram, Sewa Bhavan,  
New Delhi-110066

Lr.No.Dir(Proj)/CE(SLDC)/SE(PS)/DE(SS)/ADE(SS)/F.Reactor LI/D.No. 228/16, Dt: 03/09/2016  
Sir,

Sub: - TSTransco - In principle approval of transmission evacuation scheme of Kaleshwaram Lift Irrigation Project (Dr.BR Ambedkar Pranihita Chevella - Sujala Sravanthi) & Palamuru - Rangareddy Lift Irrigation Schemes, Proposed Generation Evacuation of 2x800 MW Telangana STPP - Provision of Reactors Reg.

Ref:- CEA Ir.No.51/4SP&PA-2015/406-407, dt.14-06-2016

\*\*\*\*\*

1) We are thankful for conveying in-principle approval of transmission evacuation scheme of Kaleshwaram Lift Irrigation Project (Dr.BR Ambedkar Pranihita Chevella - Sujala Sravanthi) & Palamuru - Rangareddy Lift Irrigation Schemes, Proposed Generation Evacuation of 2x800 MW Telangana STPP vide reference cited above.

2) In the above approval, with regard to provision of reactors to prevent high voltages during non operation of lift irrigation loads, it was mentioned that the requirement of provision for reactors would be worked out by TSTransco and would be submitted to CEA.

3) As per the above directive, studies are carried out for arriving the requirement of reactors to prevent high voltages during non operation of lift irrigation loads. Accordingly, the reactors are proposed at the following locations.

- i) Chadulapur LI SS( under Kaleshwaram LI Scheme) - 125 MVAR Bus Reactor
- ii) Narlapur LI SS( under Palamuru Rangareddy LI Scheme) - 125 MVAR Bus Reactor
- iii) Yedula LI SS( under Palamuru Rangareddy LI Scheme) - 125 MVAR Bus Reactor
- iv) Vатtem LI SS( under Palamuru Rangareddy LI Scheme) - 125 MVAR Bus Reactor
- v) Uddandapur LI SS( under Palamuru Rangareddy LI Scheme) - 125 MVAR Bus Reactor
- vi) Upcoming Telangana STPP(2 x800 MW), Ramagundam - 125 MVAR Bus Reactor

Contd..2..


*Smt. Shivanidevi*  
*14/9/2016*

*CC-PSPP-II-593*  
*9/9/16*

:: 2 ::

- 4) The single line diagrams along with the voltage limit check reports are herewith enclosed for your examination and concurrence.
- 5) It is requested to examine the above and suggest modifications if any, and communicate approval to the bus reactors at the above mentioned locations to prevent high voltages in operational season.

Encl: As above

  
Director/ Projects and Grid Operation

Copy to

Sri Pardeep Jindal, Chief Engineer (PSPA-2), Central Electricity Authority (CEA),  
RK Puram, Sewa Bhavan, New Delhi-110066.

**WITHOUT REACTORS**

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E

THU, SEP 01 2016 16:19

BUSES WITH VOLTAGE GREATER THAN THEIR NORMAL HIGH LIMIT:

BUS#	X-- NAME	--X BASKV	V(PU)	VLIMIT	BUS#	X-- NAME	--X BASKV	V(PU)	VLIMIT
511089	MALAKPET LI	132.00	1.1115	1.1000	511196	SIRCIJILA	132.00	1.1093	1.1000
514029	KAKTIA-G	400.00	1.0536	1.0500	514060	SURYPET4	400.00	1.0681	1.0500
514078	WARANGAL NEW	400.00	1.0629	1.0500	514079	WARN4	400.00	1.0594	1.0500
514131	MANIKONDA	400.00	1.0507	1.0500	514135	ASUPAKA	400.00	1.0980	1.0500
514164	VATTEM	400.00	1.0617	1.0500	514171	YEDULA	400.00	1.0570	1.0500
514172	NARLAPUR	400.00	1.0588	1.0500	514173	UDDANDAPUR	400.00	1.0642	1.0500
518079	WARN800	765.00	1.0818	1.0500					

BUSES WITH VOLTAGE LESS THAN THEIR NORMAL LOW LIMIT:

BUS#	X-- NAME	--X BASKV	V(PU)	VLIMIT	BUS#	X-- NAME	--X BASKV	V(PU)	VLIMIT
511069	SHPRN1	132.00	0.8930	0.9000	511182	JADCHERLA	132.00	0.8725	0.9000
511184	AYYAGARPALLI	132.00	0.8923	0.9000					

**WITH REACTORS**

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E      THU, SEP 01 2016 16:30

BUSES WITH VOLTAGE GREATER THAN THEIR NORMAL HIGH LIMIT:

BUS#	X--	NAME	--X	BASKV	V(PU)	VLIMIT	BUS#	X--	NAME	--X	BASKV	V(PU)	VLIMIT
514060		SURYPET4		400.00	1.0505	1.0500	518079		WARN800		765.00	1.0718	1.0500

BUSES WITH VOLTAGE LESS THAN THEIR NORMAL LOW LIMIT:

BUS#	X--	NAME	--X	BASKV	V(PU)	VLIMIT	BUS#	X--	NAME	--X	BASKV	V(PU)	VLIMIT
511069		SHPRN1		132.00	0.8695	0.9000	511182		JADCHERLA		132.00	0.8610	0.9000
511184		AYYAGARPAL11		132.00	0.8779	0.9000	512180		RENZAL		220.00	0.8976	0.9000

Fixed shunt data for base case

Bus Numb	Bus Name	Id	Area Num	Area Name	Zone Num	Zone Name	Code	In Service	G-Shunt (MW)	B-Shunt (Mvar)	G-Zero (MW)	B-Zero (Mvar)	Remarks
511079	WRNG 132.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	83.55	0	0	
512022	GAJWEL2 220.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	55.7	0	0	
512023	MEHBOBNG 220.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	222.79	0	0	
512055	MOULALI 220.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	374.29	0	0	
512102	BHOOTPUR 220.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	28.52	0	0	
512106	WANPRITHY 220.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	55.7	0	0	
514001	RSTP 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	-2	0	0	-57	0	0	
514002	HYDR 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	-57	0	0	
514002	HYDR 400.00	2	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	-113	0	0	
514003	NSAG 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	-45	0	0	
514003	NSAG 400.00	2	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	-113	0	0	
514004	KHAM 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	-45	0	0	
514004	KHAM 400.00	2	5 SOUTH	5 SOUTH	51	TELANGANA	1	0	0	-125	0	0	
514009	CHAND-SR 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	931.51	0	0	
514014	SSLBPH4 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	-2	1	0	-125	0	0	36 th SCM
514012	HYDR-TS4 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	-125	0	0	39 th SCM
514022	GAJWEL4 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	-125	0	0	36 th SCM
514023	MAHABUB4 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	-125	0	0	36 th SCM
514031	SINGARENI 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	-2	1	0	-63	0	0	Commissioned
514051	MAILARMA 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	-125	0	0	36 th SCM
514052	MALKARMA 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	-125	0	0	36 th SCM
514080	KOTH-VII 400.00	2	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	-125	0	0	36 th SCM
514134	MANUGURU 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	-2	1	0	-125	0	0	39 th SCM
514169	DAMARCHARLA 400.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	-2	1	0	-125	0	0	39 th SCM
518004	KHAM 800 765.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	-2	1	0	-250	0	0	39 th SCM
518051	HYDR 800 765.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	4	0	0	-660	0	0	
518051	HYDR 800 765.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	240	0	0	37 th SCM
518051	HYDR 800 765.00	2	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	240	0	0	37 th SCM
518062	NIZAMABAD 765.00	1	5 SOUTH	5 SOUTH	51	TELANGANA	1	1	0	240	0	0	37 th SCM


FIXED SHUNT DATA WITH PROPOSED REACTORS

Bus Number	Bus Name	Area	Area Name	Zone	Zone Name	Code	In Service	G-Shunt (MW)	B-Shunt (MVar)	G-Zero (MW)	B-Zero (MVar)	Remarks
511079	WRNG 132.00	1	5 SOUTH	51	TELANGANA	1	0	0	83.55	0	0	
512022	GAJWEL2 220.00	1	5 SOUTH	51	TELANGANA	1	0	0	55.7	0	0	
512023	MEHBOBNG 220.00	1	5 SOUTH	51	TELANGANA	1	0	0	222.79	0	0	
512055	MOULALI 220.00	1	5 SOUTH	51	TELANGANA	1	0	0	374.29	0	0	
512102	BHOOTPUR 220.00	1	5 SOUTH	51	TELANGANA	1	0	0	28.52	0	0	
512106	WANPRTHY 220.00	1	5 SOUTH	51	TELANGANA	1	0	0	55.7	0	0	
514001	RSTP 400.00	1	5 SOUTH	51	TELANGANA	-2	0	0	-57	0	0	
514002	HYDR 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-57	0	0	
514002	HYDR 400.00	2	5 SOUTH	51	TELANGANA	1	0	0	-113	0	0	
514003	NSAG 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-45	0	0	
514003	NSAG 400.00	2	5 SOUTH	51	TELANGANA	1	0	0	-113	0	0	
514004	KHAM 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-45	0	0	
514004	KHAM 400.00	2	5 SOUTH	51	TELANGANA	1	0	0	-113	0	0	
514009	CHAND-SR 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-125	0	0	
514011	SSLBPH4 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	331.51	0	0	
514012	HYDR-TS4 400.00	1	5 SOUTH	51	TELANGANA	-2	0	0	-125	0	0	
514022	GAJWEL4 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-125	0	0	
514023	MAHABUB4 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-125	0	0	
514031	SINGARENI 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-125	0	0	
514036	TEL_STPP/NTP400.00	1	5 SOUTH	51	TELANGANA	2	0	0	-63	0	0	
514051	MAILARM4 400.00	1	5 SOUTH	51	TELANGANA	-2	0	0	-125	0	0	Now proposed with 125MVAR
514052	MAL KARM4 400.00	1	5 SOUTH	51	TELANGANA	1	0	0	-125	0	0	
514080	KOTH-VII 400.00	2	5 SOUTH	51	TELANGANA	1	0	0	-125	0	0	
514107	CHANDULAPUR 400.00	1	5 SOUTH	51	TELANGANA	-2	0	0	-125	0	0	
514134	MANUGURU 400.00	1	5 SOUTH	58	TEL-LOAD	-2	0	0	-125	0	0	
514164	VATEM 400.00	1	5 SOUTH	58	TEL-LOAD	-2	0	0	-125	0	0	Now proposed with 125MVAR
514169	DAMARCHARLA 400.00	1	5 SOUTH	58	TEL-LOAD	-2	0	0	-125	0	0	
514171	YEDULA 400.00	1	5 SOUTH	58	TEL-LOAD	2	0	0	-250	0	0	Now proposed with 125MVAR
514172	NARLAPUR 400.00	1	5 SOUTH	58	TEL-LOAD	-2	0	0	-125	0	0	
514173	UDDANDAPUR 400.00	1	5 SOUTH	58	TEL-LOAD	-2	0	0	-125	0	0	Now proposed with 125MVAR
518004	KHAM 800 765.00	1	5 SOUTH	58	TEL-LOAD	-2	0	0	-125	0	0	Now proposed with 125MVAR
518051	HYDR 800 765.00	1	5 SOUTH	51	TELANGANA	4	0	0	-680	0	0	Now proposed with 125MVAR
518051	HYDR 800 765.00	2	5 SOUTH	51	TELANGANA	1	0	0	-240	0	0	
518051	HYDR 800 765.00	2	5 SOUTH	51	TELANGANA	1	0	0	-240	0	0	




TRANSCO-Base Case

518051  
HYDR. 810  
1.0  
7/8.3



STRAINS CO - Study with a Reactory

HYDR. 800  
787.9





Annex Agenda - 21.1

From  
The Director/Projects & LI,  
TSTRANSCO,  
Vidyut Soudha,  
Hyderabad.

To  
The Chief Engineer/PS P&A -II,  
Central Electricity Authority(CEA),  
RK Puram, Sewa Bhavan,  
New Delhi-110066

Lr.No. Dir(Proj)/SE(PS)/DE(SS)/ADE-3/F.39<sup>th</sup> SCM /D.No. 350 /16, Dt:28/05/2016

Sir,

Sub: - TSTransco - Minutes of 39<sup>th</sup> Standing Committee on Power System Planning of Southern Region, Dated 18-Feb-2016 - Proposal for augmentation of Power Transformers at 400 kV Gajwel SS with 1 No. additional 315 MVA( 4<sup>th</sup> PTR) and LILO of 400 kV Nagarjunasagar(Tallapalli) - Kurnool line to the Upcoming 400 kV Dindi SS as accepted in the meeting- Requested - Reg.

Ref:- 1) Minutes of the 39<sup>th</sup> Standing Committee Meeting dtd:18-02-2016.  
2) Lr.No. Dir(Proj)/SE(PS)/DE(SS)/ADE3/F.39<sup>th</sup> SCPSPSR Minutes/  
D.No.278/15,Dt.27-02-2016  
3) Lr.No. Dir(Proj)/ADE-T/F.TSTPP REVISED/d.No.197/16,  
Dt.27-04-2016

\*\*\*\*\*

1) We are thankful for arranging the joint studies at your esteemed office as per telephonic discussion on dtd.30-04-2016 regarding the study for the revised proposal for Kaleshwaram and Palamuru-Rangareddy Lift Irrigation Schemes on dtd:05-05-2016 and 06-05-2016.

2) In the references cited, it was requested to arrange approval for the augmentation of Power Transformers at 400 kV Gajwel SS with 1 No. additional 315 MVA Power Transformer ( 4<sup>th</sup> MVA PTR) and LILO of 400 kV Nagarjunasagar(Tallapalli) - Kurnool line to the Upcoming 400 kV Dindi SS.

3) The augmentation of the power transformers at 400 kV Gajwel SS with 1 No. additional 315 MVA Power Transformer (4<sup>th</sup> 315 MVA PTR) is essential in view of the COD of Singareni Collieries Company Limited Generation Unit -I(1x600 MW) in the month of June 2016.

4) In view of the above, it is requested to arrange for the approval of augmentation of Power Transformers at 400 kV Gajwel SS with 1 No. additional 315 MVA (4<sup>th</sup> 315 MVA PTR) and LILO of 400 kV Nagarjunasagar(Tallapalli) - Kurnool line to the Upcoming 400 kV Dindi SS and communicate the approval at the earliest for taking up the works.

Encl: As above

  
Director/Projects & LI 28/5/16

Copy to

Mrs.Seema Gupta, COO/CTU,CORPORATE CENTRE, Power Grid Corporation of India (PGCIL), Sector - 29, Near IFFCO Chowk, Gurgaon, Haryana - 122001.  
Chief Engineer/Projects-I & Chief Engineer/Projects-II/Vidyutsoudha/TSTRANSCO



Annex - Agenda - 22.1

TRANSMISSION CORPORATION OF TELANGANA LIMITED  
VIDYUT SOUDHA::HYDERABAD

From  
The Director/Transmission,  
TSTransco,  
Vidyut Soudha,  
Hyderabad

To  
The Chief Engineer,  
PSPA-II Division,  
Central Electricity Authority,  
Ministry of Power, Sewa Bhawan,  
RK Puram, New Delhi - 110066.

Lr.No.SE(PS)/DE(SS)/ADE/D.No. 283 /16,dt. 08-03-2016

Sir,

Sub:- Integration of Solar Power Project in Telangana, Arunachal Pradesh and Nagaland - Submission of proposals - Reg.

Ref:- Lr.No.200/13/PSPA-II-2016/73-81,dt.02-02-2016

\*\*\*\*

I am directed to inform that, it is convenient to evacuate 500 MW solar power at Gattu as follows:

- i) Gattu Solar Park to 400/220 kV Veltor SS by 220 kV D/C line of TSTransco which is about 70 KM.
- ii) Gattu Solar Park to upcoming 220 kV Thimmajipet Switching Station by 220 kV D/C line of TSTransco which is about 90 KM.

The above proposals are submitted for evacuation of 500 MW solar power at Gattu as sought.



PSIP  
ADE-2

Yours faithfully

DIRECTOR/TRANSMISSION

(Draft approved) (1/7)



Copy submitted to

The VC & Managing Director/NREDCAP/TNERDCL/5-8-207/2, Pisgah Complex  
Nampally/Hyderabad

Copy to

The Chief Engineer/Plg., Comml.&Co-Ordn./TSTransco/VS/Hyderabad  
The Chief Engineer/Project-II/TSTransco/VS/Hyderabad  
The Chief Engineer/Transmission/TSTransco/VS/Hyderabad



08/03

Annex - Agenda - 28.1

TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

From:  
The Chief Engineer( IPC&Power Systems),  
APTRANSCO,  
Vidyut Soudha,  
Hyderabad - 500 082

To  
The Chief Engineer (PSPA-II),  
Central Electricity Authority,  
Seva Bhavan,  
R.K.Puram,  
NEW DELHI - 110 066

Lr. No. CE(IPC&PS)/SE(PS)/DE(SS&LTSS)/F. SCM/ D.No. 125 /16 Dt. 14-07-2016

Sir,

Sub: APTRANSCO - Inclusion of 2 Nos items in the agenda discussion, in the forthcoming 40<sup>th</sup> Standing Committee Meeting - Requested - Regarding.

\*\*\*

APTRANSCO proposed the following 2Nos items and is requested to include these proposals as an agenda items for discussion in the forthcoming 40<sup>th</sup> Standing Committee Meeting.


**Item -1** : Joint System Studies were conducted by APTRANSCO with CEA &PGCIL on 25<sup>th</sup> & 26<sup>th</sup> May 2016 at New Delhi for evacuation of 6745 MW power from Wind Generators and 4000 MW power from solar power projects coming up in Andhra Pradesh with various wind & solar dispatch scenarios. These studies were conducted duly considering the wind & solar power evacuation schemes which were approved in 35<sup>th</sup> & 38<sup>th</sup> Standing Committee Meetings and the same is enclosed in ANNEXURE-1.

**Item - 2** : Scheme for evacuation of 231 MW power from M/s TPCIL at 220kV level in Nellore district and the same is enclosed in ANNEXURE-2.

Hence, it is requested to arrange to conduct special Standing Committee Meeting for approval of above agenda items.

**Encl : As above**

Yours faithfully,

  
Chief Engineer (IPC&Power Systems)

Copy to:

The Director (SP&PA),  
Central Electricity Authority,  
Seva Bhavan, R.K.Puram,  
NEW DELHI - 110 066

Ms. Suvoni  
19/7/16

331 C.E. PSPA-II  
19/7-16



## ANNEXURE -1

### Item No :1

Joint System Studies were conducted by APTRANSCO with CEA on 25<sup>th</sup> & 26<sup>th</sup> May 2016 at New Delhi for evacuation of 6745 MW power from Wind Generators and 4000 MW power from solar power projects coming up in Andhra Pradesh with various wind & solar dispatch scenarios and instructed APTRANSCO to communicate the load flow studies for proposed scheme for inclusion of agenda item for discussion in the forthcoming 40<sup>th</sup> Standing Committee Meeting.

The APTRANSCO proposed comprehensive wind power evacuation scheme for evacuation of power from wind projects of about 3150 MW mainly coming up in Ananthapur, Kurnool and Kadapa districts of Andhra Pradesh i.e., at Uravakonda area (1361 MW), Kondapuram area (1109 MW) and Hindupur area (680 MW) based on the location of wind power projects. The scheme was approved in the 35<sup>th</sup> Standing Committee Meeting on Power system planning of Southern Region held on 04<sup>th</sup> January 2013 and this is under implementation by APTRANSCO. Later the transmission scheme for evacuation of 1000 MW wind power projects coming up at Aspiri in Kurnool district was approved in the 38<sup>th</sup> Standing Committee Meeting on Power system planning of Southern Region held on 23<sup>rd</sup> March 2015.


In this context, the APTRANSCO carried out system studies and the load flow results along with scheme details are herewith enclosed. The same is sent through mail also.

**Details of wind & solar power projects**

	Name	Location	Type	Installed Capacity (MW)	Developer
1	NP. Kunta	Anantapur	Solar	1000	NTPC
2	Galiveedu	Cuddapah	Solar	500	APSPCL
3	Panayam	Kurnool	Solar	1000	NVVNL
4	Talaricheruvu	Anantapur	Solar	500	APGENCO
5	Mylavaram	Kadapa	Solar	1000	APSPCL
	<b>Sub-total</b>		<b>Solar</b>	<b>4000</b>	
6	Uravakonda	Anantapur	Wind	2095	Pvt developers
7	Kondapur	Cuddapah	Wind	950	Pvt developers
8	Hindupur	Anantapur	Wind	1300	Pvt developers
9	Uravakonda -2	Anantapur	Wind	1400	Pvt developers
10	Aspiri	Kurnool	Wind	1000	Pvt developers
	<b>Sub-total</b>		<b>Wind</b>	<b>6745</b>	
	<b>Total</b>			<b>10745</b>	

4345 - 3150 = 1195

**EVALUATION SCHEME OF WIND POWER PROJECTS COMING UP IN AP in Kadapa, Anantapur & Kurnoor Districts**



400 KV URAVAKONDA	2095 MW
400 KV KONDAPURAM	950 MW
400 KV HINDUPUR	1300 MW
400 KV URVAKONDA	1400 MW
400 KV ASPTL	1000 MW
<b>TOTAL WIND (PROPOSED MW)</b>	<b>6745 MW</b>
<b>SOLAR</b>	
400 KV NP KUNTA	1500 MW
400 KV GANIPANYAM	1000 MW
400 KV TALARICHERUVU	500 MW
400 KV MALAVARAM	1000 MW
<b>TOTAL SOLAR (PROPOSED MW)</b>	<b>4000 MW</b>



Scheme details

Connectivity Approved

SI No	Name of the Element	Length in KM	Status
1	400kV Quad Moose DC line from 400kV Uravakonda SS to 400kV MahaboobNagar SS	190	Under construction
2	400kV Quad Moose DC line from 400kV Uravakonda SS to 400kV Kondapuram SS	128	Commissioned
3	400kV Quad Moose DC line from 400kV Uravakonda SS to 400kV Hindupur SS	130	Under construction
4	400kV Quad Moose DC line from 400kV Kondapuram SS to 400kV Kurmool SS	120	Commissioned
5	400kV Quad Moose DC line from 400kV Hindupur SS to 400kV NPKunta SS	110	to be executed by PGCIL
6	400kV Quad Moose DC line from 400kV Kadapa SS to 400kV NPKunta SS	60	to be executed by PGCIL
7	220kV Twin Moose DC line from 400/220kV Uravakonda SS to 220kV Vajrakarur SS	13	Under construction
8	220kV Twin Moose DC line from 400/220kV Uravakonda SS to 220kV Borampalli SS	55	Under construction
9	220kV Single Moose DC line from 400/220kV Uravakonda SS to 220kV Borampalli SS	55	Under construction
10	220kV Single Moose DC line from 220kV Kalyandurg SS	15	Under construction
11	220kV Single Moose DC line from 400/220kV Kondapuram SS to 220kV Thirumalayapalli SS	17	Under construction
12	220kV Single Moose DC line from 400/220kV Kondapuram SS to 220kV Bethamcherla SS	66	Proposed
13	220kV Single Moose DC line from 400/220kV Kondapuram SS to 220kV Chakrayapet SS	70	Under construction
14	220kV Single Moose DC line from 400/220kV Kondapuram SS to 220kV Porumamilla SS	75	Under construction
15	220kV Single Moose DC line from 400/220kV Kondapuram SS to 220kV Tadipatri SS	40	Proposed
16	220kV Single Moose DC line from 400/220kV Kondapuram SS to 220kV Jammalamadugu SS	10	Under construction
17	220kV Twin Moose DC line from 400/220kV Hindupur SS to 220kV Pampanur Tanda SS	70	Proposed
18	220kV Single Moose DC line from 400/220kV Hindupur SS to 220kV Penukonda SS	50	Proposed
19	220kV Single Moose DC line from 400/220kV Hindupur SS to 220kV Hindupur/Gollapuram SS	20	Proposed
20	1x 80 MVAR Bus reactor at 400/220kV Uravakonda SS		Under construction
21	1x 80 MVAR Bus reactor at 400/220kV Kondapuram SS		Under construction
22	1x 80 MVAR Bus reactor at 400/220kV Hindupur SS		Under construction
23	132kV DC line from 220/132kV Jammalamadugu to 132kV Jammalamadugu	10	Under construction
24	132kV DC line from 220/132kV Porumamilla to 132kV Porumamilla	10	Under construction
25	132kV DC line from 220/132kV Penukonda to 132kV Penukonda	10	
<b>Connectivity to be approved</b>			
1	Making LLO of both circuits of 400kV Quad Moose DC line from 400kV Uravakonda SS to 400kV Kondapuram SS at proposed 400kV Talaricheruvu SS	2	
2	400kV Quad Moose DC line from 400kV Kondapuram SS to 400kV Mylavaram SS	10	
3	400kV Quad Moose DC line from 400kV Aspiri SS to 400kV Kurmool SS	80	
4	400kV Quad Moose DC line from 400kV Uravakonda SS to 400kV Uravakonda-2 SS	25	
6	220kV Single Moose DC line from 400/220kV Hindupur SS to 220kV Pampanur Tanda SS	70	
7	220kV Twin Moose DC line from 220kV Vajrakarur SS to 220kV Antartapur SS	60	
8	1x125 MVAR Bus reactor at 400/220kV Uravakonda-2 SS		
9	1x125 MVAR Bus reactor at 400/220kV Talaricheruvu SS		
10	1x125 MVAR Bus reactor at 400/220kV Mylavaram SS		
11	1x125 MVAR Bus reactor at 400/220kV Aspiri SS		
<b>Modification</b>			
1	Already approved 220kV Single Moose DC line from 400/220kV Hindupur SS to 220kV Hindupur/Gollapuram SS to be modified as 220kV Twin Moose DC line from 400/220kV Hindupur SS to 220kV Hindupur/Gollapuram SS	20	
2	Already approved 220kV Single Moose DC line from 220kV Borampalli SS to 220kV Kalyandurg SS to be modified as 220kV Twin Moose DC line from 220kV Borampalli SS to 220kV Kalyandurg SS	15	

### Wind Power Projects

SL No	Name of 400kV Substation	Name of the Substation	Proposed Wind Power Generation Installed Capacity (MW)	Project Status
1	400kV Uravakonda SS, Ananthapur Dt. (2x315+2x 500 MVA)	LV Bus of 400kV SS	1035 ✓	Under construction
		220kV Borampalli SS (2x160 MVA)	800	
		220kV VajraKarur SS (2x160 MVA)	260	
2	400/220/132kV Kondapuram SS, Kadapa Dt. (3x315 MVA+ 2x 160 MVA) Jammalamadugu)	220kV Tirumalayapalli SS (2x160 MVA)	250	Under construction
		220kV Bethamcherla SS (2x160 MVA)	250	
		220kV Chakrayapet SS (2x160 MVA)	200	
		220kV Porumamilla SS(2x160 MVA)	250	
3	400kV Hindupur SS, Ananthapur Dt. (4x315 MVA)	220kV Penukonda SS (2x160 MVA)	300	Under construction
		220kV PampanurThanda SS (2x160 MVA)	1000	
4	400kV Uravakonda-2 SS (4x315 MVA)	LV Bus of 400kV SS	1400	Proposed
5	400kV Aspiri SS (3x315 MVA)	LV Bus of 400kV SS	1000	Proposed
<b>TOTAL</b>			<b>6745</b>	

### Solar Power Projects

SL No	Name of 400kV Substation	Name of the Substation	Proposed solar Power Generation Installed Capacity (MW)	Project Status
1	400kV Talaracheruvu SS, Ananthapur Dt. (3x315 MVA)	LV Bus of 400kV SS	500	Proposed
2	400kV Mylavaram SS, Kadapa Dt. (3x315 MVA)	LV Bus of 400kV SS	1000	Proposed
TOTAL			1500	

SI No	Name of the SS	PTR Capacity (MVA)
1	400kV Uravakonda	2 x315+ 2 x500
2	400kV Kondapuram	3 X 315
3	400kV Uravakonda -2	4 X 315
4	400kV Hindupur	4 x 315
5	400kV Talaricheruvu	3 X 315
6	400kV Aspiri	3 x 315
6	400kV Mylavaram	3 X 315
7	220kV Borampalli	2 x 160
8	220kV Vajrakarur	2 x 160
9	220kV Thirumalayapalli	2 x 160
10	220kV Bethamcherla	2 x 160
11	220kV Porumamilla	2 x 160
12	220kV Chakrayapet	2 x 160
13	220kV Jammalamadugu	2 x 160
14	220kV Penukonda	2 x 160
15	220kV PanpanurTanda	2 x 160

Bus Name	Id	In Service	PGen (MW)	PMax (MW)	Type	Column f
ASPIRI 220.00	W1	1	790	1000	Wind	IPP
BETUMCHARLA 220.00	W1	1	187.5	250	Wind	IPP
BORUMPALLI 220.00	W1	1	800	800	Wind	IPP
CHAKRAPET 220.00	W1	1	150	200	Wind	IPP
GAMESH 132.00	W1	1	5.25	7	Wind	IPP
JAMMALAMADUG 220.00	W1	1	90	120	Wind	IPP
KLDG 132.00	W1	1	1.5	2	Wind	IPP
KOMA 132.00	W1	1	18.75	25	Wind	IPP
PAMPUN 220.00	W1	1	750	1000	Wind	IPP
PENUKONDA 220.00	W1	1	225	300	Wind	IPP
PORUMAMILLA 220.00	W1	1	187.5	250	Wind	IPP
RAYALA-WIND 220.00	W1	1	5.25	7	Wind	IPP
RCANATAPUR 220.00	W1	1	52.5	70	Wind	IPP
SHAPURAM 220.00	W1	1	63	84	Wind	IPP
SUZLON 132.00	W1	1	40.5	54	Wind	IPP
SUZLON 220.00	W1	1	45	60	Wind	IPP
TIRUMALAYAPA 220.00	W1	1	197.5	250	Wind	IPP
URAVAKONDA 220.00	W1	1	776.25	1035	Wind	IPP
URVKND2 220.00	W1	1	1050	1400	Wind	IPP
VAJRAKORUR 220.00	W1	1	195	250	Wind	IPP

peak demand  
11500 MW

VC, MW	Thermal	Hydro	Gas	Wind	Solar	total-Con	total-RE	Total
State	5016	1882	0	0	2500	6892	2500	9392
IPP	1046	0	2536	7174	1650	3576	8724	12300
CS & CS IPPs	3125	0	0	0	0	3125	0	3125
Total	9175	1882	2536	7174	4050	13593	11224	24817

Case 1 : Full Wind & Full Solar (1300 Hr. in May/June -Max case)

VC, MW	Thermal	Hydro	Gas	Wind	Solar	total-Con	total-RE	Total-Disp	Demand
State	501	376	0	5381	3038	3305	8017	11322	397
IPP	1046	0	2536	7174	1650	3576	8724	7007	Diff.
CS & CS IPPs	3125	0	0	0	0	3125	0	1563	
Total	2168	376	761	5381	3038	3305	8017	11322	397

Case 2 : Less Wind & full Solar (1300 Hr. in May/June)

VC, MW	Thermal	Hydro	Gas	Wind	Solar	total-Con	total-RE	Total-Disp	Demand
State	2004	565	0	4304	2025	5471	6061	11532	-168
IPP	1046	0	2536	7174	1650	3576	8724	3819	Diff.
CS & CS IPPs	3125	0	0	0	0	3125	0	5838	
Total	5024	188	0	3587	3038	5212	6625	11837	11700

Case 3 : Full Wind & Less Solar (July Noon time)

VC, MW	Thermal	Hydro	Gas	Wind	Solar	total-Con	total-RE	Total-Disp	Demand
State	2004	565	0	4304	2025	5471	6061	11532	-168
IPP	1046	0	2536	7174	1650	3576	8724	3819	Diff.
CS & CS IPPs	3125	0	0	0	0	3125	0	5838	
Total	4599	565	507	4304	2025	5471	6061	11532	-168

Case 4 : No Wind & Full Solar (Noon time December)

VC, MW	Thermal	Hydro	Gas	Wind	Solar	total-Con	total-RE	Total-Disp	Demand
State	2268	1129	761	0	3038	8375	2636	11011	-689
IPP	1046	0	2536	0	0	3576	0	6281	Diff.
CS & CS IPPs	3125	0	0	0	0	3125	0	2250	
Total	6485	1129	761	0	3038	8375	2636	11011	-689


Case 5 : Full Wind & No Solar (Evening Peak in June)

VC, MW	Thermal	Hydro	Gas	Wind	Solar	total-Con	total-RE	Total-Disp	Demand
State	3258.5	376.4	507.2	4304.4	0	7368.1	4811.6	12179.7	1024.7
IPP	1046	0	2536	7174	0	3576	0	3632.9	Diff.
CS & CS IPPs	3125	0	0	0	0	3125	0	6046.8	
Total	6484.5	376.4	507.2	4304.4	0	7368.1	4811.6	12179.7	11155


Case 6 : No Wind & No Solar (Evening peak in March)

VC, MW	Thermal	Hydro	Gas	Wind	Solar	total-Con	total-RE	Total-Disp	Demand
State	4509	1317.4	2028.8	0	0	11603.7	0	11603.7	103.7
IPP	1046	0	2536	0	0	3576	0	5826.4	Diff.
CS & CS IPPs	3125	0	0	0	0	3125	0	2964.8	
Total	6257.5	1317.4	2028.8	0	0	11603.7	0	11603.7	11500


ANDHRA PRADESH SYSTEM STUDIES (2019-20 TIME FRAME)



ANDHRA PRADESH SYSTEM STUDIES (2019-20 TIME FRAME)




ANDHRA PRADESH SYSTEM STUDIES (2019-20 TIME FRAME)







ANDHRA PRADESH SYSTEM STUDIES (2019-20 TIME FRAME)



# ANDHRA PRADESH SYSTEM STUDIES (2019-20 TIME FRAME)



# ANDHRA PRADESH SYSTEM STUDIES (2019-20 TIME FRAME)



## ANNEXURE – II


### Item - II

APTRANSCO proposed the following dedicated scheme for Evacuation of 231 MW power from M/s Thermal Powertech Corporation India Ltd. at 220 kV level in Nellore District.

- a) 220 kV Twin Moose DC line (40 KM) from M/s TPCIL to 400/220 kV Manubolu SS.
- b) 2 x 315 MVA 400/220 kV ICT at M/s TPCIL.


The Load flow results are herewith enclosed. The same is sent through e-mail also.

<b>LINE FLOWS WITH AND WITHOUT EVACUATION OF TPCIL AT 220KV LEVEL.</b>			
<b>S/L.No.</b>	<b>Description</b>	<b>Existing System</b>	<b>220KV TWIN MOOSE DC LINE FROM 220KV MANUBOLU SS TO M/S TPCIL</b>
		<b>MW</b>	<b>MW</b>
1	400/220KV ICT Loadings at Manubolu	3 x 343.9	3 X 249.5
2	400 kV Manubolu - Nunna	2 x -49.7 + 1 x -59.4	2 x -79.5 + 1 x -95
3	400 kV Manubolu - VTPS-IV	-36.7	-68.4
4	400 kV Manubolu - Krishnapatnam	2 x -504.8	2 x -547.4
5	400 kV Manubolu - Nellore Pool	2 x -764.4	2 x -452.2
6	400 kV Manubolu - Tiruvefani	2 x 460.6	2 x 424.8
7	400 kV Manubolu - Almatti	2 x 390.5	2 x 361.8
8	220/132KV PTR Loadings at Manubolu	3 x 54.2	3 x 56.9
9	220KV Manubolu - Sullurpet	2 x 133.7 + 1 x 92.4	2 x 148.5 + 1 x 102.7
10	220KV Manubolu - Nellore	2 x 128.8 + 1 x 85.4	2 X 139.8 + 1 X 92.7
11	220KV Manubolu - Rachagunneri	2 x 52.4	2 x 69.5
12	220KV Manubolu - Renigunta	61.3	77.7
13	220KV Manubolu - TPCIL	-	2 X -205.5
14	220/132KV PTR Loadings at Nellore	2 x 96.4 + 1 x 65.8	2 x 96.9 + 1 x 66.1
15	220KV Nellore - Atmakur	2 x -15.3	2 x -6.2
16	220KV Nellore - IFFCO SEZ	53.1	62.4
17	220KV IFFCO SEZ - Ongole	-96	-85.5
18	220/132KV PTR Loadings at Podili	1 x 39.6 + 1 x 38.7	1 x 39.6 + 1 x 38.7
19	220KV Podili - Atmakur	2 x 92.2	2 x 82.7
20	220KV Podili - Kandukur	2 x 48.0	2 x 48.0
21	ICT Loadings at 400/220KV Podili SS	3 x 130.6	3 x 127.5
22	400 kV Podili - Sattenapalli	2 x -150.4	2 x -143.3
23	400 kV Podili - Chilakaluripet	2 x -45.6	2 x -47.9
24	ICT Loadings at 400/220KV TPCIL SS	-	2 x 206.4
25	400 kV TPCIL - Nellore Pool	2 x 620.00	2 x 103.4
	<b>EHT System Losses</b>	<b>449.540</b>	<b>442.920</b>



ANVA 05/09/1997: SERRAVALLE/BAIO J.M.H.

WITH TYPICAL ELEVATION AT 200V LEVEL



EIGHT OTHER WIRING LOSSES: 442 820 000 W