

**Central Electricity Authority**  
**Power System Planning & Appraisal-II Division**  
**Sewa Bhawan, R.K. Puram, New Delhi – 110066**

No. 51/4/(40<sup>th</sup>)/PSPA-II-2017/245-258

Dated: 17.03.2017

Sub: **40th meeting** of the Standing Committee on Power System Planning of  
**Southern Region - Corrigendum to Minutes** of the meeting.


Sir,

The minutes of **40th meeting** of the Standing Committee on Power System Planning of Southern Region were issued vide our letter No. 51/4/(40<sup>th</sup>)/PSPA-II/2017/92-105 dated 16<sup>th</sup> Feb, 2017. Based on observations/comments received from APTRANSCO corrigendum to the above minutes is enclosed at Annex-I.

It is also available at CEA's website ( www.cea.nic.in ).

This is issued with the approval of Member (Power System), CEA.

Yours faithfully,



(प्रदीप जिंदल /Pardeep Jindal)

मुख्य अभियंता (वि प्र यो मू2 -) / Chief Engineer (PSPA-II)

To

1. The Member Secretary, Southern Regional Power Committee, 29, Race Course Cross Road, <b>Bangalore 560 009.</b> FAX : 080-22259343	2. The Director (Projects), Power Grid Corp. of India Ltd. "Saudamini", Plot No.2, Sector-29, <b>Gurgaon 122 001, Haryana.</b> FAX : 95124-2571932
3. CEO, POSOCO, B-9, Qutub Institutional Area, Katwaria Sarai, <b>New Delhi-110016</b>	4. The Director (Transmission), Karnataka State Power Trans. Corp.Ltd., Cauvery Bhawan, <b>Bangalore - 560 009.</b> FAX : 080 -22228367

<p>5. The Director (Transmission), Transmission Corp. of Andhra Pradesh Ltd., (APTRANSCO) Vidyut Soudha, <b>Hyderabad – 500 082.</b> FAX : 040-66665137</p>	<p>6. The Director (Grid Transmission and Management), Transmission Corp. of Telangana Ltd., (TSTRANSCO) Vidyut Soudha, Khairatabad <b>Hyderabad – 500 082.</b> FAX : 040-23321751</p>
<p>7. The Member (Transmission), Kerala State Electricity Board, Vidyuthi Bhawanam, Pattom, P.B. No. 1028, <b>Thiruvananthapuram - 695 004.</b> FAX : 0471-2444738</p>	<p>8. Member (Distribution), Tamil Nadu electricity Board (TNEB), 6<sup>th</sup> Floor, Eastern Wing, 800 Anna Salai, <b>Chennai - 600002.</b> FAX : 044-28516362</p>
<p>9. The Director (Power), Corporate Office, Block – I, Neyveli Lignite Corp. Ltd., <b>Neyveli , Tamil Nadu – 607 801.</b> FAX : 04142-252650</p>	<p>10. The Superintending Engineer –I, First Floor, Electricity Department, Gingy Salai, <b>Puducherry – 605 001.</b> FAX : 0413-2334277/2331556</p>
<p>11. Director (Projects), National Thermal Power Corp. Ltd. (NTPC), NTPC Bhawan, Core-7, Scope Complex, Lodhi Road, <b>New Delhi-110003.</b> FAX-011-24360912</p>	<p>12. Director (Operations), NPCIL, 12<sup>th</sup> Floor, Vikram Sarabhai Bhawan, Anushakti Nagar, <b>Mumbai – 400 094.</b> FAX : 022- 25991258</p>

**Copy to:**

1.	<p>The Director (Projects), Power Grid Corp. of India Ltd. "Saudamini", Plot No.2, Sector-29, <b>Gurgaon 122 001, Haryana.</b> FAX : 95124-2571932</p>
2.	<p>GM, SRLDC, 29, Race Course Cross Road, <b>Bangalore 560 009</b> FAX – 080-22268725</p>



---

**Corrigendum#1:**

**Corrigendum to Minutes of 40th Meeting of the Standing Committee on Power System Planning in Southern Region (SCPSPSR) held on 19 November, 2016 in Hyderabad**

---

The minutes of **40th meeting** of the Standing Committee on Power System Planning of Southern Region were issued vide our letter No. 51/4/ (40<sup>th</sup>)/PSPA-II/2017/92-105 dated 16<sup>th</sup> Feb, 2017. Following corrigendum is issued based on observations/comments received from APTRANSCO received vide their letter No CE(IPC&PS)/SE(PS)/DE(SS&LTSS)/F.SCM/D.NO.240/17 dated 20.02.2017

**Corrigendum to para 29.5 of the minutes:** The para 29.5, **Item 5** and **Item 7** is modified as given below:

**5) Transmission schemes for wind projects at 400kV Aspiri SS (3X315)**

- i) 400kV Quad Moose DC line from 400kV Aspiri SS to 400kV Kurnool SS
- ii) 1x125 MVAR Bus reactor at 400/220kV Aspiri SS

**7) Transmission schemes for solar projects at 400kV Mylavaram SS, Kadapa (3X315)**

- i) 400kV Quad Moose DC line from 400kV Kondapuram SS to 400kV Mylavaram SS
- ii) 1x125 MVAR Bus reactor at 400/220kV Mylavaram SS