

Corrigendum.
10th SCM

**CENTRAL ELECTRICITY AUTHORITY
SYSTEM PLANNING & APPRAISAL DIVISION
SEWA BHAWAN, R.K. PURAM,
NEW DELHI-110 066.**

No. 26 / 10 /99-SPA/ 291-99

Dated 18th Feb. 1999.

The Chief Engineer (Tr.Plg.)
Maharashtra State Elec. Board
'Prakashgad', Plot No.G-9,
Bandra (East), **Mumbai-400051.**
Fax No. 022-6452868

The Member (Power),
Narmada Control Authority
113-BG, Scheme No.74-C,
Vijay Nagar, **Indore- 452 010.**
Fax No. 0731-559888

The Chief Engineer (Tr.)
Gujarat Electricity Board,
Sardar Patel Vidyut Bhawan,
Race Course, **Baroda-390 007.**
Fax No. 0265-337918

The General Manager (Elect.)
NTPC Limited,
Engg. Office Complex,
A-8, Sector- 24,
Noida-201 301
Fax No. 91-539462

The Executive Director (T&P)
Madhya Pradesh Elec. Board,
Shakti Bhawan, Vidyut Nagar,
Jabalpur-482 008
Fax No. 0761-311696

The Chief Engineer (Tr.)
Nuclear Power Corporation,
Vikram Sarabhai Bhawan,
Anushakti Nagar,
Mumbai-400 094.
Fax No.022-5563350

The Chief Elect.Engineer,
Electricity Department,
Government of Goa, **Panaji.**
Fax No.0832-222354

The Member Secretary,
Western Regl.Elec. Board,
MIDC Area, Marol,
Andheri East, **Mumbai.**
Fax No.022-8370193

The Executive Director (Engg.)
Power Grid Corp. of India Ltd,
Hemkunt Chambers, 10th Floor,
89, Nehru Place, New Delhi.- 19

**Subject: Summary record of Tenth Standing Committee meeting on Power
System Planning in Western Region held on 2.12.98.**

Sir,

Please refer to our letter of even no. dated 18.12.98 forwarding summary record of Tenth Standing Committee meeting on power system planning in Western Region held on 2.12.98. It is requested that following corrections in the summary record may be incorporated:

Para 5 on page 2 may be read as follows:

“ The Executive Director MPEB stated that the share of power from Central Sector power project located in the Gujrat would be supplied to the constituents at 220kV and share of MPEB would be transferred to MPEB through displacement and accordingly it was necessary that the network in MPEB area should also be strengthened to enable MP absorb its share in a proper manner. He therefore proposed that 400KV substation be established at Chhegaon in Madhya Pradesh by LILO of 400kV Itarsi-Dhule DC line. As Chhegaon is close to the alignment of line, additional transmission network may not be required. It was also suggested by Executive Director, MPEB that power evacuation system of Kawas CCGT Stage-II and Gandhar CCGT Stage-II should from two parts . Part I should cover Network included in the agenda notes and agreed by the constituents and part II should cover 400/220kV 2x315MVA 400kV substation at Chhegaon by LILO one ckt. Of Itarsi-Dhule 400kV DCDS line.”

In third para on last page, Chief Engineer, MPEB may be read as Executive Director, MPEB.

Yours faithfully,



o/c

(V.J. TALWAR)
DIRECTOR (SP&A)

Issued
19.02.99