

LIFE ENHANCEMENT OF E&M EQUIPMENT THROUGH IMPROVISED O&M TECHNIQUES



By: S.P.Pathak,
GM Electrical Design



PART -A

**EXPERIENCES OF SJVN WITH HVOF
HARD COATINGS OF UNDERWATER
TURBINE PARTS AT NJHPS AND RHPS:
WAY FORWARD**


1. HVOF Coating

- Tungsten Carbide
 - Typical Chemical Composition
 - Typical HVOF Parameters

Innovations of SJVN

- Hard coating plant installed at NJHPS which is 1st ever hard coating plant provided at a Hydel Power house in the country

Hard coating workshop



robotic arm hard coating the
guide vane



Hard coating workshop with 40T Turn table

- **Following components are under regular coating**
 - Guide vanes
 - Cheek plate
 - Labyrinth seal
 - Turbine Wear rings
 - Upper DT cone
 - Silt Flushing gate
 - GV Sealing ring

- **MOP has initiated policy interventions for setting up of such Hard Coating facilities by all Hydro Power Developer for their projects.**

NJHPS new runners (250 MW each) with coating



Hard coated runners of RHPS (68.67 MW each)



NJHPS runners (coated and uncoated)

Original runner



uncoated 16:5 runner after one year of operation

New Runner




coated 13:4 runner after one year of operation

Runner materials

- Original runners were of 16:5 composition
- 4 new spare runners of 13:4 composition were procured in 2008

- | | Original runner | New Runner |
|----------------------|---|---|
| Material Composition | X4CrNiMo 16-5-1
C max 0.06
Cr 15.0-17.0
Ni 4.0-6.0
Mo 0.80-1.50 | X3CrNiMo 13-4
C max 0.05
Cr 12-14
Ni 3.5-4.5
Mo 0.3-0.7 |

Other Innovations In Underwater Components



Innovative Repair Techniques

- Advanced coating in
 - Spiral casing
 - Stay rings and stay vanes
- In-situ Machining in
 - Upper Turbine cover/ top cover
 - Bottom Turbine cover/ Bottom ring
 - Sitting surface of Upper Labyrinth Seal Stationary (ULSS)

Bottom Turbine cover/ Bottom ring



In Situ machining



Sitting surface of Upper Labyrinth Seal Stationary (ULSS)

- Repeated failure of labyrinth was observed



After Welding and Manual Grinding



In-Situ Machined ULSS

3. Repair and Maintenance

- Regular maintenance and cleaning is done to enhance the lifecycle and availability of the components.
- The welding is done with ESAB 309 Mo electrode.
- The profiles of over dimensional and non-removable components of hydro turbines were re-maintained through In-situ self-leveling machining using laser guidance.
- The repair of runner and guide vanes were carried out using templates to match original profile to the extent possible.

In-situ machining of Silt Flushing gates



What we achieved

- Enhancement in life of components
- Reliable and consistent performance throughout the annual operating cycle
- Less erosion in underwater parts and less maintenance time.
- Consistent generation both in NJHPS and RHPS above design value

Challenges ahead:

- To improve the quality of hard coating, its application, and continuous adoption of better materials
- To achieve two year repair cycle in place of one year repair cycle at present
- To achieve most optimal/ suitable combination of HVOF (Hard coating) and Soft Coating (Ceramics based brushable/ epoxy based combination coating) for enhancing the life of underwater components

PART -B

**LIFE EXTENSION MEASURES FOR
ELECTR-MECHANICAL EQUIPMENT:
AN EXPERIENCE OF SJVN**

SJVN'S EXPERIENCE OF LIFE EXTENSION MEASURES



AT NJHPS
(6X 250MW)

- **Retrofit of 400kV GIS**
- **Modernization of existing Bus Bar Protection scheme**

RATIONALE FOR R&M & LIFE EXTENSION



New Plants – costly, having longer gestation period.

Obsolescence due to technology upgradation.

R&M at lower costs and life extension achieved.

OBJECTIVE FOR R&M & LIFE EXTENSION

Exploit the design margins

Better spare management

Ease of operation

Life extension in cost effective manner

CHALLENGES TO R&M



IMPLEMENTATION

R&M Solutions are complex and plant specific

Constraints in defining exact scope of work

Limited agencies for R&M implementation (OEM vs Others)

R&M activity to be associated with planned unit shutdown

Loss of Generation/ Availability

Retrofit and Extension of 400kV GIS

NEED

&

BENEFITS

Equipment Failure History at NJHPS due to impact of Overvoltage during off Peak Seasons (Sept. to May)


- A. B-Ph CB pole failure of NJ-Rampur(Ex NLG) on 12/07/03.
- B. R-ph CB pole failure of NJ-KCW-I (Ex Baspa)on 10/02/05
- C. B-Ph CB pole failure of NJ-Panchkula-I(ex ABD) on 04/04/09
- D. R-PH CB pole failure of NJ-Panchkula-I on 19/11/09
- E. R-Ph CB pole failure of NJ-KCW-II on 13/12/09
- F. - R-Ph CB pole failure of NJ-Panchkula-I on 20/02/11

REMARK SINCE 2011, SJVN HAS MANAGED TO MITIGATE THE FAULTS BY ADOPTING FREQUENT MONITORING OF SF6 ACIDITY LEVELS **OVER AND ABOVE THE MANUFACTURER'S RECOMMENDATIONS.**


OVER VOLTAGES DURING OFFPEAK HOURS IN LEAN SEASON




NJHPS Typical bus Voltage




Abdullapur-1 , Pre Fault Voltage 431KV



- VA 248766.072
- VB -114348.625
- VC -131129.219
- VN 3897.573



- IA -20.233
- IB 105.548
- IC -90.534
- IN -0.144



- ↓ L1 52 R PH OPEN
- ↓ L2 52 Y PH OPEN
- ↓ L3 52 B PH OPEN
- ↓ L8TRIP CH 1/2REC
- ↑ L15 86 LO TRIP
- ↓ L12 LBB OPTD
- ↓ L10MAIN 2 OPTD
- ↓ Any Start
- ↓ Any Trip
- ↓ L6BUS 1/2 U/V
- ↓ L7 V>PROTN OPTD
- ↓ Z1
- ↓ Z4
- ↓ T1
- ↓ T4


00.995 21:47:11.885 01.094 21:47:11.984 01.194 21:47:12.084 01.293 21:47:12.183 01.393 21:47:12.283 01.492 21:47:12.382 01.592 21:47:12.482



EView - [C:\Program Files\AREVA T&D\LBB191109\Dated 191109\Abdi_191109_214711.cfg]

File Edit Window Help

Fault Developed when Voltage Rises to 368.7KV(Ph-N)







EFFECTS

HIGH FREQUENCY OF BREAKER FAULTS

FASTER RATE OF CONSUMPTION OF INITIAL SPARES

SPARE MANAGEMENT BECAME A BOTTLENECK FOR SJVN

THE NEED

- ***RECOMMENDATIONS OF NRPC FOR REACTIVE COMPENSATION(80MVar Reactor at both NJHPS & RHPS)***
- ***SPARE MANAGEMENT OF EXISTING OBSOLETE MODEL OF GIS EQUIPMENT***

THE PROPOSAL

- ***EXTENSION OF 01 NEW 420KV GIS BAY FOR SWITCHING OF 80MVAR BUS REACTOR***
- ***RETROFITTING OF EXISTING 01 NO. 420 KV GIS LINE BAY WITH LATEST AVAILABLE GIS CIRCUIT BREAKER.***

BENEFIT



ADAPTATION OF NEW TECHNOLOGY

THE SPARE FOR THE NEW MODEL BREAKER WOULD BE EASILY AVAILABLE, WHILE THE THREE POLES OF THE OLD GIS MODEL B-142 DISMANTLED C.B, AS WELL ITS HYDRAULIC OPERATING MECHANISMS, WOULD SERVE AS SPARE FOR THE EXISTING BAYS, LEADING TO SPARE MANAGEMENT IN COST EFFECTIVE MANNER FOR NEXT 5-10 YEARS.

PLANNING

AS BOTH 1500MW NJHPS AND 412MW RHPS OF SJVN ARE RUNNING IN TANDEM, LOSSES ASSOCIATED WITH THE DOWNTIME FOR INSTALLATION, TESTING AND COMMISSIONING HAD TO BE KEPT TO MINIMUM.

FOR RETROFIT ACTIVITY OF NEW BAYS AN INTERFACE BETWEEN OLD EQUIPMENT AND NEW INSTALLATION WAS REQUIRED, WHICH NECESSITATED COMPLETE SHUTDOWN OF BOTH BUSES AT NJHPS WHICH WOULD MEAN SHUTDOWN OF BOTH POWER HOUSES I.E NJHPS AND RHPS.

THE WHOLE ACTIVITY HAS BEEN PLANNED IN A THREADBARE MANNER AFTER WHICH IT HAS BEEN POSSIBLE TO SCHEDULE THE WHOLE ACTIVITY IN A SHUTDOWN OF **30HRS .**

CONCLUSION


The road to R&M implementation has its own challenges & O&M engineers shall have to take a call to convert the adversities into opportunities.

Modernization is a continuous process and can be part of Renovation Program



THANKS

Project Name	400V GIS at Netherland Substation
Project No.	400V-T1S Model GIS
Revision	400V GIS GAS SINGLE LINE DIAGRAM
Sheet No.	03
Project Date	1988
Project No.	G034A000235



NOTE:
SCOPE 1
PANCHULU-1 (EX ABOLLA PUR-I) CIRCUIT BREAKERS (B-142 MODEL) IS TO BE RETROFIT WITH T-155 CB MODULES
SCOPE 2
FUTURE 1 BAY TO BE EXTENDED FROM THE EXISTING COMMON POINT ASSEMBLY TO SF6 AIR BUSHING TERMINATION

CURRENT TRANSFORMER
According to IEC 61869-2

CT No	Bay Name	Quantity (1 phase)	Alarm Ref	Core Identification	Ith = 50kA, 1s			Idyn = 125kA			Icth = 120%			Application
					Ratio (A)	Accuracy class	Output (VA)	ISF	Min. KPV (VA)	RCT (Ω) at 75deg C	Max. Exciting Current (mA) at Vth			
CT-1	BUS REACTOR	03 NOS	P2	N9	Core # 4	200 / 1	0.5	20	-	-	-	-	-	METERING
			F8	Core # 3	200 / 1	PS	-	-	200	1.5	<30	-	-	LBB, BACKUP IMPEDANCE
			F8	Core # 2	200 / 1	PS	-	-	200	1.5	<30	-	-	REACTOR REF. PROT.N
			P1	F8	Core # 1	200 / 1	PS	-	-	200	1.5	<30	-	-
CT-2	BUS REACTOR	03 NOS	P1	F1	Core # 1	4000 / 1	PS	-	-	-	-	-	-	BUSBAR DIFF. PROT.N (MAIN ZONE)
			P1	F1	Core # 1	2000 / 1	PS	-	-	-	-	-	-	BUSBAR DIFF. PROT.N (CHECK ZONE)
			P1	F1	Core # 1	1000 / 1	PS	-	-	-	-	-	-	BUSBAR DIFF. PROT.N (CHECK ZONE)
			P2	F1	Core # 2	4000 / 1	PS	-	-	-	-	-	-	-

SF6 DENSITY MONITORING DETAILS	CIRCUIT BREAKER	OTHER COMPARTMENTS
Normal : 6.3 Bars	SF6 Refill level : 6.0 Bars	Normal : 6.3 Bars
SF6 Alarm level : 5.7 Bars	SF6 Alarm level : 5.5 Bars	SF6 Refill level : 5.9 Bars
		SF6 Alarm level : 5.5 Bars

Notes:
1. All Gas compartment are equipped with Gas Density switch+Pressure gauge, Pressure Relief Device & Gasfilling Valve.

LEGEND:

SYMBOL	DESCRIPTION
---	PRESENT SCOPE
- - - -	EXISTING SCOPE

GIS COLOR:
INDOOR : GRAY RAL 7038
OUTDOOR : GRAY RAL 9016

MAIN CHARACTERISTICS

RATED CURRENT EXISTING BUSBAR	I _r 4000A
RATED CURRENT EXISTING BUSCOUPLER	I _r 4000A
RATED CURRENT LINE BAYS, REACTOR & ICT BAYS	I _r 2000A
RATED FREQUENCY	F _r 50Hz
SHORT-TIME WITHSTAND CURRENT	I _k 50kA
DURATION	t _k 1s
RATED VOLTAGE	U _r 420 kV rms
POWER FREQUENCY WITHSTAND VOLTAGE	U _d 650 kV rms
LIGHTING IMPULSE WITHSTAND VOLTAGE	U _p 1425 kVp
SWITCHING IMPULSE WITHSTAND VOLTAGE	U _s 1050 kVp
PEAK WITHSTAND CURRENT	I _p 125kA
INTERNAL ARC WITHSTAND TIME	600 ms
MAXIMUM GAS LOSS PER YEAR	≤0.5 %

SF6 AIR BUSHING PARAMETER

Power Frequency Withstand Voltage	U _d 650 kVrms
Lighting Impulse Withstand Voltage	U _p 1425 kVp
Minimum Creepage distance	mm/VV 25 mm/kV
Total Creepage Distance	mm 10500 mm

LEGEND

(---)	INTERNAL DESIGNATION
Qxx	CUSTOMER'S DESIGNATION
— —	CIRCUIT-BREAKER
— —	DISCONNECTOR
— —	BUSBAR
— —	CURRENT TRANSFORMER
— —	VOLTAGE TRANSFORMER
⊖	INSULATED MAINTENANCE EARTHING SWITCH
⊖	INSULATED FAST ACTING EARTHING SWITCH
⊖	SF6 AIR BUSHING
⊖	TELESCOPIC ENCLOSURE
▽	MODIFICATION
□	GAS PARTITIONING
[BAY-01]	ALSTOM BAY NUMBERING
⊖	GAS COMPONENTS : DENSITY SWITCH
⊖	BURSTING DISC
⊖	FILLING VALVE
⊖	PARTIAL DISCHARGE COUPLER

NOTE:
Ref Value for P8 Core to be confirmed