



भारत सरकार/ Government of India
विद्युत मंत्रालय/Ministry of Power
केन्द्रीय विद्युत प्राधिकरण/Central Electricity Authority
ईंधन प्रबन्धन प्रभाग/ Fuel Management Division

सं.: के.वि.प्रा./योजना/एफ.एम./1/40/2019/1207-13

दिनांक: 11.02.2019

OFFICE MEMORANDUM

Subject: Enhancement in the recommended quantity of coal for commissioning activities, start up, trial run and achieving COD etc.- reg.

The commissioning coal for commissioning activities, start up, trial run and achieving COD etc. is recommended by CEA based on the norms prescribed by CEA on 17.02.2014, which is one lakh tonne for unit size upto 500 MW and two lakh tonnes for unit size 500 MW and above. However, various power utilities have requested to enhance the quantity as two lakh tonnes is not sufficient particularly for larger unit size of 660/800 MW.

2. The matter has been examined and the following norms is prescribed for recommending one time release of coal for commissioning activities, start up, trial run and achieving COD etc. :

- | | | |
|------|--------------------------------|-------------------|
| i. | For unit size less than 500 MW | : 1,00,000 Tonnes |
| ii. | For unit size of 500 MW | : 2,50,000 Tonnes |
| iii. | For unit size of 660 MW | : 3,30,000 Tonnes |
| iv. | For unit size of 800 MW | : 4,00,000 Tonnes |

The above quantity of coal shall be adjusted against FSA quantity.

(रमेश कुमार)
22/02/19

मुख्य अभियंता (एफ.एम.)

To:

1. GM (S&M), Coal India Ltd., Coal Bhawan, Premise No-04 MAR, Plot No-AF-III, Action Area-1A, Newtown, Rajarhat, Kolkata-700156
2. Chief General Manager (Corporate Planning & Projects), Singareni Collieries Company Ltd., Kothagudem Collieries, Bhadradri Kothagudem District, (Telangana)-507101

Copy to:

1. Joint Secretary (LA), Ministry of Coal
2. Joint Secretary (Th), Ministry of Power

Copy for information to: Chief Engineer (TETD/TPM-I/TPP&D), CEA