



सत्यमेव जयते

भारत सरकार/Govt. of India
विद्युत मंत्रालय/Ministry of Power
केन्द्रीय विद्युत प्राधिकरण/Central Electricity Authority
मुख्य विद्युत निरीक्षणालय प्रभाग/Chief Electrical Inspectorate Division

विषय: जुलाई, 2018 के दौरान किए गए निरीक्षण की स्थिति और 1 अगस्त, 2018 को लंबित निरीक्षण की स्थिति।

के.वि.प्रा के विनियम 30 और 43 (सुरक्षा और बिजली आपूर्ति से संबंधित उपाय), 2010 के तहत जुलाई, 2018 के दौरान, मुख्य विद्युत निरीक्षणालय प्रभाग और क्षेत्रीय निरीक्षक संगठनों द्वारा किए गए निरीक्षण की आवेदन स्थिति सूची का सारांश कृपया प्राप्त करें। अनुलग्नक-I में 1 अगस्त, 2018 तक की लंबित निरीक्षणों की स्थिति संलग्न हैं और जुलाई, 2018 के दौरान किए गए निरीक्षण के विवरण अनुलग्नक -II में संलग्न हैं। आपकी जानकारी एवं किसी आवश्यक कार्रवाई के लिए प्रस्तुत है।

संलग्नक : यथोपरि ।

गौतम राय

(गौतम राय)
मुख्य अभियंता

सदस्य (विद्युत प्रणाली), के.वि.प्रा
सी.ई.आई/1/14/2018/ 1152

दिनांक: 16.08.2018

91-A2

Annexure-I

Summary of Application status for July, 2018

Status	Regulation	FIO				
		East	North-East	South	West	North
No. of Applications pending as on 01.07.2018	43 & 30	20*	6	28	80	19*
No. of Applications received during July, 2018	43 & 30	15	14	41	105	25
No. of inspections carried out during July, 2018 Details in Annexure-II	43	17	8	34	88	13
	30	7	10	13	30	9
	Total	24	18	47	118	22
No. of applications pending as on 01.08.2018	43	5	1	6	41	5
	30	3	1	15	26	14
	Total	8**	2	21	67	19***

* One application already inspected was mistakenly shown

** Applicants didn't reply for inspection(s) of 2 applications under Reg. 43 and 1 application under Reg. 30

*** 3 incomplete applications were requested back for submitting with valid documents

Inspections carried out during July 2018 - R10 (East)

S.N.	Reg No/41	Installation Name	Utility	Location	State	Application Received Date	Inspection Date	Inspector Name & Designation	Status
1	43	Inspection of DG SET AND PANEL							
2	30	Periodical of HPCL PARADEEP TERMINAL	HPCL	Haldia	West Bengal	03-05-2018	11-07-2017	S Kejriwal, Director	Inspection Report issued on 12-07-2018
3	30	Periodical of Indian Oil Corporation Ltd, Bhubaneswar Terminal	HPCL	Parulip	Odisha	10-05-2018	26-07-2018	S Kejriwal, Director	Inspection Report issued on 30-07-2018
4	30	Periodical of NALCO ALUMINA REFINERY	IOCL	Bhubaneswar	Odisha	05-06-2018	5-07-2018	S Pauldy, Director	Inspection Report issued on 16-07-2018
5	43	Inspection of HPV Reactors	NALCO	Damanjodi	Bihar	09-06-2018	5-07-2018	S Pauldy, Director	Inspection Report issued on 16-07-2018
6	30	Periodical of BARAJINI IRD	HPCL	Baranai	Bihar	14-06-2018	11-07-2018	S Pauldy, Director	Application Closed
7	43	Inspection of Generator, Excitation Transformer, Generator Busbar with oil	HPCL	Nahargar	Jharkhand	20-06-2018	3-07-2018	S Kejriwal, Director	Inspection Report issued on 20-07-2018
8	30	Periodical of LPG Boiling Plant	HPCL	SARAIKELA	Jharkhand	21-06-2018	2-07-2018	S Kejriwal, Director	Inspection Report issued on 03-07-2018
9	43	Inspection of Margreite Plant 6.6 KV Sub Station	PGCIL	Charbasa	Jharkhand	21-06-2018	2-07-2018	S Kejriwal, Director	Inspection Report issued on 12-07-2018
10	43	Inspection of 123 MVAR BUS REACTOR AND ITS ASSOCIATED BAY	PGCIL	SINGBHDUM	Jharkhand	21-06-2018	2-07-2018	S Kejriwal, Director	Inspection Report issued on 03-07-2018
11	43	Inspection of 6.6 KV Crushing and Grinding Sub Station	PGCIL	SINGBHDUM	West Bengal	26-06-2018	2-07-2018	S Pauldy, Director	Approval issued on 18-07-2018
12	43	Inspection of 6.6 KV Water Treatment Plant Substation	TPPL	Siliguri	West Bengal	29-06-2018	11-07-2018	S Kejriwal, Director	Inspection Report issued on 17-07-2018
13	43	Inspection of 2X63 MVAR Line Reactor in Testia III, Kishanganj Transmis	PGCIL	Murshidabad	Jharkhand	29-06-2018	11-07-2018	S Kejriwal, Director	Inspection Report issued on 17-07-2018
14	43	Inspection of 400KV Sagardigh, Farakka-2 Bay and Sagardigh-Berhampur	DVC	Panchet	Jharkhand	29-06-2018	31-07-2018	S Kejriwal, Director	Inspection Report Under preparation
15	43	Inspection of 33 KV Sri Bhagnathi Industries Transmission Line	DVC	Panchet	West Bengal	29-06-2018	31-07-2018	S Kejriwal, Director	Inspection Report Under preparation
16	43	Inspection of Sri Bhagnathi Industries	DVC	Panchet	West Bengal	02-07-2018	30-07-2018	S Pauldy, Director	Approval issued on 30-07-2018
17	43	Inspection of 133KV GIS OUTGOING BAY FOR BS-VI PROJECT HAL	IOCL	Haldia	West Bengal	02-07-2018	27-07-2018	S Kejriwal, Director	Inspection Report Under preparation
18	43	Inspection of Elevator	IOCL	Alipudur	West Bengal	09-07-2018	20-07-2018	S Kejriwal, Director	Approval issued on 30-07-2018
19	30	Periodical of Tai SATS Air Catering Ltd	Thyssen	NSC Bose Airport	West Bengal	10-07-2018	14-07-2018	S Pauldy, Director	Approval issued on 26-07-2018
20	43	Inspection of 400kV BAYS 425 AND 426 INCL UDING 123MVAR BUS R	PGCIL	Durgapur	West Bengal	10-07-2018	14-07-2018	S Pauldy, Director	Inspection Report issued on 20-07-2018
21	43	Inspection of L110 OF 400KV S/C FARAKKA-JEEBART TL AT SAGAR	PGCIL	Sagardigh	West Bengal	11-07-2018	26-07-2018	S Kejriwal, Director	Inspection Report Under preparation
22	43	Inspection of 400 K.V. D/C TWIN HTLS FARAKKA - BEHAMPUR T/L	PGCIL	Berhampur	Odisha	11-07-2018	26-07-2018	S Kejriwal, Director	Inspection Report Under preparation
23	30	Periodical of PARADIP REFINERY, INDIAN OIL CORPORATION LIM	IOCL	Paradip	Odisha	16-07-2018	26-07-2018	S Kejriwal, Director	Inspection Report Under preparation
24	43	Inspection of PP PROJECT PARADIP, INDIAN OIL CORPORATION LI	IOCL	Paradip	Odisha				
Inspections carried out during July 2018 - R10 (North East)									
1	43	400 K.V. DC Transmission line from Silchar to Melurail	PGCIL	Aizawl	Mizoram	04-06-2018	02-07-2018	Lalinsanga, Director	Inspection Report issued on 09-07-2018
2	43	132 K.V. SHIVAR Resour	PGCIL	Aizawl	Mizoram	08-06-2018	02-07-2018	Lalinsanga, Director	Inspection Report issued on 09-07-2018
3	30	Periodical Inspection	PGCIL	Aizawl	Mizoram	30-06-2018	02-07-2018	Lalinsanga, Director	Inspection Report issued on 10-07-2018
4	30	Periodical Inspection	IOCL	Mawlabang	Mizoram	12-06-2018	07-07-2018	Lalinsanga, Director	Inspection Report issued on 10-07-2018
5	30	Periodical Inspection	AIR	Aizawl	Mizoram	03-07-2018	04-07-2018	Lalinsanga, Director	Inspection Report issued on 10-07-2018
6	30	Periodical Inspection	DDK	Aizawl	Mizoram	04-07-2018	05-07-2018	Lalinsanga, Director	Inspection Report issued on 10-07-2018
7	30	Periodical Inspection	IOCL	Cochlar	Assam	05-07-2018	06-07-2018	Lalinsanga, Director	Inspection Report issued on 10-07-2018
8	30	Periodical Inspection	PGCIL	Bokhola	Assam	02-07-2018	06-07-2018	Lalinsanga, Director	Inspection Report issued on 17-07-2018
9	43	3*165 MVA, 400/132 KV ICT and 420 KV Bus Reactor	PGCIL	Balpara	Assam	22-06-2018	13-07-2018	Lalinsanga, Director	Inspection Report issued on 16-07-2018
10	43	132 KV Impregal Impregal 1 TL	PGCIL	Impjal	Manipur	20-06-2018	12-07-2018	Lalinsanga, Director	Inspection Report issued on 16-07-2018
11	30	Periodical Inspection	PGCIL	Manipur	Manipur	11-07-2018	12-07-2018	Lalinsanga, Director	Inspection Report issued on 16-07-2018
12	30	Periodical Inspection	IOCL	Imphal	Manipur	11-07-2018	12-07-2018	Lalinsanga, Director	Inspection Report issued on 16-07-2018
13	30	Periodical Inspection	IOCL	Imphal	Manipur	10-07-2018	12-07-2018	Lalinsanga, Director	Inspection Report issued on 16-07-2018
14	43	36 Kw Roofing Spv P/F and associate Equipment	IOCL	Sekmai	Manipur	12-07-2018	18-07-2018	Lalinsanga, Director	Inspection Report issued on 21-07-2018
15	43	400/220/33 K.v Transformer at Bongjapoon SS	PGCIL	Bongjapoon	Assam	11-07-2018	19-07-2018	Lalinsanga, Director	Inspection Report issued on 31-07-2018
16	43	420 KV, 80 MVAR Bus reactor	OTCC	Pulitana	Tripura	13-07-2018	20-07-2018	Lalinsanga, Director	Inspection Report issued on 21-07-2018
17	30	Periodical Inspection	GAIL	Agartala	Tripura	22-01-2018	20-07-2018	Lalinsanga, Director	Inspection Report issued on 21-07-2018
18	43	750 KVA DG Set	AAI	LOBJ Guwahati	Assam	30-04-2018	23-07-2018	Lalinsanga, Director	Inspection Report issued on 21-07-2018
Inspections carried out during July 2018 - R10 (South)									
1	30	110kV Switchyard equipments etc	The Fertilisers and Chemicals Tyananore Ltd	Cochin	KL	27-04-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
2	30	Existing at Kundankulam Nuclear power project - 1&2	NECL	Kudankulam	TN	28-04-2018	05-07-18	M Rana Krishna DD	Inspection Report Under preparation
3	30	11/0/413V 1000KVA TF, HT Panel, DG Set and other equipments etc	India Gateway Terminal Pvt Ltd	Ernakulam	KL	14-03-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
4	30	Existing electrical installations	IOCL, Indian Boiling Plant Central University	Parippally, Kollam Pettaya	KL	15-03-2018	12-07-18	M Rana Krishna DD	Inspection Report Under preparation
5	36	Li-Ion	Cosial Energen Pvt Ltd	Tuticorin	TN	20-03-2018	04-07-18	M Rana Krishna DD	Inspection Report Under preparation
6	30	Existing electrical installations at HPCL, Ilangam	HPCL	Trangapam, Cochin	KL	28-03-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
7	30	Existing electrical installations at HPCL, Ilangam	HPCL, Kochi refinery	Amthalangal	KL	26-03-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
8	32	180KVA DG Set	BPCL Kochi refinery	Amthalangal	KL	08-06-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
9	32	125KVA DG Set, 2nos	BPCL Kochi refinery	Amthalangal	KL	12-06-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation

S.N.	Rec	Installation Name	Utility	Location	State	Application Received Date	Inspection Date	Inspector Name & Designation	Status
10	43	22kV DP Structure, 22kV 630A LBS Panel etc...	ED	Puducherry	PDY	14-06-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
11	36	Existing installations	CCTL	Chennai	TN	19-06-2018	03-07-18	Mary Francis, DD	Inspection Report Under preparation
12	30	33/11kV Substation	Shikha Container Terminal Pvt Ltd	Vishakhapatnam	AP	20-06-2018	13-07-18	M Rama Krishna, DD	Inspection Report issued on 16-07-2018
13	43	33kV RMU Panel, 33/0 433kV 2500KVA, 2nos. LT Panels etc.	Department of Atomic Energy	Vishakhapatnam	AP	20-06-2018	13-07-18	M Rama Krishna, DD	Inspection Report issued on 16-07-2018
14	32	45KVA DG Set - 1 No	BPCL Kochi refinery	Ambalunai	KL	25-06-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
15	32	63KVA DG Set - 1nos with control panel	BPCL Kochi refinery	Ambalunai	KL	25-06-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
16	32	20KVA & 30KVA DG Sets	BPCL Kochi refinery	Ambalunai	KL	25-06-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
17	43	22kV DP Structure, 22/0 433kV 500KVA T/F, LT Panels and other equipm	RCE	Ambalunai	KL	25-06-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
18	43	765kV Bay extension at Vemagiri GIS	PGCIL	Puducherry	PDY	26-06-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
19	43	MV Panels installations and other equipment etc...	PGCIL	Vemagiri	AP	26-06-2018	13-07-18	M Rama Krishna, DD	Inspection Report issued on 16-07-2018
20	30	Existing electrical installations	BPCL	Belgum	KA	27-06-2018	18-07-18	M Rama Krishna, DD	Inspection Report Under preparation
21	30	Existing electrical installations	OMPL	Mangalore	KA	26-06-2018	19-07-18	M Rama Krishna, DD	Inspection Report Under preparation
22	32	62.5kVA DG STF	ISPRL	Mangalore	KA	26-06-2018	19-07-18	M Rama Krishna, DD	Inspection Report Under preparation
23	43	MV Additions etc.	DEEKAY Exports Ltd	Puducherry	PDY	02-07-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
24	32	3.85MWp Solar pv plant	FTIPL	Puducherry	PDY	02-07-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
25	43	MV Panels installations and other equipment etc...	Pulkat Metals Pvt Ltd	Puducherry	PDY	02-07-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
26	43	MV Additions etc.	Pushpil steels	Puducherry	PDY	02-07-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
27	43&32	MV Loads and 177kW Solar PV Plant	HPCL	Secundrabad	AP	04-07-2018	12-07-18	M Rama Krishna, DD	Inspection Report Under preparation
28	36	LIH - 1nos	ESIC Hospital	Kolarakuravi	KL	06-07-2018	12-07-2018	Mary Francis, DD	Inspection Report Under preparation
29	43	765/400kV GIS S/s	PGCIL	Kadapa	AP	06-07-2018	11-07-18	M Rama Krishna, DD	Inspection Report issued on 16-07-2018
30	43	765kV Bus reactor at Kadapa GIS	PGCIL	Kadapa	AP	06-07-2018	11-07-18	M Rama Krishna, DD	Inspection Report issued on 16-07-2018
31	32	2X2000KVA DG Sets	IISC	Bangalore	KA	09-07-2018	18-07-18	M Rama Krishna, DD	Inspection Report Under preparation
32	43&32	33/0 433kV 2000KVA T/F - 2nos, VCB - 4nos, 1500KVA DG Set - 2nos,	ESIC Hospital	Tirupathi	AP	10-07-2018	11-07-18	M Rama Krishna, DD	Inspection Report issued on 17-07-2018
33	32	2x20KVA DG Sets	BPCL Kochi refinery	Ambalunai	KL	10-07-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
34	32	1x25KVA DG Set	BPCL Kochi refinery	Ambalunai	KL	10-07-2018	11-07-18	Mary Francis, DD	Inspection Report Under preparation
35	43	11/0 433kV 500KVA T/F, 11kV HT Breakers, LT panels etc.	RECL	Rangasundam	AP	10-07-2018	12-07-18	M Rama Krishna, DD	Inspection Report Under preparation
36	43	22kV RMU - 2nos, 22/0 433kV 500KVA T/F and loads etc.	SPL Technologies India Pvt Ltd	Puducherry	PDY	14-07-2018	20-07-18	Mary Francis, DD	Inspection Report issued on 17-07-2018
37	32	600KVA DG Set - 1 No, 200KVA DG Set - 1Nos, 380KVA DG Set - 1No	SPL Technologies India Pvt Ltd	Puducherry	PDY	14-07-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
38	43&32	11kV pole structure, 11kV VCB - 6Nos, 11/0 433kV 500KVA T/F - 3Nos,	HPCL	Vishakhapatnam	AP	15-07-2018	27-07-18	M Rama Krishna, DD	Inspection Report Under preparation
39	43	200KVA DG Set, LT Panel Boards - 3TNos etc.	Platinum Holdings Pvt Ltd	Chennai	TN	17-07-2018	25-07-18	Mary Francis, DD	Inspection Report Under preparation
40	30	33kV HT Panel, 33/0 433kV 2500KVA T/F - 3NOS, 2000KVA DG Set - 3	SPL Cinemas	Puducherry	PDY	18-07-2018	27-07-18	Mary Francis, DD	Inspection Report Under preparation
41	32	1MW Solar powerplant	HPCL	Vishakhapatnam	AP	18-07-2018	27-07-18	M Rama Krishna, DD	Inspection Report Under preparation
42	30	Existing electrical installations	BPCL	Belgum	KA	18-07-2018	18-07-18	M Rama Krishna, DD	Inspection Report issued on 24-07-2018
43	43	11/0 433kV 250KVA T/F, MV panel and other etc.	Shri Aurbindo Society	Puducherry	PDY	19-07-2018	20-07-18	Mary Francis, DD	Inspection Report Under preparation
44	43	22/0 433kV 1600KVA T/F and MV Panel etc.	Creative Propak Ltd	Puducherry	PDY	19-07-2018	20-07-2018	Mary Francis, DD	Inspection Report Under preparation
45	36	LIH - 2nos	Central University	Kasaraguda	KL	19-07-2018	20-07-2018	M Rama Krishna, DD	Inspection Report issued on 24-07-2018
46	30	Existing electrical installations	HPCL White oil	Vishakhapatnam	AP	25-07-2018	27-07-18	M Rama Krishna, DD	Inspection Report issued on 24-07-2018
47									

S.N.	Rec	Installation Name	Utility	Location	State	Application Received Date	Inspection Date	Inspector Name & Designation	Status
Inspections carried out during July 2018 - RIQ (West)									
1	30	BHARAT PETROLEUM CORP LTD GURI INTERMEDIATE PUMPING STATION	BHARAT PETROLEUM CORP LTD	Dhule	MP	5-Feb-18	13-Jul-18	R K Meena, DD	Approval issued on 24-07-2018
2	30	BHARAT PETROLEUM CORP LTD SANGHYI INTERMEDIATE PUMPING STATION	BHARAT PETROLEUM CORP LTD	Dhule	MH	5-Feb-18	13-Jul-18	R K Meena, DD	Approval issued on 24-07-2018
3	30	HPCL LPG Bottling Plant	HPCL Corporation Ltd	Goa	MH	3-Mar-18	27-Jul-18	Sachin K Bhis, DD	Inspection Report Under preparation
4	30	BEL OPTRONIC DEVICES LTD	BEL OPTRONIC DEVICES LTD	PUNE	MH	16-04-2018	2-Jul-18	Goutam Roy, CEI	Approval issued on 03-07-2018
5	30	HPCL VADODARA IRD	HPCL	VADODARA	GJ	04-05-2018	3-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 04-07-2018
6	30	Electrical Installations of 2 substations and associated plants of DFCC-AU	Opal India Corporation Limited	Bhanach	GJ	11-05-2018	10-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 11-07-2018
7	30	BHARAT PETROLEUM CORPORATION LIMITED	CORPORATION LIMITED	Kutch	GJ	02-06-2018	6-Jul-18	Santosh Kumar, DD	Inspection Report issued on 16-07-2018
8	30	Indian Oil Corporation Ltd (MID), Gandhar, LPG Bottling Plant	Indian Oil Corporation Ltd	Bhanach	GJ	12-06-2018	10-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 11-07-2018
9	30	132/6.9 KV SUBSTATION NEPA LIMITED NEPANAGAR	Nepalid Limited	NEPANAGAR	MP	13-06-2018	12-Jul-18	R K Meena, DD	Approval issued on 20-07-2018
10	30	INDIAN OIL CORPORATION LIMITED WRPL, MUNDRA	Indian Oil Corporation Ltd	Kutch	GJ	14-06-2018	6-Jul-18	Santosh Kumar, DD	Inspection Report issued on 16-07-2018
11	30	IOCL Colony, Gandhidham	IOCL	Kutch	GJ	14-06-2018	6-Jul-18	Santosh Kumar, DD	Inspection Report issued on 16-07-2018
12	30	System and CHP Electrical System at 6x660 MW Sason UMPP, Waidhan	C/O Sason Power Ltd	Waidhan	MP	23-06-2018	13-Jul-18	IK Mehta, DD	Inspection Report issued on 23-07-2018
13	30	Hindustan Petroleum Corporation Limited	Hindustan Petroleum Corporation Limited	Mumbai	MH	25-06-2018	5-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 06-07-2018
14	30	LPG Recovery Plant Compressor Station and HRSG Vaghodia	GAIL India Ltd.	Vaghodia	GJ	26-06-2018	3-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 04-07-2018
15	30	HPCL Vashi Terminal	Corporation Limited	Mumbai	MH	29-06-2018	5-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 06-07-2018
16	30	BPCL WAI LPG PLANT, SATARA	Ltd	SATARA	MH	02-07-2018	13-Jul-18	Goutam Roy, CEI	Inspection Report Under preparation
17	30	NHDC Ltd	NHDC Ltd	Omkareshwar	MP	06-07-2018	12-Jul-18	R K Meena, DD	Inspection Report Under preparation
18	30	NHDC Ltd	NHDC Ltd	Omkareshwar	MP	06-07-2018	12-Jul-18	R K Meena, DD	Inspection Report Under preparation
19	30	Periodical Inspection of all HT and LT Equipment	Ltd	Silvassa	DNH	15-07-2018	16-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 23-07-2018
20	30	INDIAN OIL CORPORATION LTD.	LTD.	Goa	MH	25-07-2018	27-Jul-18	Sachin K Bhis, DD	Inspection Report issued on 31-07-2018
21	30	HPCL KANDLA TERMINAL	CORPORATION LTD	Kandla	GJ	30-07-2018	30-Jul-18	Sachin K Bhis, DD	Inspection Report Under preparation
22	30	SOLAPUR LPG BOTTLING PLANT	PLANT	Solapur	MH	11-Oct-17			Auto closed
23	30	Periodical	GALLIANDA LIMITED	Ujain	MP	17-Nov-17			Auto closed
24	30	HINDUSTAN PETROLEUM CORP LTD.	Hindustan Petroleum Corp Ltd	Manila	MP	2-Dec-17			Auto closed
25	30	INDIAN OIL CORPORATION LIMITED	CORPORATION LIMITED	Goa	MH	3-Jan-18			Auto closed
26	30	Periodical Inspection	Plant, Pillanpur	Pillanpur	MP	29-Jan-18			Auto closed
27	30	765/400KV POOLING STATION JABALPUR	PGCIL	Jabalpur	MP	31-Mar-17			Rejected
28	30	400kV Solapur - Karad LILCO	Adani Group	Solapur	MH	05-06-2018			Rejected
29	30	400kV Solapur - Kolhapur	Adani Group	Solapur	MH	05-06-2018			Rejected
30	30	JHANSOR GANDHAR GAS POWER PROJECT	NTPC Limited	Bhanach	GJ	11-06-2018			Rejected
31	43	Hindustan Petroleum Corporation - MIDNDRA	Powertrac Solar Projects Ltd	Mundra	GJ	11-07-2018			Rejected
32	43	DG SETS	BHABHA ATOMIC RESEARCH CENTRE	TARAPUR	MH	18-07-2018			Rejected
33	43	Sevcon II Terminal	Indian Oil Corporation Limited	Sevcon, Mumbai	MH	18-07-2018			Rejected
34	43	AND UNDERGROUND FEEDER 1.85 SQMM X 3 CORE HT CABLE	Community Health Centre	SILVASSA	DNH	02-07-2018	17-Jul-18	Sachin K Bhis, DD	Approval issued on 17-07-2018
35	43	SS 28 Extension at IOCL, Gujarat Refinery	Indian Oil Corporation Limited	Vadodara	GJ	02-07-2018	3-Jul-18	Sachin K Bhis, DD	Approval issued on 23-07-2018
36	43	400 KVA TRANSFORMER X 2 NOS WITH H.T. 400 AMP OF V.C.B. PANEL X 3 NOS	SILVASSA MUNICIPAL COUNCIL	SILVASSA	DNH	02-07-2018	16-Jul-18	Sachin K Bhis, DD	Approval issued on 19-07-2018
37	43	REWA, Madhya Pradesh, INDIA	Private Limite	REWA	MP	02-07-2018	12-Jul-18	IK Mehta, DD	Inspection Report Under preparation
38	43	Hindustan Petroleum Corporation Limited	Hindustan Petroleum Corporation Limited	Mumbai	MH	02-07-2018	5-Jul-18	Sachin K Bhis, DD	Approval issued on 26-07-2018

S.N.	Ref	Installation Name	Utility	Location	State	Application Received Date	Inspection Date	Inspector Name & Designation	Status
39	43	KOVALL INSTALLATION 11KV OVERHEAD LINE FEEDER, TWO POLE DP STRUCTURE, CPT UNIT, VCB PANEL	BHARAT PETROLEUM CORP LTD DODHIA SYNTHETICS LIMITED	BARODA	GJ	02-07-2018	3-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 04-07-2018
40	43	400KV AND CONSTRUCTION OF 220KV NEW SWITCHYARD INCLUDING 2NOS OF 500MVA, 400/220/33 KV, ICT, 400KV BAYS NO. 403, 406, 220KV BAYS NO 201, 202, 203, 204, 205, 206, 207, 208, 209, 211	POWERGRID CORPORATION OF INDIA LTD	SILVASSA	DNH	03-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 18-07-2018
41	43	VFD and Associated equipments for CEP of Unit 50	Coastal Gujarat Power Limited, M/S LEEBO METALS PVT LTD	INDORE	MP	03-07-2018	12-Jul-18	R K Meena, DD	Inspection Report Under preparation
42	43	11 KV SUB STATION PANEL WITH 1250 KVA TRANSFORMER	JOLLY CONTAINERS Rewa Ultra Mega Solar Limited	DAMAN	DMN	05-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 23-07-2018
43	43	11 KV CPT UNIT INSTALLATION POLE MOUNTED OUTDOOR	AYKA PIPES & FITTINGS PRIVATE LIMITED	KACHIGAM	DMN	03-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 25-07-2018
44	43	11 KV CPT UNIT INSTALLATION POLE MOUNTED OUTDOOR	AYKA PIPES & FITTINGS PRIVATE LIMITED	Bhopal	MP	05-07-2018	12-Jul-18	IK Mehra, DD	Inspection Report Under preparation
45	43	11 KV CPT UNIT INSTALLATION POLE MOUNTED OUTDOOR	PRINCE SWR SYSTEMS PVT LTD	SILVASSA	DNH	06-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 23-07-2018
46	43	11 KV CPT UNIT INSTALLATION POLE MOUNTED OUTDOOR	PRINCE SWR SYSTEMS PVT LTD	SILVASSA	DNH	06-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 23-07-2018
47	43	11 KV CPT UNIT INSTALLATION POLE MOUNTED OUTDOOR	PRINCE SWR SYSTEMS PVT LTD	SILVASSA	DNH	06-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 23-07-2018
48	43	11 KV CPT UNIT INSTALLATION POLE MOUNTED OUTDOOR	PRINCE SWR SYSTEMS PVT LTD	SILVASSA	DNH	06-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 23-07-2018
49	43	11 KV CPT UNIT INSTALLATION POLE MOUNTED OUTDOOR	PRINCE SWR SYSTEMS PVT LTD	SILVASSA	DNH	06-07-2018	16-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 17-07-2018
50	43	Unit 2 220/33KV Pooling S/s at Ramnagar Pahad	Rewa Ultra Mega Solar Limited	Bhopal	MP	07-07-2018	12-Jul-18	IK Mehra, DD	Inspection Report Under preparation
51	43	STATION TRANSFORMER, BUS REACTOR - NTPC 2X660MW KHARGONE STPP	NTPC LIMITED Anandaben B. Prabhakar	KHARGONE	MP	08-07-2018	13-Jul-18	R K Meena, DD	Inspection Report Under preparation
52	43	125KVA DG Set with LV Installation	M.S.E.D.C.L. SOLARIS SPECIALITY CHEMICALS PVT. LTD.	Daman	DMN	11-07-2018	16-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 20-07-2018
53	43	thru. Ruresh Keshavrao Chichghare at Yr Chimur shri Chandrasakhar D Bisen at Kolhar Rih, lah chimur	M.S.E.D.C.L. SOLARIS SPECIALITY CHEMICALS PVT. LTD.	NAGPUR	MH	11-07-2018			Rejected
54	43	Replacement of 800 KVA Transformer	M.S.E.D.C.L. SOLARIS SPECIALITY CHEMICALS PVT. LTD.	NAGPUR	MH	11-07-2018			Rejected
55	43	Replacement of 800 KVA Transformer	M.S.E.D.C.L. SOLARIS SPECIALITY CHEMICALS PVT. LTD.	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 20-07-2018
56	43	11/0 433KV, 315KVA Transformer centre at opp. Yogi Hosoi at Silvassa 11/0 433KV, 315KVA Transformer centre at Silpam Apartment, Amli, Silvassa	DNHDPCL	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 24-07-2018
57	43	Replacement of 111 KV/433 V, 1600 KVA Transformer	DNHDPCL	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 24-07-2018
58	43	Replacement of 111 KV/433 V, 1600 KVA Transformer	DNHDPCL	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 24-07-2018
59	43	11/0 433KV, 315KVA Transformer centre at Ahmad Raja Society, Bairvaidia, Silvassa	DNHDPCL	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 25-07-2018
60	43	11/0 433KV, 315KVA Transformer centre at Bhutalalia, Malivavanshifalita road, Silvassa	DNHDPCL	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 24-07-2018
61	43	320 KVA DG SET	M/S LEEBO METALS PVT LTD	Daman	DMN	13-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 24-07-2018
62	43	320 KVA DG SET	M/S LEEBO METALS PVT LTD	Daman	DMN	13-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
63	43	11/0 433KV, 315KVA Transformer centre at Near Malhar Ba., Bairvaidia Road, Silvassa	DNHDPCL	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
64	43	11/0 433KV, 315KVA Transformer centre at Gort Housing Society, near Harud Apartment, Silvassa	DNHDPCL	Silvassa	DNH	13-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 24-07-2018
65	43	600 KVA DG SET	M/S ALTHEA PHARMA PVT LTD	Daman	DMN	13-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 24-07-2018
66	43	1500 KVA DG SET	M/S TEMPLE PACKAGING PVT LTD	Daman	DMN	13-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
67	43	1010 KVA DG SET	M/S K KALPANA INDUSTRIES (INDIA) LTD	Daman	DMN	13-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
68	43	11/0 433KV, 500KVA Transformer centre at M/s SP/ Developers, Dadra	DNHDPCL	Silvassa	DNH	14-07-2018	17-Jul-18	Sachin K Bhise, DD	Approval issued on 19-07-2018
69	43	20 KVA DG SET	PREMA HOSPITAL Rewa Ultra Mega Solar Limited	Silvassa	DNH	15-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 19-07-2018
70	43-B	220 KV Line 1 and Line 2 Ramnagar Pahad, Rewa	PREMA HOSPITAL Rewa Ultra Mega Solar Limited	Bhopal	MP	10-07-2018	12-Jul-18	IK Mehra, DD	Approval issued on 19-07-2018

S.N.	Ref	Installation Name	Utility	Location	State	Application Received Date	Inspection Date	Inspector Name & Designation	Status
71	43	200KW Grid Interactive Solar Power Plant at Al Ahial, Silvassa							
72	43	1251VA DG Set with LV Installation	DNHDPCL	Silvassa	DNH	16-07-2018	17-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 25-07-2018
73	43	1251VA DG Set with LV Installation	M/s Hotel Saurajya Imperial	DAMAN	DMN	16-07-2018	16-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 01-08-2018
74	43	1251VA DG Set with LV Installation	M/s. Schott Kaisha Pvt Ltd	DAMAN	DMN	16-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval Report issued on 20-07-2018
75	43	1251VA DG Set with LV Installation	Shri Kairus Sharav Dadacharji	DAMAN	DMN	16-07-2018	16-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 01-08-2018
76	43	50KVA DG Set with LV Installation	Panel Jayeshbhai Premabhai	DAMAN	DMN	16-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval Report issued on 20-07-2018
77	43	140KVA DG Set with LV Installation	Sri. Premalaben L. Tandel	DAMAN	DMN	16-07-2018	16-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 31-07-2018
78	43	500KVA D B Transformer, LBS, VCB Panel along with HV, MV, Installation	M/s. Schott Kaisha Pvt Ltd	DAMAN	DMN	16-07-2018	16-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 31-07-2018
79	43	M/s. Dalipkaji	M/s. Schott Kaisha Pvt Ltd	DAMAN	DMN	17-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
80	43	230 KVA DG SET	M/s. Dalipkaji	Kharvel	DNH	17-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 31-07-2018
81	43	500 KVA DG SET	M/S AGS TRANSACT TECHNOLOGIES LTD	DAMAN	DMN	17-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
82	43	160 KVA DG SET	M/S MUDITBASE INDIA LTD	DAMAN	DMN	17-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
83	43-B	11 KV CABLE UNDERGROUND FROM OLD PLANT TO NEW PLANT	M/S COROB INDIA PVT LTD	DAMAN	DMN	17-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 01-08-2018
84	43	Service II Terminal	PRINCE SWR SYSTEMS PVT LTD	Silvassa	DNH	17-07-2018	16-Jul-18	Sachin K Bhise, DD	Approval issued on 17-07-2018
85	43	18 Numbers of 2000 KW Wind Turbine Generator and 33 KV USS	Indian Oil Corporation Limited	Sworce	MH	19-07-2018	23-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 23-07-2018
86	43	765 /400 K.V. VINDHYACHAL POOLING STATION	Osro Kutch Wind Private Limited	Bachau	GJ	21-07-2018	22-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 31-07-2018
87	43	Bay Extension - 400/220KV Mapusa Substation - 02 nos 220K V Line bays for Mapusa-Terna 220K V Line	POWER GRID CORPORATION OF INDIA LIMITED	SINGRAULI	MP	21-07-2018	30-Jul-18	R K Meena, DD	Inspection Report Under preparation
88	43	380 KVA DG set with AMF panel at ARPF complex for RR CAT, DAE, Indore	Powergrid Corporation of India Ltd	Goa	MH	21-07-2018	27-Jul-18	Sachin K Bhise, DD	Inspection Report Under preparation
89	43-B	33KV SC Overhead Transmission line Feeders	Raja Ramanna Centre for Advanced Technology	Indore	MP	26-07-2018	27-Jul-18	Self certification	Self certification
90	43	Hindustan Petroleum Corporation - Kandla	Osro Kutch Wind Private Limited	Bachau	GJ	25-07-2018	22-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 31-07-2018
91	43	Hindustan Petroleum Corporation - MUNDRA	Hindustan Petroleum Corporation Ltd	Kandla	GJ	27-07-2018	23-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 31-07-2018
92	43-B	Mahan Signal	Essar Power Transmission Company Ltd	Mundra	GJ	28-07-2018	23-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 31-07-2018
93	43	Transformers, 11 Kv line And Motors Substation No. 28 Extension in IOCL, Gujarat Refinery	Indian Oil Corporation Limited	SINGRAULI	MP	27-07-2018	31-Jul-18	Ashok Thakur, Dir	Inspection Report Under preparation
94	43	11 KV U/G Express Feeder	NTPC	Vandhachal	GJ	10-Jun-17			Rejected
95	43	Replacement of 1500 KVA Transformer	Indian Oil Corporation Limited	Vadodara	DNH	07-06-2018			Rejected
96	43	220K V metering CTs and PTs at HOCL Kasa and	Audax Protective Fabrics Pvt. Ltd	SILVASSA	DNH	12-06-2018			Rejected
97	43	Hindustan Petroleum Corporation - Haxira	TSUBAKI HOOVER INDIA PVT LTD	Relagd	MH	01-06-2018			Rejected
98	43	Unit 3 220/33kV Feeding 5% at Barasahi Doshi	Hindustan Organic Chemicals Ltd	Relagd	GJ	13-06-2018			Rejected
99	43	Hindustan Petroleum Corporation Limited - Palapur	Powertrac Solar Projects Ltd	Surandranagar	MP	21-06-2018			Rejected
100	43	220 K V Line - 2 Barasahi Doshi	Powertrac Solar Projects Ltd	Surandranagar	GJ	29-06-2018			Rejected
101	43	11 K V Transformer and VCB	Rewa Ultra Mega Solar Limited	Bhopal	MP	29-06-2018			Rejected
102	43	ESIG HOSPITAL PROJECT	Bharat Petroleum Corporation Ltd	SATARA	MH	06-05-2018	13-Jul-18	Goutam Roy, CEI	Inspection Report Under preparation
103	43	DG Set-Temporary	NATIONAL BUILDING CONSTRUCTION CORPORATION LTD	Mumbai	MH	23-05-2018	23-Jul-18	Sachin K Bhise, DD	Inspection Report issued on 26-07-2018
104	43	300 KWp Solar Project	ONGC Petro addition Ltd	Bharuch	GJ	21-05-2018	10-Jul-18	Sachin K Bhise, DD	Approval issued on 20-07-2018
105	43	300 KWp Solar Project	Airport Authority Of India Pune	Pune	MH	06-06-2018	1-Jul-18	Goutam Roy, CEI	Inspection Report Under preparation

S.N.	Reg	Installation Name	Utility	Location	State	Application Received Date	Inspection Date	Inspector Name & Designation	Status
43	30/43	2x500KVA, 11/0.433KV, Distribution Transformer at M/s. Delta Projects Pvt. Ltd., Silvassa	DNHDDCL POWERGRID CORPORATION OF INDIA LIMITED	SILVASSA	DNH	12-06-2018	17-Jul-18	Sachin K. Bhise, DD	Approval issued on 19-07-2018
106	43	400 KV 123 MVAR Bus Reactor and 03 nos 400 KV GIS Bays	POWERGRID CORPORATION OF INDIA LIMITED	Valodara	GJ	14-06-2018	3-Jul-18	Sachin K. Bhise, DD	Approval issued on 23-07-2018
107	43	Hindustan Petroleum Corporation - Kandla	Powertrac Solar Projects Ltd	Surendranagar	GJ	15-06-2018	6-Jul-18	Santosh Kumar, DD	Approval Report issued on 12-07-2018
108	43	500KVA x 2 Nos. DG Set with LV Installations	M/s. Kalyan Resorts	Daman	DMN	20-06-2018	16-Jul-18	Sachin K. Bhise, DD	Inspection Report issued on 31-07-2018
109	43	17 Numbers of 2000 KW Wind Turbine Generator and 33 KV USS	Ostro Kutch Wind Private Limited	Daman	GJ	20-06-2018	5-Jul-18	Santosh Kumar, DD	Approval issued on 23-07-2018
110	43	63KVA DG Set with LV Installation	M/s. Hotel Ocean Panorama	Daman	DMN	21-06-2018	16-Jul-18	Sachin K. Bhise, DD	Approval issued on 01-08-2018
111	43	400KVA DG Set with LV Installation	M/s. Hotel Sea View Pvt. Ltd. Ostro Kutch Wind Private Limited	Daman	DMN	21-06-2018	16-Jul-18	Sachin K. Bhise, DD	Approval issued on 01-08-2018
112	43	33KV SC/D/C/M/C Overhead Transmission line Feeders	HINDUSTAN PETROLEUM LTD	Bachau	GJ	21-06-2018	5-Jul-18	Santosh Kumar, DD	Inspection Report issued on 11-07-2018
113	43	DG SET AND PANEL	Katwala Power Solutions Coastal Gujarat Power Limited.	SURAT	GJ	25-06-2018	6-Jul-18	Shyam Kejriwal	Inspection Report issued on 09-07-2018
114	43	190 KW Rooftop Solar Power Plant	Coastal Gujarat Power Limited.	Valodara	GJ	28-06-2018	3-Jul-18	Sachin K. Bhise, DD	Inspection Report issued on 04-07-2018
115	43	VTD and Associated equipments for CEP of Unit 10	M/s. School Kaisha Pvt. Ltd. Shri Ishwarbhai Dnyanhai Patel	Kutch	GJ	30-06-2018	6-Jul-18	Santosh Kumar, DD	Inspection Report Under preparation
116	43	250KVA DG Set with LV Installation	M/s. School Kaisha Pvt. Ltd. Shri Ishwarbhai Dnyanhai Patel	Daman	DMN	30-06-2018	16-Jul-18	Sachin K. Bhise, DD	Approval issued on 01-08-2018
117	43	35KVA DG Set with LV Installation		Daman	DMN	30-06-2018	16-Jul-18	Sachin K. Bhise, DD	Approval issued on 01-08-2018
118	43								
Inspections carried out during July 2018 - RIQI (North)									
1	43	BPCL Kera TOP	BPCL	Kola	Rajasthan	23.05.2018	19.07.2018	Sunil Kumar Jain, DD	Inspection Report issued on 28.07.2018
2	43	1600 KVA transformer of 33/433 KV	SSB	Lakhimpur Khetri	U.P.	20.06.2018	07.07.2018	Prakash Khichi, Dir.	Approval issued on 23.07.2018
3	43	WTC IARI, Faza, New Delhi	IARI	PUSA	New Delhi	23.06.2018	19.07.2018	I K Mehra, DD	Inspection Report issued on 27.07.2018
4	43	1000 KVA Transformer - 2 No.	All India Radio	Kingswar, Camp	New Delhi	28.06.2018	03.07.2018	Sunil Kumar Jain, DD	Inspection Report issued on 16.07.2018
5	43	1600 KVA 11KV Compact Substation at Airside of IGI Airport	DIAL	IGI Airport	New Delhi	29.06.2018	02.07.2018	Prakash Khichi, Dir.	Approval issued on 05.07.2018
6	43	33 KV Electrical Substation at Delhi Cargo	Delhi Cargo Service Centre	AIR Cargo COMPLEX	New Delhi	30.06.2018	02.07.2018	Prakash Khichi, Dir.	Approval issued on 11.07.2018
7	43	132 KV bays at 132 KV S/S Shekoi	UPPTCL	Bijnor	U.P.	06.07.2018	11.07.2018	Sunil Kumar Jain, DD	Approval issued on 23.07.2018
8	43	58.5 K.W. Rooftop Solar Plant	AIIMS	Sadiq Nagar	New Delhi	09.07.2018	17.07.2018	Prakash Khichi, Dir.	Approval Report issued on 20.07.2018
9	43	250 KVA DG	HPCL	Devaria	U.P.	12.07.2018	27.07.2018	Santosh Kumar, DD	Inspection Report Under preparation
10	43	BUS REACTOR -125 MVAR	Meja Uja Nigam Private Limited	Allahabad	U.P.	17.07.2018	31.07.2018	I K Mehra, DD	Inspection Report Under preparation
11	43	DG SET AND PANEL	HPCL	Rewari	Haryana	30.07.2018	30.07.2018	Sunil Kumar Jain, DD	Inspection Report Under preparation
12	43	IPD Depra	HPCL	Rewari	Haryana	30.07.2018	30.07.2018	Sunil Kumar Jain, DD	Inspection Report Under preparation
13	43	132 KV Dhangra-Kalagani LIUO line	UPPTCL	Bijnor	U.P.	06.07.2018	11.07.2018	Sunil Kumar Jain, DD	Approval issued on 21.07.2018
14	39	FOU, Depra	BPCL	Kanpur	U.P.	23.05.2018	04.07.2018	Sunil Kumar Jain, DD	Inspection Report issued on 09.07.2018
15	39	Area Gas Brown Station MTPC Ams	GAIL	Amra	Rajasthan	09.06.2018	20.07.2018	Sunil Kumar Jain, DD	Approval issued on 27.07.2018
16	39	Terminal Station	BPCL	Rewari	Haryana	19.06.2018	30.07.2018	Sunil Kumar Jain, DD	Inspection Report Under preparation
17	39	Airside SF6/E BLOCK/BOAC and 11KV CSS Substation at IGI Airport	DIAL	IGI Airport	Delhi	21.06.2018	02.07.2018	Prakash Khichi, Dir.	Inspection Report issued on 05.07.2018
18	39	Kanpur Terminal	HPCL	Kanpur	U.P.	21.06.2018	04.07.2018	Sunil Kumar Jain, DD	Inspection Report issued on 09.07.2018
19	39	DG Set	Candle Hoods Pvt. Ltd	IGI Airport	New Delhi	01.07.2018	13.07.2018	Prakash Khichi, Dir.	Inspection Report issued on 16.07.2018
20	39	Workshop-1, Asset 11	Aggen Buildtech Ltd	Aerocity	New Delhi	13.07.2018	31.07.2018	Prakash Khichi, Dir.	Inspection Report Under preparation
21	39	Workshop 2 workshop	Ok Infrastructure Developers Ltd.	Aerocity	New Delhi	13.07.2018	31.07.2018	Prakash Khichi, Dir.	Inspection Report Under preparation
22	39	Oil Depra	HPCL	Rewari	Haryana	19.07.2018	30.07.2018	Sunil Kumar Jain, DD	Inspection Report Under preparation