



सत्यमेव जयते

भारत सरकार Government of India
विद्युत मंत्रालय Ministry of Power

क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation



ISO 9001:2008

केंद्रीय विद्युत प्राधिकरण

Central Electricity Authority

एन ई आर पी सी कॉम्प्लेक्स, डोंग पारमाओ, लापालांग, शिलांग-७६३००६, मेघालय
NERPC Complex, Dong Parmaw, Lapalang, Shillong-793006, Meghalaya

Phone No: 0364-2534082 / Tele-Fax No.: 0364-2534024

सं./No. RIO/NER/DVC/RTPS/894

दिनांक/Date : 13.09.2017

To
To,
The Deputy Chief Engineer (Elect.),
RTPS, Raghunathpur, DVC,
Distt – Purulia - 723101
West Bengal.

Subject: Under Regulations 43 & 30 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended) – **approval for charging 11/0.415 kV, 1000 kVA Transformer - reg.**

Ref: (1) DVC online application No. A/2017/02462 dated 04/08/2017
(2) RIO/NER/RTPS/DVC/523 dated 22.08.2017
(3) DVC letter no. RT/ST/Elec./729 dated 09.09.2017 (Self Certification Form-II)

Sir,

With reference to the above letters and taking into account the self certification made by your organization vide duly filled up Form – II of Schedule-IV of CEA Regulations, 2010 (as amended), approval is hereby granted to charge the subject cited transformer.

This approval is strictly subjected to your continued full compliance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended) in every respect.

The periodical inspection of the above mentioned installations shall be due after 2 years from the date of issue of this approval. Further, the statutory inspection of all the other electrical equipments installed at RTPS, DVC will also have to be renewed every 2 years.

THIS APPROVAL IS VALID UPTO 12.09.2019

Iqbal
13/09/17

(Farooque Iqbal)
Deputy Director

for Chief Electrical Inspector
to Govt. of India

Copy to : Chief Engineer, EI Division, CEA, New Delhi (for information please)