



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Ground Floor, WRPC Building, F-3, MIDC Area
Marol, Andheri (East), Mumbai 400 093



ISO: 9001:2008

Telefax:022-28211003

riowestcea@gmail.com

No. WRIO/ RRCAT/Indore/SC/2017/ 548-49

Dated: 01/11/2017

Acceptance of Self-Certification

[Under Regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date)]

Electrical Installation: -

System : 750KVA, 11/0.433KV Package substation, E-Type Quarters at RRCAT, Indore

Electrical Apparatus:

1. 750KVA, 11/0.433KV Package substation [Make: C&S Electric Ltd; S.No: PSS 194; Qty: 1 No]
2. 3CX185Sqmm, 11KV Power cable [Make: KEC; Length: 160mtrs]

Location:- Electrical Engineering Section, Construction & Services Division, Raja Ramanna Centre for Advanced Technology (RRCAT), PO-CAT, Indore - 452013.

- Ref:** 1. Your online application No. A/2016/01181 Dated 08.10.2016
2. Our email dated 05/10/2016
3. Your letter No: RRCAT/CSD/E/2016/852 Dated 01.11.2016

With reference to the above, M/s RRCAT, Indore has submitted Self-Certification Report in Form-III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended). The general condition of the installations submitted by M/s RRCAT, Indore in FORM III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) has been examined and it is found to be in order.

Therefore, the Self - Certification Report submitted by M/s RRCAT, Indore is hereby accepted for energisation of the electrical apparatus as per details given above under regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date).

The consistent compliance of relevant provisions of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) shall be ensured for safety in operation and maintenance of the above electrical installation

(Sachin K. Bhise)
Deputy Director
For Chief Electrical Inspector
to the Govt. of India

To: Head, Electrical Engineering Section, Construction & Services Division, Raja Ramanna Centre for Advanced Technology (RRCAT), PO-CAT, Indore - 452013.

Copy: Chief Engineer (EI), CEA, 3rd Floor, NRPC Building, Katwaria Sarai, New Delhi.