



Government of India  
Central Electricity Authority  
Regional Inspectorial Organisation  
Ground Floor, WRPC Building, F-3, MIDC Area  
Marol, Andheri (East), Mumbai 400 093



ISO: 9001:2008

Telefax:022-2821 1003

riowestcea@gmail.com

No. WRIO/JCESD/PWD/Jabalpur/SC/2017/546-47

Dated: 01/11/2017

### Acceptance of Self-Certification

[Under Regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date)]

#### Electrical Installation: -

<b>System :</b> 100KVA S/s, Compound light and service connection
<b>Electrical Apparatus:</b> 100KVA, 11/0.433KV Transformer [Make: Alaska S.No:TTL/PP/104466, Qty: 01 no.]
<b>Location:-</b> Office cum Residential Complex for SIB Balaghat.
<b>Ref:</b> 1. Your online application No. A/2016/01230 Dated 27.08.2016 2. Your letter No: 72(7)/JCESD/2016-17/157 Dated 09.09.2016

With reference to the above, M/s CPWD, Jabalpur has submitted Self-Certification Report in Form-III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended). The general condition of the installations submitted by M/s CPWD, Jabalpur in FORM III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) has been examined and it is found to be in order.

Therefore, the Self - Certification Report submitted by M/s CPWD, Jabalpur is hereby accepted for energisation of the electrical apparatus as per details given above under regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date).

The consistent compliance of relevant provisions of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) shall be ensured for safety in operation and maintenance of the above electrical installation

(Sachin K. Bhise)  
Deputy Director  
For Chief Electrical Inspector  
to the Govt. of India

To: Assistant Engg (E), Jabalpur Central Electrical Sub Division(JCESD), CPWD, GSI Colony, Sanjivni Nagar, Garha, Jabalpur -482 003.

Copy to: Chief Engineer (EI), CEA, 3<sup>rd</sup> Floor, NRPC Building, Katwaria Sarai, New Delhi.