



Telefax:022-28211003

riowestcea@gmail.com

No. WRIO/ RRCAT/Indore/SC/2017/550-51

Dated: 01/11/2017

Acceptance of Self-Certification

[Under Regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date)]

Electrical Installation: -

System : 3CX240Sqmm, A2XFY, 11KV(E) cable from 132KV MRS to MFL Substation, RRCAT

Electrical Apparatus:

3CX240Sqmm, A2XFY, 11KV(E) cable from 132KV MRS to MFL Substation, RRCAT

Location:- Electrical Engineering Section, Construction & Services Division, Raja Ramanna Centre for Advanced Technology (RRCAT), PO-CAT, Indore - 452013.

Ref: 1. Your online application No. A/2017/01721 Dated 25.01.2017

2. Our email dated 06/02/2017

3. Your letter No: RRCAT/E/2017/179 Dated 13.02.2017

With reference to the above, M/s RRCAT, Indore has submitted Self-Certification Report in Form-III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended). The general condition of the installations submitted by M/s RRCAT, Indore in FORM III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) has been examined and it is found to be in order.

Therefore, the Self - Certification Report submitted by M/s RRCAT, Indore is hereby accepted for energisation of the electrical apparatus as per details given above under regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date).

The consistent compliance of relevant provisions of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) shall be ensured for safety in operation and maintenance of the above electrical installation

(Sachin K. Bhise)

Deputy Director

For Chief Electrical Inspector
to the Govt. of India

To: Head, Electrical Engineering Section, Construction & Services Division, Raja Ramanna Centre for Advanced Technology (RRCAT), PO-CAT, Indore - 452013.

Copy: Chief Engineer (EI), CEA, 3rd Floor, NRPC Building, Katwaria Sarai, New Delhi.