

भारत सरकार
Govt. of India
विद्युत मन्त्रालय, केन्द्रीय विद्युत प्राधिकरण
Ministry of Power, Central Electricity Authority
क्षेत्रीय निरीक्षण संगठन

REGIONAL INSPECTORIAL ORGANISATION

14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033

14 Golf Club Road, Tollygunj, Kolkata-700033

No.RIO/ER/RRRLF-KOL/721-722

Date: 16.11.2017

Executive Engineer (E),
Kolkata Central Electrical Division - VI
CPWD
Kolkata

Subject: Acceptance of FORM-III as self certification for energization of Electrical installations of 1 no. of 500KVA, 11/0.433KV Energypac make Cast Resin Transformer and 1 no. of Biecco Lawrie make 12KV VCB at Raja Ram Mohan Library Foundation, Salt Lake, Kolkata under Regulation-43 of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulation, 2010.

Ref: Your letter no. 23(RRRLF)/KCED-VI/2017-18/1052 dated 16.10.2017


With reference to the above mentioned subject, it is to intimate that duly filled up FORM-III as self certification for energization of the Electrical installations of 1 no. of 500KVA, 11/0.433KV Energypac make Cast Resin Transformer and 1 no. of Biecco Lawrie make 12KV VCB at Raja Ram Mohan Library Foundation, Salt Lake, Kolkata has been received at this office vide your letter under reference above.

The self certification, as submitted in FORM-III, is accepted at this end for energization of Electrical installations of 1 no. of 500KVA, 11/0.433KV Energypac make Cast Resin Transformer and 1 no. of Biecco Lawrie make 12KV VCB at Raja Ram Mohan Library Foundation, Salt Lake, Kolkata (as indicated below along with Sl. Nos. of Transformer & VCB) under Regulation-43 of CEA (Measures Relating to Safety and Electric Supply) Regulation, 2010, subject to strict compliance with all the relevant provisions of the said regulations.

- Energypac make 500KVA, 11/0.433KV Transformer with Sl. No. CRT/11/0.433/500/028
- Biecco Lawrie make 12KV, 630A VCB with Sl. No. HXB81F-1181

It shall be ensured that earth pit resistance values shall be $<5\Omega$ (individual or without grid) & $<1\Omega$ (with grid) for all the pits.

The designated Electric safety officer shall routinely carry out periodic inspection from time to time of the said installations.


(S. KEJRIWAL)

Deputy Director &
Electrical Inspector to the Govt. of India

Copy to: The Chief Engineer (EI) CEA, 3rd Floor, NRPC, 18A, SJS Marg, Katwaria Sarai,
New Delhi-110016

Received
Area/Inspector
16/11/17.