



Government of India  
Central Electricity Authority  
Regional Inspectorial Organisation  
Block IV, Floor III, Shastri Bhawan, Chennai - 600 006



No.140/1/2016-RIO/

Dated 08.12.2017.

To,  
M/s NIT Campus Surathkal,  
P.O Srinivasanagar - 575025,  
D.K, Karnataka.

O/C.

**Sub:** Self - Certification report submitted by M/s NIT Surathkal under regulation 43 for 11/0.433kV 500KVA Transformer, 11kV DP structure and MV additions/alterations done at Computer Science Building, NIT Campus, Surathkal - Reg.

**Ref:** NIT letter dated 06.11.2017 (Received on 20.11.2017)

Vide letter under reference, M/s NIT Surathkal has submitted Self-Certification report under regulation 43 for 11/0.433kV 500KVA Transformer, 11kV DP structure and MV additions/alterations (as mentioned in the Self Certification report) done at Computer Science Building, NIT Campus, Surathkal and requested for acceptance of the same by this office.

It is hereby said that Self - Certification report of 11/0.433kV 500KVA Transformer, 11kV DP structure and MV additions/alterations (as mentioned in the Self Certification report) done at Computer Science Building, NIT Campus, Surathkal submitted by M/s NIT Surathkal is found to be generally in order. Hence the Self - Certification report submitted by M/s NIT Surathkal under regulation 43 for the mentioned electrical installations in the Self Certification report is hereby accepted and can be energized. The acceptance of Self - Certification report of aforesaid electrical installations for energizing is subject to full compliance of relevant provisions of CEA (Measures relating to Safety and Electric supply) Regulations, 2010 (as amended to date) in every respect

M. L. J. H.

8/12/17

Mary Francis

(Mary Francis)  
Deputy Director  
For CEI to Govt. of India

उप निदेशक / Deputy Director  
क्षेत्रीय निरीक्षण संगठन  
Regional Inspectorial Organisation  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
चेन्नई / Chennai-600 006.