



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Block IV, Floor III, Shastri Bhawan, Chennai - 600 006



No.140/1/2016-RIO/ 1187

Dated 12.12.2017.

To,
Nijalingappa,
Director (Safety)&Head of Office,
Regional Labour Institute,
No.1, Sardar Patel Road,
Adyar, Chennai - 600113.

%

Sub: Acceptance of Self - Certification report submitted by M/s Regional Labour Institute for the equipment which has been erected at newly constructed 2X315KVA S/s at their office premises - Reg.

Ref: F.No. RLI/CPWD/Elect/2017 dated 20.11.2017

Vide letter under reference M/s Regional Labour Institute has submitted Self - Certification report under regulation 43 for HV&MV equipment which has been erected at newly constructed 11/0.433kV,2X315KVA S/S at their office premises and requested for acceptance of the same by this office. The list of equipment which are erected at 11/0.433kV, 2X315KVA S/S are as given below:

SNo.	Name of the Equipment	Qty
1.	11/0.433kV, 315KVA T/F	2nos
2.	11kV, HT Panel	1nos
3.	3CX240 Sq.mm 11kV grade, XLPE Al conductor cable. (Connecting HT panel and T/Fs)	-
4.	MV Non Essential Panel	1nos
5.	630A TPN AL Bus bar	-
6.	31/2C 300Sqmm AL Ar XLPE Cable from TR - 1& 2 to MV non essential panel	-
7.	Essential MV Switch Board	1nos
8.	APFC Panel	2nos
9.	LDB - SS	-

It is hereby said that Self - Certification report submitted by M/s Regional Labour Institute under regulation 43 for the above mentioned HV&MV installations which are erected at new 11/0.433kV,2X315KVA S/s constructed at their office premises is found to be generally in order. Hence the Self - Certification report submitted by M/s Regional Labour Institute under regulation 43 for the aforesaid

electrical installations installed at new 11/0.433kV, 2X315KVA S/s constructed at their office premises is hereby accepted and can be energized. The acceptance of Self - Certification report of aforesaid electrical installations is subject to full compliance of relevant provisions of CEA (Measures relating to Safety and Electric supply) Regulations,2010 (as amended to date) in every respect.

M. L. S.
12/12/12

Mary Francis

(Mary Francis)
Deputy Director
For CEI to Govt. of India

उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectional Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्ने / Chennai-600 008.