



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Block IV, Floor III, Shastri Bhawan, Chennai – 600 006



No.140/1/2016-RIO/ 1123

Dated 04.12.2017.

To,
M/s NIT Campus Surathkal,
P.O Srinivasanagar - 575025,
D.K, Karnataka.

Sub: Self - Certification report submitted by M/s NIT Surathkal under regulation 43 for 11/0.433kV, 500KVA Transformer, 11kV DP structure and associated equipment installed at Mechanical Engineering Block, NIT Campus Surathkal - Reg.

Ref: F.No. 155/2017-18/DM dated 17.11.2017

Vide letter under reference, M/s NIT Surathkal has submitted Self - Certification report under regulation 43 for 11/0.433kV, 500KVA Transformer, 11kV DP structure and associated equipment installed at Mechanical Engineering Block, NIT Campus Surathkal and requested for acceptance of the same by this office. The list of equipment are as given below:

SNo.	Name of the Equipment	Qty
1.	11/0.433kV, 500KVA T/F	1nos
2.	11kV DP Structure	1nos
3.	Connecting cables	
4.	MV Panel	1nos

It is hereby said that Self - Certification report of above mentioned electrical installations under regulation 43 installed at Mechanical Engineering Block, NIT Campus Surathkal submitted by M/s NIT Surathkal is found to be generally in order. Hence the Self - Certification report submitted by M/s NIT Surathkal under regulation 43 for the aforesaid electrical installations installed at Mechanical Engineering Block, NIT Campus Surathkal is hereby accepted and can be Energized. The acceptance of Self - Certification report of aforesaid electrical installations for energizing is subject to full compliance of relevant provisions of CEA (Measures relating to Safety and Electric supply) Regulations, 2010 (as amended to date) in every respect

Mary Francis

(Mary Francis)
Deputy Director

For CEI to Govt. of India

उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्नाई / Chennai - 600 006.