



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Block IV, Floor III, Shastri Bhawan, Chennai - 600 006



No.140/1/2016-RIO/ 10/13

Dated 17.11.2017.

To,
S.Thandapani,
Deputy General Manager (Electrical),
NMDC Limited, Khanij Bhavan,
10-3-311/A, Castle Hills,
Masab Tank, Hyderabad - 50002

O/c.

Sub: Acceptance of Self - certification report submitted by M/s NMDC Limited under regulation 43 for 11/0.433kV 1250KVA prefabricated compact S/s and associated equipment installed at their premises - Reg.

Ref: NMDC Limited letter dated 16.11.2017.

Vide letter under reference, M/s NMDC Limited has submitted Self - Certification report under regulation 43 for the below mentioned electrical installations which are installed at their premises and requested for acceptance of the same by this office. The list of equipment is as given below:

SNo.	Name of the Equipment	Qty
1.	11/0.433kV, 1250KVA pre fabricated compact S/s	1nos
2.	2000A LT Bus Duct	1set

It is hereby said that Self - Certification report of above mentioned electrical installations under regulation 43 installed at premises of NMDC submitted by M/s NMDC Limited is found to be generally in order. Hence the Self - Certification report submitted by M/s NMDC Limited under regulation 43 for the aforesaid electrical installations installed at their premises is hereby accepted and can be energized. The acceptance of Self - Certification report of aforesaid electrical installations is subject to full compliance of relevant provisions of CEA (Measures relating to Safety and Electric supply) Regulations, 2010 (as amended to date) in every respect.

Mary Francis

(Mary Francis)
Deputy Director
For CEI to Govt. of India

उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्नै / Chennai - 600 006.

M.L. Th
17/11/17