



#### भारत सरकार

### Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युतसंचारविकासप्रभाग

# **Power Communication Development Division**

No.: CEA/PCD/PTCC/UP-508 410-412

Date 20.08.2020

Subject: PTCC proposal for LILO of 220 kV S/C Chandausi-Badaun transmission line at 400 kV GIS Badaun-regd.

Ref.: (i) OCBTL Ref. No. OCBTL/Bareilly/PTCC/92

Dated: 31.08.2019

(ii) BSNL Ref. No. DET/PTCC/ND/DV-9719/UP-866/2020-21

Dated: 16.07.2020

(iii) North Eastern Railway Ref. No. N/242/0(Tele)PTCC Part-

Dated: 11.03.2020

II/1067

(iv) Defense Ref. No. B/46937/Sigs 7(b)/1850

Dated:22.01.2020

The PTCC proposal submitted vide ref. (i) has been examined. The LF induction on telecom cables of BSNL and Block & Telecom circuits of North Eastern Railway with respect to details furnished vide above references (ii) and (iii) respectively has been computed. The Soil Resistivity (SR) value has been taken as 20,000 Ohm-cm. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of North Eastern Railway under Single Line to Ground fault condition are enclosed at Annex-I and Annex-II respectively. The screening factors, as applicable, have been considered. Vide ref. (iv) above, Defence Authority have issued No Objection Certificate (NOC) (a copy enclosed as Annex-III).

Taking above into consideration, kindly take necessary action for PTCC route approval.

Encl.: As above.

Upouskakimin

(Upendra Kumar) Chief Engineer

To,
The Divisional Engineer (Telecom), BSNL
PTCC O/o GM (North), Inspection Circle (T & D),
CTS Compound, Netaji Nagar,
Africa Avenue, New Delhi – 110023.

Me

Case No.: UP-508

Name of the Power Line: 220 KV Chandausi- Badaun Transmission line at 400/220/132 KV GIS Badaun

Annexure I

Toposheet Scale : 1cm=500mts

Total Length :

18.489 Kms

S.R Value : 20,000 Ohm-cm

Sl. No.	Name of Telecom Line	LOP in Kms	MC in Ohms	Fault Current (Amps)	IV in Volts
BSNL Reference Date :	e No. DET/PTCC/ND/DV-9719/UP-866/20201-21	Dated:- 16.07.2			
	BSNL Details		1		·
1	Devchara to Bhamora 20 Pair ( 3 KM)	1			
2	Sainda to Iffco Township 1200 pair ( 4 KM)				
3	Coinda to Khudha 50 pair ( 5 KM)	LITY	Hoss	than 4	30V
4	Kunwargaon TE to Charvrah 200 mts	and any V	1 6	1 1000	
5	Kunwargaen TE to chaired Town 50 pm	3 7			
6	Kunwargaon TE to Charvah 200 pm Kunwargaon TE to Charvah 7000 50 pm Kunwargaon TE to Charish Town 50 pm Binawar TE to Bionawar Thana 200 pm				
	/				
:					

सत्यक निदेशक II/Asst. Director-II सत्यक निदेशक II/Asst. Director-II फेट्रीय विश्वन अधिकारण/C E.A. विश्वन मंत्रातय/Ministry of 20 अ भारत सरकार/Goot, or In 3 नहिल्ली/New Diship. 3

## ANNEXURE - II

Case No.: UP-508

Name of the Power Line: LILO of 220 kV S/C

Chandausi-Badaun transmission line at 400 kV GIS

Badaun.

Map Scale : 1 cm = 500 m. Route Length : 18.489 km

Soil Resistivity: 20,000 Ohm-cm

S.No. Telecom Details	Length of Parallelism (in km)	Mutual Coupling (Ohms)	Fault Current (Amps)	Induce d Voltage (Volts)	
		1			Ĺ

	NORTH EASTERN RAILWAY Ref. No: N/242/0(Tele)PTCC Part-II/1067		DATED: 1	1.03.2020	
	Affected Blocks & Telecom Circuits De	etails			
1	Makrandpur-Ghatpuri	10.3	0.0098	7241	71
2	Makrandpur-Bamiyana	Out of Parallelism			00

REST / TABLE DIRECTOR!

Tele: 23019746

(Annex-III)

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/1850/

22 Jan 2020

Associate Manager
Obra-C Badaun Transmission Limited
House No. 116, Green Park Colony,
Bisalpur Road, Bareilly (UP) India,
Pin Code-243006

# PTCC APPROVAL OF LILO OF 220KV S/C CHANDAUSI-BADAUN TRANSMISSION LINE AT 400KV GIS BADAUN

- 1. Ref your letter No OCBTL/Bareilly/PTCC/92 dt 31 Aug 2019. (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat) Maj GSO 1 (Comn) for SO-in-C

Enclosures : (As above)

Copy to :-

: 3

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, N. w Delhi – 110016

Divisional Engineer Telegraph (PTCC)
O/o GM (North): BSNL, QA & Inspection Circle,
CTS Compound, Africa Avenue Road,
Netal Nagar, New Delhi-110023

for information