

भारत सरकार Government of India दिद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग Power Communication Development Division

No.: CEA/PCD/ PTCC/UP-497/ 292-2-9, 4

Date: 14.07.2020

Subject: PTCC proposal for 220 kV DC PGCIL Shahjahanpur (400 kV)- Ajeejpur (Shahjahanpur) Transmission line.

Ref.:

(i) UPPTCL Ref.5/3 ETD(S)/DCML

Dated: 04.05.2019

(ii) BSNL Ref. No. DET/PTCC/ND/DV-9457/UP-707/2019-2020

Dated: 08.07.2020

(iii) Northern Railway Ref. No. 342-SIG/1/PTCC

Dated: 29.07.2019

The PTCC proposal submitted vide above ref. (i) has been examined. The low frequency induction on block circuits/Telecom circuits of Northern Railway as per details furnished vide ref. (iii) has been examined. The Average Soil Resistivity value has been taken as 15,000 Ohms-cm. Voltages likely to be induced on paralleling Block/Telecom circuits of Northern Railway under single line to ground fault condition are enclosed at Annex-I. The screening factors as applicable have been considered.

BSNL vide ref. (ii) above, has intimated that there are no U/G cable and no armoured OFC within 08 kms of the proposed power line and hence, issued No Objection Certificate (NOC).

Telecommunication details from Defense are pending and the power authority has shown urgency for the charging of the line. In view of this kindly take necessary action regarding issuance of provisional PTCC route approval for 220 kV DC PGCIL Shahjahanpur (400 kV)- Ajeejpur (Shahjahanpur) Transmission line.

Encl.: As above.

Upondragan - 14.07. 2000

(Upendra Kumar) Chief Engineer

To,
The Divisional Engineer (Telecom), BSNL
PTCC O/o GM (North), Inspection Circle (T & D),
CTS Compound, Netaji Nagar,
Africa Avenue, New Delhi - 110023

MIC

Copy to:

- 1.Executive Engineer, Electricity Transmission Division, UPPTCL,220 kV Sub-Station, Powayan Road, Shahjahanpur, Uttar Pradesh-242001.
- 2. General Manager (\$&T), Northern Railway, Headquarter Office, Baroda House, New Delhi.

or of the state of the second

ANNEXURE - I

Map Scale : 1cm=500mts

Total Langth : 24.474 Km.

S.R. Value : 15,000 Ohms-cm

Effective

Length of Mutual Fault I.V

current

in Amps.

1

Voite

Coupling

in Ohms.

NORT	HERN RAILWAY				
Ref. No: 342-SIG/1/PTCC		DATED: 29.07.2019			
				•	
<u>Affect</u>	ed Blocks & Telcom Circuits Details	,	-		
1	Shahjahanpur-Rosa	Out of IV calculation Consideration Zone			
2	Rosa-Kahilia	2.4	0.01	5400	54
3	Rosa-Bantra	4.6	0.0062	10000	62
			i		

Parallelism

in Km.

Case No.: UP-497

S.No.

Name of the Power line: 220 kV DC PGCIL Shahjahanpur

Telecom. Details

(400 kV)- Ajeejpur (Shahjahanpur) Transmission line.

STATES AND STATES OF POWER STATES AND STATES AND STATES AND DESTRUCTIONS OF INDICATES AND DESTRU