

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युतसंचार विकास प्रभाग Power Communication Development Division

No.: CEA/PCD/ PTCC/UP-530/ 295-297

Date: 14.07.2020

Subject: PTCC proposal for LILO of 400 kV DC Unchahar(NTPC)-Fatehpur (PGCIL) at Raibareily.

Ref.: (i) UPPTCL Ref. 327/ETDR/400 kV LILO

Dated: 13.03.2020

(ii) BSNL Ref. No. DET/PTCC/ND/DV-9671/UP-842/2019-2020

Dated: 08.07.2020

(iii) Northern Railway Ref. No. 342-SIG/1/PTCC/2019-20/02/02

Dated: 13.02.2020

The PTCC proposal submitted vide above ref. (i) has been examined. The low frequency induction on block circuits/Telecom circuits of Northern Railway as per details furnished vide ref. (iii) has been examined. The Average Soil Resistivity value has been taken as 10,000 Ohms-cm. Voltages likely to be induced on paralleling Block/Telecom circuits of Northern Railway under single line to ground fault condition are enclosed at Annex-I. The screening factors as applicable have been considered.

BSNL vide ref. (ii) above, has intimated that there are no U/G cable and no armoured OFC within 08 kms of the proposed power line and hence, issued No Objection Certificate (NOC).

Telecommunication details from Defense are pending and the power authority has shown urgency for the charging of the line. In view of this kindly take necessary action regarding issuance of provisional PTCC route approval for LILO of 400 kV DC Unchahar(NTPC)-Fatehpur (PGCIL) at Raibareily.

Encl.: As above.

Upendra Kumar)

(Upendra Kumar Chief Engineer

To,
The Divisional Engineer (Telecom), BSNL
PTCC O/o GM (North), Inspection Circle (T & D),
CTS Compound, Netaji Nagar,
Africa Avenue, New Delhi - 110023

MIC

Copy to:

1.Executive Engineer, Electricity Transmission Division, UPPTCL,132 kV S/s Tripula campus, Raebareli, Uttar Pradesh-229001.

2. General Manager (S&T), Northern Railway, Headquarter Office, Baroda House, New Delhi.

ANNEXURE - L

Map Scale : 1cm=500mts

Case No.: UP-530

Name of the Power line: LILO of 400 kV DC

Unchahar(NTPC)- Fatehpur (PGCIL) at Raibareily.

Effective

		i anath ali	Mutua:	Effective Fault	l.V
	-	Length of Parallelism	Coupling	current	[[U]
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.
				j 	<u>. </u>

-	DRTHERN RAILWAY f. No: 342-SIG/1/PTCC/2019-20/02/02 DATED: 13.02						
	ed Blocks & Telcom Circuits Details			<u></u>			
1	Manjhilepur- Iswardaspur	Outside IV Calculation Consideration Zone					
2	Iswardaspur- Unchahar	Outside IV Calculation Consideration Zone					
. 3	Unchahar-Arkha	2.3	0.0045	14200	÷-		
4	Arkha-Pariawan K.K Road	2.1	0.0027	14150	38		
5	Pariawan K.K Road- Garhi Manikpur	Outside IV Calculation Consideration Zone					
6	Lachmanpur-Ramchanderpur	Outside IV Calculation Consideration Zone					
7	Ramchanderpur-Unchahar	Outside IV Calculation Consideration Zone					

14.57.20

मुख्य अधिपता/Chief Engineer केन्द्रीय विद्या प्राधिकरण/C.E.A. केन्द्रीय विद्या प्राधिकरण/C.E.A. विद्युत संत्रालय/Ministry of Power भारत सरकार/Govl. of India भारत सरकार/Govl. of India नई दिल्ली/New Delhi