

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलप्मेंट प्रभाग

Power Communication Development Division

No. CEA/PCD/ PTCC/MP-426/ 523-25

Date: 25.04.2019

DET (PTCC), Western Zone, Bharat Sanchar Nigam Limited (BSNL), O/o DET(PTCC), QA & Inspection Circle, 3rd Floor, D-Wing, BSNL Admin Bldg., Juhu Tara Road, Santacurz (West), Mumbai – 400054.

Subject: Induced Voltage calculation in respect of PTCC proposal of LILO of 2nd circuit of 220 kV Birsinghpur - Amarkantak at 220 kV S/S Shahdol

Ref: (i) BSNL letter no. IC/MBI/PTCC/MP-521 dated 19.01.2019

- (ii) South East Central Railway letter no. SERC/S&T/PTCC/MP/796 dated 23.08.2018
- (iii) Defense letter no. B/46937/Sigs 7(b)/962 dated 07.03.2018

Sir.

The low frequency induction on BSNL and Railway Telecommunication circuits as per details furnished vide above cited references (i) and (ii) respectively has been examined. The Soil Resistivity value has been taken as 10,000 Ohms-cm, as per data submitted by Power Authority. Voltages likely to be induced on paralleling BSNL Telecom Cables and Railway Telecommunication circuits under single line to ground fault condition are enclosed at Annex-I&II respectively. The screening factors as applicable have been considered. Defense has accorded NOC vide above Ref.(iii) for the line (a copy enclosed at Annex-III).

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above

Yours faithfully.

(Naresh Bhandari) Chief Engineer

Copy to:

- Office of CSTE, South East Central Railway, 2nd Floor, SECR Zonal Hq Building, Bilaspur 495004 (Only Annex II)
- 2) Chief Engineer(Procurement), MPPTCL, Block No. 3, Shakti Bhawan, Rampur, Jabalpur (M.P.) 482008

MIC

OFA OCT				11/0/2/			
CEA	Office Case No.: MP- 426	Map Scale: 1:50,000					
DET	(PTCC) Office Case No.: IC/MBI/PTCC/MP-521		Route Length: 5.681 Kms				
Rails	way Office Case No.:						
ican	way Office Case No.:	Average SR Value: 10,000 Ohm cms					
Nam	e of Power Line LILO of 2 nd Circuit of 220KV proposed 220KV S/s Shahdo	Birsing	hpur	- Amarkant	ak DCDS	ine at	
S.	Name of Telecom Line/ Cable	Length	of.	Mutual	T14	7.7	
No.			sm	Coupling	Fault Current	Induce Voltage in	
		in Kms.	, in it	in Ohms	in Amps	Volts	
	SHAHDOL SSA					· OILG	
	SDOT Shahdol						
	Singpur T/Exchange						
	U/G Cable towards Location (1) – 100 Pair)		de 14 consid	ODGI E		
	U/G Cable towards Location (2) - 100 Pair	01	12 21	ALE IN CONSTR	evalua 2	one >	
	U/G Cable towards Location (3) - 50 Pair	1	-	<u> </u>	<u> </u>		
	U/G Cable towards Location (4) – 50 Pair	-					
	Shahdol T/Exchange	0					
	U/G Cable towards Location (A) - 800 Pair	7					
	U/G Cable towards Location (B) - 800 Pair						
?	U/G Cable towards Location (C) - 800 Pair				/		
	U/G Cable towards Location (D) - 800 Pair	· · · · ·					
	U/G Cable towards Location (E) - 400 Pair	1					
	U/G Cable towards Location (F) - 400 Pair						
	U/G Cable towards Location (G) - 400 Pair	1					
	U/G Cable towards Location (H) - 400 Pair						
	U/G Cable towards Location (I) - 400 Pair	VIV	less	than 4	30 V -	>	
	U/G Cable towards Location (J) – 400 Pair	1			·		
	U/G Cable towards Location (K) – 200 Pair			-			
	U/G Cable towards Location (L) - 200 Pair			L.			
	U/G Cable towards Location (M) – 200 Pair						
	U/G Cable towards Location (N) - 200 Pair						
	U/G Cable towards Location (O) - 200 Pair						
	U/G Cable towards Location (P) - 200 Pair						
	U/G Cable towards Location (Q) - 200 Pair						
	U/G Cable towards Location (R) - 200 Pair	1					
	U/G Cable towards Location (S) – 200 Pair	1 11			,		

नरेश भंडणि/NARESH BHANDARI
मुख्य अभियन्ता/Chief Engineer
कन्त्रीय विद्युत प्राधिकरण/C.E.A.
विद्युत मंत्रालय/Ministry of Power
भारत सरकार/Govt. of India
नई दिल्ली/New Delhi-66

ANNEXURE - II Map Scale : 1cm=500mts Case No.: MP-426 Total Length: 5.681Km. Name of the Power line: LILO of second circuit of 220 kV S.R. Value : 10,000 Ohms-cm Birsinghpur- Amarkantak at 220KV S/s shahdol **Effective** Length of Mutual Fault I.V Parallelism Coupling current in S.No. Telecom, Details in Km. in Ohms. in Amps. Volts. SOUTH EAST CENTRAL RAILWAY Ref. no. No. SE € N/ S&T / PTCC / MP / 796 Dated 23.08.2018 Burhar - Chhada ----Out side IV Consideration Zone---Chhada - Singhpur 2 2.0 0.0005 7690 3 Singhpur-Shahdol 3.0 0.0021 8800 18 4 Shahdol - Badhwapara Out of //sm---0 5 Badhwapara - Ghunghuti ---Out side IV Consideration Zone----मुख्य अभियन्ता/Chief Engineer
मुख्य अभियन्ता/Chief Engineer
कन्द्रीय निजुत प्राधिकरण/C.E.A.
कन्द्रीय निजुत प्राधिकरण/C.E.A.
विद्युत मंत्रालय/Ministry of Power
भारत सम्मार/Govt. of India
नई दिल्ली/Nev/ Delhi-00

Tee: 23019746

ANNEX-111 MP-426

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi - 110011

Mar 2018 C.E. (Procurement) M.F.P.T.C.L., Jobalpur 1 5 MAR 2018

B/46937/Sigs 7(b)/962/

Chief Engineer (Procurement) Madhya Pradesh Power Transmission Co Ltd Block No. 3 Shakti Bhawan, Jabaipur (MP) - 48008

PTCC ROUTE APPROVAL FOR LILO OF SECOND CIRCUIT OF 220KV BIRSINGHPUR - AMARKANTAK LINE AT 220KV S/S SHAHADOL

- 1. Reference your letter No__ _/PTCC/2527-A/TR-I/699 dt 19 Jan 2018.
- No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your letter mentioned above.
- Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(Nainee Sharma)

Lt Col

GSO 1 (Comn)

for SO-in-C