



भारत सरकार

Government of India विद्युत मंत्रालय

Ministry of Power केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority पावर कम्युनिकेशन डवलप्मेंट प्रभाग

Power Communication Development Division

No.:CEA/PCD/PTCC/RAJ-626/831-832

Date: 05.08.2019

DET (PTCC), Northern Zone, Bharat Sanchar Nigam Ltd (BSNL), O/o PGM(N), Inspection Circle, CTS/Compund, Netaji Nagar, New Delhi – 110023

Subject:

PTCC Route Approval for 220 kV S/C transmission line from Azure 130 MW Pooling

Station to PGCIL 765/400/220 kV Bhadla GSS.

Reference:

(i) BSNL letter no. DET/PTCC/ND/DV-9439/Raj-1214/2019-2020 dated 23.07.2019

(ii) North Western Railway letter no. SG/158/NWR/PTCC/743 dated 28.05.2019

(iii) Defense letter no. B/46937/Sigs 7(b)/1644 dated 11.07.2019

Sir,

The instant PTCC proposal has been examined. Vide ref. (i) above, BSNL have issued No Objection Certificate (NOC). Vide ref. (ii) above, North Western Railway have intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Hence, Induced Voltage calculation is not required. Vide ref. (iii) above, Defense Authority have issued No Objection Certificate (NOC) (enclosed as Annex).

Taking above into consideration, kindly take necessary action for PTCC route approval.

Encl.: As above

mlc

(R.P. Singh)
Director, PTCC

Copy to:

General Manager – SBU Utilities, Azure Power India Private Limited, 3rd Floor, Asset 301-304 and 307, WorldMark 3, Aerocity, New Delhi - 110037

Annes

Tele: 23019746

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

// Jul 2019

B/46937/Sigs 7(b)/1644/

General Manager-SBU Utilities Azure Power India Private Limited 3rd Floor, Asset 301-304 and 307, WorldMark 3, Aerocity, New Delhi-110037

PROPOSAL FOR PTCC APPROVAL OF PROPOSED 220KV S/C TRANSMISSION LINE FROM AZURE 130MW POOLING STATION TO PGCIL 765/400/220 GSS BHADLA GSS AT NURE KI BHURJ DIST-JODHPUR RAJASTHAN

- 1. Ref your letter No Azure/PTCC/130MW-TLC-MSEDCL/RAJ/001/05/2019 dt 10 May 2019 (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat) Maj GSO 1 (Comn) for SO-in-C

Enclosures: As above

Copy to :-

The Director (PTCC), CEA

Power Communication Development Division

NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

for information.