

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलप्पेंट प्रभाग

Power Communication Development Division

No.:CEA/PCD/PTCC/KNK-915 /812-813

Date: 17.07.2019

DET (PTCC), QA & Inspection (T&D) Circle, BSNL 1 Floor, Raj Bhavan Exchange, No. 26, Sardar Patel Road, Guindy, Chennai – 600032

Subject:

Induced Voltage Calculation in respect of PTCC proposal for 220 kV DC LILO line on MC towers from existing Belagavi – Chikkodi 220 kV DC line to the proposed 220/110/11 kV SS of M/s AEQUS SEZ PVT Ltd at Hattargi village in Hukkeri taluk, Belagavi District

Reference:

- (i) BSNL letter no. SR-PTCC/SKT-2305/03 dated 29.04.2019
- (ii) South Western Railway letter no. SG/SWR/PTCC/F-2834/1838/31 dated 11.04.2019

(iii) Defense letter no. B/46937/Sigs 7(b)/1421 dated 02.04.2019

Sir,

The instant PTCC proposal has been examined. Low frequency induction on telecom cables of BSNL with respect to details furnished vide above reference has been computed. The Soil Resistivity (SR) value has been taken as 25,000 Ohm-cm. The voltages likely to be induced on paralleling telecom cables of BSNL under Single Line to Ground fault condition have been computed and are enclosed as Annex – I. The screening factors, as applicable, have been considered. Vide ref. (ii) above, South Western Railway have issued No Objection Certificate (NOC). Vide ref. (iii) above, Defense Authority have issued No Objection Certificate (NOC) (enclosed as Annex – II).

Taking above into consideration, kindly take necessary action for PTCC route approval.

Encl.: As above

mic

राधिन प्रताम भिट्ट रि.P. Singh) Director, PTCC

Copy to:

Chief Engineer Electricity, KPTCL, State Load Despatch Centre, No. 28, R.C. Cross Road, Bengaluru - 560009

-CEA Case No. : KNK-915

	1		SSA:Belagavi		
ame of the power line	ower line			n MC towers from ne to the proposed nited at Hattargi V	1 220 1000 100
9R Value: 25,000 12-cm	5.637	Taluk,Belagav Kms		ale : Lan=	= 500 mt
No. Name of Telecom line		Type of BSNL (LOP in KMs	Cable: PIJF cable	FC in Amps	IV in Volts
y)YAMKANMARDI Exge UG cables 1 Exge to Hattargi(Y-Y2) 2 Exge to Indiranagar(Y-Y3) Exge to Yamkanmardi Local to Village 3 Y1-Y4)	(Y-] } 1v		IMAN 43	

राध्येद प्रताप सिंह स्वतिप्रताप सिंह RAGHVENDRA PRATAP SINGH स्थित प्रताप शिक्ष केन्द्रीय शिक्ष प्रतिग्रहरूग/C.E.A. विक्रत मंत्रालय/Ministry of Power बारत मंत्रालय/Ministry of India नारत मंत्रालय/Ministry of India नारत सर्वार/Govi. of India नारत सर्वार/New Delin-B6

Anner - 11 RNK-91

Tele: 23019746

Directorate General of Signals Signals - 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/1421

₹2_ Apr 2019

Karnataka Power Transmission Corporation Limited Office of the Chief Engineer Electricity, State Load Despatch Centre, # 28, R.C. Pross Road, Bengaluru – 560 009

PROPOSED 220KV DC LILO LINE ON MC TOWERS FROM EXISTING BELAGAVI-CHIKKODI 220KV DC LINE TO THE PROPOSED 220/110/11KV SS OF M/S AEQUS SEZ PVT LIMITED AT HATTARGI VILLAGE IN HUKKERI TALUK, BELAGAVI DISTRICT

- 1. Ref your letter No CEE/SLDC/PTCC/F-2834/-16936-44 dt 17 Jan 2019 (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat)

Мај

GSO 1 (Comn)

for SO-in-C

Enclosures: (As above)

Copy to:

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

for information.