



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डेवलपमेंट प्रभाग

Power Communication Development Division

No.:CEA/PCD/PTCC/RAJ-619/816-817

Date: 24.07.2019

DET (PTCC), Northern Zone,
Bharat Sanchar Nigam Ltd (BSNL),
O/o PGM(N), Inspection Circle,
CTS Compound, Netaji Nagar,
New Delhi – 110023

Subject: PTCC Route Approval for Mahoba Solar Power Plant Switchyard at Rawra – Bhadla
220 KV S/C line

Reference: (i) BSNL letter no. DET/PTCC/ND/DV-9416/Raj-1207/2019-2020 dated 09.07.2019
(ii) North Western Railway letter no. SG/158/NWR/PTCC/731 dated 22.03.2019
(iii) Defense letter no. B/46937/Sigs 7(b)/1509 dated 08.07.2019

Sir,
The instant PTCC proposal has been examined. Vide ref. (i) above, BSNL have issued No Objection Certificate (NOC). Vide ref. (ii) above, North Western Railway have intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Hence, Induced Voltage calculation is not required. Vide ref. (iii) above, Defense Authority have issued No Objection Certificate (NOC) (enclosed as Annex).

Taking above into consideration, kindly take necessary action for PTCC route approval.

Encl.: As above

Raghendra Pratap Singh
24.07.19
(R.P. Singh)
Director, PTCC

m/c

Copy to:

M/s Mahoba Solar (UP) Private Limited, Adani House, Nr Mithakhali Six Roads, Navrangpura,
Ahmedabad, Gujarat – 380009

Original Received
[Signature]

Annex RAS-113

Tele : 23019746

**Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011**


B/46937/Sigs 7(b)/1509 /

08 Jul 2019

~~Mahoba Solar (UP) Private Limited
Adani House
Nr. Mithakhali Six Roads
Navrangpura
Ahmedabad 380 009
Gujarat, India~~

SUBMISSION OF PROPOSAL FOR PTCC APPROVAL OF "MAHOBA SOLAR POWER PLANT SWITCHYARD AT RAWRA-BHADLA 220KV S/C LINE" OF M/S MAHOBA SOLAR (UP) PVT LTD IN JODHPUR DISTRICT OF RAJASTHAN

1. Ref your letter No MSUPPL/RAVRA/TL/003 dt 21 Feb 2019 (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.


(A Rawat)
Maj
GSO 1 (Comn)
for SO-in-C

Enclosures : As above

Copy to:

✓ The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

for information.