

#### Government of India विद्युत मंत्रालय

Ministry of Power केन्द्रीय विद्युत 'प्राधिकरण

# Central Electricity Authority पावर कम्युनिकेशन डवलप्मेंट प्रभाग

## Power Communication Development Division

No.CEA/PCD/PTCC/KNK-865

दिनांक:07/03/2019

The Divisional Engineer Telecom (PTCC), QA & Inspection (T&D) circle, BSNL, 1st floor, Raj Bhavan Exchange, No.26, Sardar Patel Road. Guindy, Chennai-600032

Subject:

PTCC Route Approval for 400kV D/C YTPS -Kalaburgi T/L

Reference: i) BSNL letter no. SR-PTCC/SKT\_1382/10 dated 27/06/2018

ii) South Central Railway letter no. SG/85/4/3/PTCC/SCRKS201615 RTD dated 30/12/2016

iii) Central Railway letter no.N.153/PTCC/400kV /KAR-70 dated 21/02/2017

iv) Defense letter no. B/46937/Signs 7(b)/454/ dated 18.01.2017

Sir.

The instant PTCC proposal has been examined. The low frequency induction on telecom cables of BSNL and Block & Telecom Circuits of South Central Railway with respect to details furnished vide above reference has been computed. The average Soil Resistivity (SR) value has been taken as 30,000 Ohm Cm, as intimated by Power Authority(KPTCL). The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of South Central Railway circuits under Single line to Ground fault condition have been computed and are enclosed at Annex-I & II respectively. The screening factors, as applicable, have been considered. Vide Ref. (iii) above Centrale Railway have issued No Objection Certificate (NOC). Vide Ref. (iv) above, the Defense authority have issued No Objection Certificate (NOC) (enclosed at Annex-

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above

(Naresh Bhandari) Chief Engineer

### Copy to:

(i)SSTE, South Central Railway, Headquarters Office, Signal & telecom Branch, rail Nilayam, Secunderabad-500071- (with Annexure II only).

(ii) Chief Engineer, Electricity, SLDC, KPTCL, # 28, R.C. Road, Bengaluru-560009.

Case flo. SKT -1382		SSAs: Mahabubnagar, Raichur & Gulbarga					
CE	A. Case No KNR-865		g,	- outsaiga			
Name of the power line		400 KV Partly MC/DC line on MC/DC towers from the existing KV SS at YTPS to the proposed 400/220 KV Pooling Station at Kalaburgi near Firozabad Village in Kalaburgi Taluk & District					
Lengt	th: 121.694	.					
Avorso	ge SR value : 30,000 ohm cms	Kms					
Averag	ge Sk value : 39,000 ohm cms						
SI.No.	Name of Telecom line	100: 400					
		LOP in KMs	MC in Ohms	FC in Amps	IV in Volts		
	Raichur SSA Topo map						
	details						
. A	V						
. А	Yeggasanahalli A/N Rack Exge UG cables						
	1 Exge to YTPS A-A1						
	TICHE TO TIPS A-AI						
	2 Exge to Yeggasanahalli Village A-A2	1210	less the	m 430	V.		
	3 Exge to Main Industrial Area A-A3				, , , , , , , , , , , , , , , , , , ,		
	4 Exge to Chicksugur A-A4						
. В	Jegarkaral A/N Rack Exge UG cables			-			
	1 Exge to Mallapur B-B1	11/10	285 other	4. 3. 3	-		
I. C	Shaktinagar RSU Exge UG cables	( / /(	-67 O A	- 430V	1		
	1 Exge to RTPS C-C1	11/1/	ess than	11501			
/. CC	Yaramarus Exge UG cables	1 1 21 6	tes one	430V			
	1 Exge to Diet college CC-C1	1	_				
	2 Exge to Potagal Road CC-C2	1 Owt 8	of Parall	1			
	3 Exge to Paras Vatika CC-C3	1	1 70 21	er in			
D	Gunj Exge UG cables						
	1 Exge to Industrial area D-D1	)					
-	2 Exge to 48 Pillar & Fire Stn. D-D2	8 Owt	of Par	allelism			
	3 Exge to Gunj Kalayan Mantap D-D3	J	1 -1.	TIEM SIN			
	Mahabubnagar SSA topo map						
	details						
	Krishna Exge UG cables						
	1 Exge to Kusumurthy	1	-				
	Exge to Gurjala	3 IV le	er Than	112511			
	Kalaburagi SSA topo map	10 110	10000	430 U			
	details						
A	Ferozabad Exge UG cables						
	Exge to Market Ferozabad A-A1	IV les	s other				

नरेश मंडागि/NARESH MANDARI मुख्य अधियन्ता/Chief Engineer केन्द्रीय विद्युत प्राधिकरण/C.E.A. विद्युत मंत्रालय/Ministry of Power भारत सरकार/Govt. of India नई दिल्ली/New Delhi-66 Case No.: KNK-865

Name of the Power line:

400kV D/C YTPS-Kalaburgi T/L

Map Scale : 1cm=500mts

Total Length: 121.694 Km.

S.R. Value : 30,000 Ohms-cm

Length of Parallelism in Km. Mutual Coupling in Ohms. I.V S.No. Block & Telecom. circuit Details Effective in Volts. Fault current in Amps.

1	Raichur(RC)-Yermarus(YS)	0	Out of parallelism			
2	Yermarus(YS)-Chiksugur(CK)	1.5	0.00018	15000	3	
3	Chiksugur(CK)-Yadulapur(YDLP)	5.0	0.001	14250	14	
4	Yadulapur(YDLP)-Krishna(KSN)	1.5	0.00023	13150	3	
5	Krishna(KSN)-Chengunta(CGTA)	2.0	0.0002	13150	3	
		मृतय अभियन्ता	नरेश मंडारी/NAKESH BHANDARI मृज्य अभियन्ता/Ohief Engineer			
		केन्द्रीय विद्युत इ तिहास मंत्रालय / N	केंन्द्रीय विद्युत प्राधिकरण/C.E.A. तिद्युत मंत्रालय/Ministry of Power			
			भारत सरकार / Govt. of India मई दिल्ली / New Delni-66			
_						

ANNEX-III KNK-865

Tele: 23019746

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD (Army) DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/454/

Jan 2017

Chief Engineer Electricity, State Load Despatch Centre, #28, R.C. Cross Road Bangalaore - 560009

# PROPOSED 400KV PARTLY MC/DC LINE ON MC/DC TOWERS FROM THE EXISTING 400KV SS AT YTPS TO THE PROPOSED 400/220KV POOLING STATION AT KALABURGI NEAR FIROZABAD VILLAGE IN KALABURGI TALUK & DISTRICT

- Reference your letter No. CEE/SLDC/PTCC/F-2463/11710 20 dt 17 Dec 2016.
- No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your letter mentioned above.
- Documents alongwith map sheets (in original) are forwarded herewith for your further necessary action.

(Bikram Kunwar)

Lt Col

GSO 1 (Comn)

for SO-in-C

Enclosures : (As above)

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheedjeet Singh Marg
Katwaria Sarai, New Delhi - 110016

for information.