



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट प्रभाग
Power Communication Development Division

No.:CEA/PCD/PTCC/KNK-896/306-308

Date:15.03.2019

DET (PTCC),
QA & Inspection (T&D) Circle, BSNL
1 Floor, Raj Bhavan Exchange,
No. 26, Sardar Patel Road,
Guindy, Chennai – 600032

Subject: Induced Voltage Calculation in respect of PTCC proposal for 2 no.s 220 kV DC lines from existing 220/66/11 kV KPTCL SS at Puttenahalli (D.G. Plant) Yelahanka to proposed KPCL 220 kV Gas Power Plant at Puttenahalli in Yelahanka


Reference: (i) BSNL letter no. SR-PTCC/SKT-2069/06 dated 16.11.2018
(ii) South Western Railway letter no. SG/SWR/PTCC/F-2743/1750 dated 27.07.2018
(iii) Defense letter no. B/46937/Sigs 7(b)/1053 dated 14.05.2018

Sir,

The instant PTCC proposal has been examined. Low frequency induction on telecom cables of BSNL and Block & Telecom circuits of South Western Railway with respect to details furnished vide above references has been computed. The Soil Resistivity (SR) value has been taken as 25,000 Ohm-cm. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of South Western Railway under Single Line to Ground fault condition have been computed and are enclosed as Annex – I & II respectively. The screening factors, as applicable, have been considered. Vide ref. (iii) above, Defense Authority have issued No Objection Certificate (NOC) (enclosed as Annex – III). Taking above into consideration, kindly take necessary action for PTCC route approval.

Encl.: As above

m/c


(Naresh Bhandari)
Chief Engineer


Copy to:

- 1) PCSTE, South Western Railway, Office of the Principal Chief Signal & Telecom Engineer, 1st Floor, West Block, Rail Soudha, Gadag Road, Hubli – 580020 (Annex – II only)
- 2) Chief Engineer Electricity, KPTCL, State Load Despatch Centre, No. 28, R.C. Cross Road, Bengaluru - 560009

ANNEXURE – I


Case No.: KNK-896					
Name of the Power line: 2 no.s 220 kV DC lines from existing 220/66/11 kV KPTCL SS at Puttenahalli (D.G. Plant) Yelahanka to proposed KPCL 220 kV Gas Power Plant at Puttenahalli in Yelahanka		Map Scale : 1cm=500mts Total Length : 0.223 km, 0.356 km Soil Resistivity : 25,000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.

BSNL letter no. – SR-PTCC/SKT-2069/06 dated 16.11.2018					
I	SAHAKARNAGAR (SHNR) Exge UG cables				
1	Exge to Bellay Road (SH-SH1)	OUT OF PARALLELISM			
2	Exge to Kodigehalli (SH-SH2)				
3	Exge to Towards Railway Tracks (SH-SH3)				
II	AMRUTHALLI (AH) Exge UG cables				
1	Exge to Amruthalli Main Road (AH-AH1)	IV LESS THAN 430 V			
2	Exge to Towards NH7 (AH-AH2)	OUT OF PARALLELISM			
III	DASARAHALLI (DE) Exge UG cables				
1	Exge to Dasarahalli Main Road (DE-DE1)	OUT OF PARALLELISM			
2	Exge to Coffee Board side (DE-DE2)				
3	Exge to Bhuvaneshwari Nagar (DE-DE3)				
IV	ASTRAZENLLA DLC (AR) Exge UG cables				
1	Exge to Godrej Housing Complex (AR-AR1)	IV LESS THAN 430 V			
2	Exge to Kempapura (AR-AR2)				
V	YELAHANKA (YNK) Exge UG cables				
1	Exge to Judicil L/O (YN-YN1)	IV LESS THAN 430 V			
2	Exge to Maruthiwagar RSU (YN-YN2)				
3	Exge to Attur L/O (YN-YN3)				
4	Exge to Anantpur (YN-YN4)				
5	Exge to Heritage DLC (YN-YN5)				
VI	RAJANKUNTE (RJN) Exge UG cables				
1	Exge to Marasandra (RJN-RJN1)	OUT OF PARALLELISM			
2	Exge to Yelahanka (RJN-RJN2)				


 नरेश भंडारी / NARESH BHANDARI
 मुख्य अभियन्ता / Chief Engineer
 केन्द्रीय विद्युत प्राधिकरण / C.E.A.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Govt. of India
 नई दिल्ली / New Delhi-66

ANNEXURE – II

Case No.: KNK-896					
Name of the Power line: 2 no.s 220 kV DC lines from existing 220/66/11 kV KPTCL SS at Puttenahalli (D.G. Plant) Yelahanka to proposed KPCL 220 kV Gas Power Plant at Puttenahalli in Yelahanka		Map Scale : 1cm=500mts Total Length : 0.223 km, 0.356 km Soil Resistivity : 25,000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
SOUTH WESTERN RAILWAY letter no. – SG/SWR/PTCC/F-2743/1750 dated 27.07.2018					
1	Yelahanka (YNK) – Rajankunte (RNN)	0.1	0.0013	10000	13



नरेश भंडारी/NARESH BHANDARI
मुख्य अभियन्ता/Chief Engineer
केन्द्रीय विद्युत प्राधिकरण/C.E.A.
विद्युत मंत्रालय/Ministry of Power
भारत सरकार/Govt. of India
नई दिल्ली/New Delhi-66

Annex-III

Tele: 23019746

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011


B/46937/Sigs 7(b)/1053 /

14 May 2018

Chief Engineer (Electricity)
State Load & Despatch Centre,
#28, R.C. Cross Road,
Bengaluru - 560009

**PROPOSED 220KV DC LINE FROM EXISTING 220/66/11KV KPTCL SS AT
PUTTENAHALLI (D.G. PLANT) YELAHANKA ATO PROPOSED KPCL 220KV
GAS POWER PLANT AT PUTTENAHALLI IN YELAHANKA BANGALORE
URBAN DIST.**

1. Reference your letter No. CEE/SLDC/PTCC/F-2743/26047-54 DT 17 Mar 2018.
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.


(AV Umdekar)
Lt Col
GSO 1 (Comn)
for SO-in-C

Copy to :-

✓
Chief Engineer (PTCC),
Chief Electrical authority, NREB Complex,
18A, Shaheed Jeet Singh Marg,
Block A, Katwaria Sarai, New Delhi - 110016