

भारत सरकार
भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलप्मेंट प्रभाग
Power Communication Development Division

No. CEA/PCD/PTCC/ORS-212/328-30

Date: 19/03/2019

Divisional Engineer Telecom (PTCC), QA & Inspection (T&D) circle, BSNL, Q.A. Bhavan, EP-GP Block, Sector-V, Salt Lake, Kolkatta-700 091

Subject: PTCC Route Approval for 220kV DC LILO line from Circuit-II (Loc. No. 193) of 220kV Meramundali - Bhanjanagar D/C T/Lat Narasinghpur

## Reference:

BSNL letter no. DE/PTCC/ER/EOR 260720171763 dated 7/11/17

ii) Defense letter no. B/46937/Sig 7(b)/623 dated 10/10/17

Sir.

The low frequency induction on BSNL telecom circuits as per details furnished vide above cited reference (i) has been examined. From topo map it was observed that there is no Railway circuits within 8km boundary of the power line. The average soil resistivity value has been taken as 50000 Ohms-cm, as per data submitted by Power Authority. Voltages likely to be induced on paralleling BSNL telecommunication circuits under SLG (Single Line to Ground) fault condition are enclosed at Annex-I. The screening factors as applicable have been considered. Vide ref. (ii) above, Defense Authority have issued No Objection Certificate (NOC), a copy is enclosed at Annex-II.

Taking above into consideration, kindly issue PTCC Route Approval.

Encl: As above

Yours faithfully,

(Naresh Bhandari) Chief Engineer

## Copy to:

(i) CSTE, East Coast Railway, East Coast Railway Sadan, Samanta Vihar, Bhubaneswar – 751017

(ii) Sr. GM (Construction Zone-I), OPTCL, Technical Building (Ground & 1<sup>st</sup> Floor), Bhoi Nagar, Bhubaneswar – 751 022 (ODISHA)

Mc

ANNEXURE - I

				ANNEXURE -	1
Case No.: ORS-212 Name of the Power line: 220 KV Line From CKT -II (LOC-193) of 220KV Meramundali –Bhanjanagar D/C Power Line to 220/33KV Grid S/s at Narasinghpur Odisa  Map Scale : 1cm=500mts Total Length : 5.048Km. S.R. Value : 50,000 Ohms-cm					
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V. in Volts.
BSNL					
Ref. No.	DE/PTCC/ER/EOR260720171763	DATED:07.11.2	017		
Affected	Blocks & Telcom Circuits Details				
1.	Narasinghpur - Nupatra	)			
2.	Narasinghpur - Basantapur	SIVLe	go than.	430V -	
3.	Narasinghpur - Ghorodia	1	F.	, _	
			$\Lambda_{\Lambda}$		
			1 del		
			नरेश भंडारी/NARES	H BHANDARI	
			मुख्य अभियन्ता/Ch केन्द्रीय विद्युत प्राधि	ETOT /C E A	
			विद्युत मंत्रालय/Mini भारत सरकार/Go नई दिल्ली/New	Ivt. of India	
			14 MANUAL MAN	Demi-66	
					1/1

ANNEX-II odisha

Tele: 23019746

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/623/

1º Oct 2017

Sr. General Manager (Construction) Zone 1 Odisha Power Transmission Corporation Ltd Technical Building Bhoi Nagar, Bhubaneshar – 22

## APPROVAL OF PTCC FOR THE PROPOSED 220KV LILO LINE FROM CKT-II (LOC NO. 193) OF 220 KV MERAMUNDALI – BHANJANAGAR D/C LINE TO 220/33KV GRID SUB-STATION AT NARSINGHPUR

- 1. Reference your letter No Sr. G.M(Const) Zone-I/PTCC/2017-18/220kv LILO Narsinghpur/2857(12) dated 01 Aug 2017.
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

:

(AV Umdekar) Lt Col GSO 1 (Comn) for SO-in-C

Copy to :-

Chief Engineer, (PTCC), CEA, NRPC Complex 18-A, Shaheed Jeet Singh Marg, Katawaria Sarai, New Delhi - 110016 for info and necessary action.