



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट प्रभाग
Power Communication Development Division

No.:CEA/PCD/PTCC/HP-64 / 951-952

Date: 09.09.2019

DET (PTCC), Northern Zone,
Bharat Sanchar Nigam Ltd (BSNL),
O/o PGM(N), Inspection Circle,
CTS Compund, Netaji Nagar,
New Delhi – 110023

Subject: Induced Voltage Calculation in respect of PTCC proposal for 400 KV D/C transmission line from 400/220/66 kV at Wangtoo to LILO point at T-2 and T-3 of 400 kV D/C Wangtoo to Kala Amb transmission line.

Reference: (i) BSNL letter No. DET/PTCC/ND/DV-9582/HP-244/2019-2020 dated 06.09.2019.
(ii) Northern Railway letter no. 342-SIG/1/PTCC dated 06.09.2019.

Sir,
The instant PTCC proposal has been examined. Vide ref. (i) above BSNL have intimated that there are no U/G cable and no armoured OFC within 08 kms of the proposed power line and hence, issued No objection Certificate(NOC). Vide ref.(ii) above, Northern Railway have intimated that there is no Railway line appearing/existing in the route of Transmission line. Hence, Induced Voltage calculation is not required. Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line. In view of this, you are requested to issue provisional PTCC route approval.

Encl.: As above

m/c

राजेश कुमार प्रसाद सिंह
09/09/19.
(R. P. Singh)
Director, PTCC

Copy to:

DGM & Head Trans. Designs, HPPTCL, Anu, Hamirpur (H.P.)-177001.