

#### भारत सरकार

### Government of India

विद्युत मंत्रालय

### Ministry of Power

# केन्द्रीय विद्युत प्राधिकरण

## Central Electricity Authority

पावर कम्युनिकेशन डवलप्मेंट प्रभाग

**Power Communication Development Division** 

No.:CEA/PCD/PTCC/HRA-223/938-946

Date: 02.09.2019

DET (PTCC), Northern Zone, Bharat Sanchar Nigam Ltd (BSNL), O/o PGM(N), Inspection Circle, CTS Compund, Netaji Nagar, New Delhi – 110023

Subject:

Induced Voltage Calculation in respect of PTCC proposal for LILO of one ckt of 220

kV D/C Bastara - Kaul line at 800 kV HVDC Bhadson

Reference:

(i) BSNL letter no. DET/PTCC/ND/DV-9555/HR-835/2019-2020 dated 28.08.2019

(ii) Northern Railway letter no. 342-SIG/1/PTCC dated 29.08.2019

Sir.

The instant PTCC proposal has been examined. Low frequency induction on telecom cables of BSNL and Block & Telecom circuits of Northern Railway with respect to details furnished vide above references has been computed. The Soil Resistivity (SR) value has been taken as 15,000 Ohm-cm. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of Northern Railway under Single Line to Ground fault condition have been computed and are enclosed as Annex – I & II respectively. The screening factors, as applicable, have been considered.

Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line. In view of this, you are requested to issue provisional PTCC route approval.

Encl.: As above

m/c

श्राध्यक्ट प्राप् सिंध (R. P. Singh) Director, PTCC

#### Copy to:

GM (S&T), Northern Railway, Headquarter Office, Baroda House, New Delhi – 110001 (Annex II only)

2. Superintending Engineer, Transmission System Circle, Haryana Vidyut Prasaran Nigam Ltd, Karnal, Haryana - 132001

Case No.: HRA-223

21

Annexure I

Toposheet Scale : 1cm=500mts

: 28.735 Kms

Ohm-cm

Name of the Power Line: LILO of 1-Ckt of 220 KV D/C Bastara-Kaul Line at 600 KV HVDC Bhadson

Total Length S.R Value:

15000

Sl. No.	Name of Telecom Line	LOP in Kms	MC in Ohms	Fault Current (Amps)	IV in Volts
	No. DET/PTCC/ND/DV-9555/HR-835/2019-20				
	BSNL Details			•	
1	Samana bahu to Raipur (100Pr)				
2	Samana bahu to Machuri ( 100 Pr)		,		
3 ,	Nilokheri to Bhutana ( 200 Pr)		•		
4	Nilokheri to Anjanthali( 100Pr)				
5	Nilokheri to Barthal (50 Pr.)				*
6	Nilokheri to Arjaheri ( 100 Pr)				
.7	Nilokheri to Yunuspur ( 100 Pr)				
8	Ramana Ramani to Sambhi (200Pr)				
9	Ramana ramani to Bhola Khalsa( 50 Pr)	/ .			
10	Ramana ramani to Golpura (50 Pr)				
11	Jamba to Brahman majra ( 50 Pr)	IV	LESS	THAN 2	130V
12	Nigdu to Kor ( 100 Pr)				
13	Nigdu to Bir Badalwa( 100 Pr)				
14	Bhadson to Bhadson( 100 Pr)	<u> </u>			
15	Bhadson to Udana ( 100 Pr)				
16	Bhadson to haibatpur(100Pr)				
17	Bhadson bairsal ( 200 Pr)		<u> </u>		<u>.</u>
18	Bhadson to Jhivarheri( 70 Pr)				
19	Bhadson to Swarn Majra (70 Pr)				
20	Bhadson to Rampur (40 Pr)				
	I and the second		1	1	l

Bhadson to Kheri Jatana (40 Pr) 

ANNEXURE - II

Case No.: HRA-223

Name of the Power line: LILO of one ckt of 220 kV D/C

Bastara - Kaul line at 800 kV HVDC Bhadson

Map Scale : 1cm=500mts

Total Length: 28.735 km

Soil Resistivity: 15,000 Ohm-cm

•	S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current	I.V in Volts.
				,	in Amps.	

	Northern Railway letter no. 342-SIG/1/PTCC	dated 29.06.2	2019		
		,			
1	Taraori R/S – Nilokheri R/S	OUT	OUT OF PARALLELISM		
2	Nilokheri R/S – Amin R/S	2.6	0.0061	7200	44
3	Amiri R/S – Kurukshetra R/S	OUT OF PARALLELISM			0

