

**GOVERNMENT OF INDIA
CENTRAL ELECTRICITY AUTHORITY
(MINISTRY OF POWER)
Sewa Bhawan (North Wing), Room No. 622, 6th Floor,
R. K. Puram, New Delhi-110066
Tel. Fax -011-26103246, email: celegal-cea@gov.in
Website: www.cea.nic.in**

PUBLIC NOTICE

In accordance with the Sub-Section (2) of Section 177 of the Electricity Act, 2003, the Central Electricity Authority (CEA) had notified the Regulations *namely* “**Central Electricity Authority (Technical Standards for Construction of Electrical Plants and Electric Lines) Regulations, 2010**” on 20.08.2010. It is now proposed to further amend specific clauses in the said regulations. The proposed draft amendments in the above regulations are available on the CEA Website www.cea.nic.in. The draft amendments of regulations can also be inspected in the office of Chief Engineer (Legal), Sewa Bhawan (North Wing), Room No. 622, 6th Floor, R. K. Puram, New Delhi-110066 on any working day till **04th April, 2019 between 1100 hrs to 1600 hrs.**

All the Stakeholders including the public are requested to send their comments on the draft regulations to Chief Engineer (Legal), Sewa Bhawan (North Wing), Room No. 622, 6th Floor, R. K. Puram, New Delhi-110066 by post or through e-mail latest by **4th April, 2019.**

**(P C Kureel)
Secretary, CEA**

Amendment proposed in Central Electricity Authority (Technical Standards for Construction of electrical Plants and Electric Lines) Regulations, 2010

- In the said Regulations, after Regulation 74(1) the following Regulation 74(1 A) shall be inserted, namely:-

For consumers supplied at voltage not exceeding 650 V (except mines and oil fields), the r.m.s value of Voltage at the point of commencement of supply of electricity, shall be as follows:

- (i) Single Phase 230 Volts between phase and neutral.
- (ii) Three Phase 400 Volts between phases.

Provided that the permissible variation in voltage at the point of commencement of supply of electricity, shall be as per relevant Indian Standard.

Explanation:- For the purpose of sub-regulation 74(1A), the expression "point of commencement of supply of electricity" shall mean the point at the outgoing terminal of meter installed at the consumer premises.