FORMAT-27 Page 1/4 PERIODICITY- DAILY SUBMISSION BY- 0900 HRS

Pegional Pow	er Supply Position	(Daily Operation	Penort) in		Pegion	for		SUBMIS _ (Date)
	ting			(Time)	Region	101		_ (Bate)
1. Regional Availa	bility/ Demand/ Shortag	e				_		
			*PEAK Hrs	**Off-Peak Hrs	DAY ENERGY			
	Particulars		(MW)	(MW)	(MkWh)	1		
	Regional Availab	ility	()	()	(1		
	Regional Demand					1		
	Regional Shortag					1		
		,	- U	II.	1	_		
2 A. State Require	ment (Net Energy - MkV	Vh)						
States	Thermal	Hydro	IPPs	CPPs	Net Sch. (From Grid)	Drawl (From Grid)	Availability	Requireme nt Met
						,		
Total								
		•						
2 B. State Demand	PEAK Hrs	(Hrs)	Off-Peak Hrs	Hrs)		Day Peak		
	PEARINS	Shortage at 50.00	OII-Feak HIS	Shortage at		Day Feak	Shortage at	_
States	Demand Met	Hz	Demand Met	50.00 Hz	Demand Met	Time (Hrs)	50.00 Hz	
Otatoo			20				00:00 1:12	_
Region			1			I		

FORMAT-27 Page 2/4

3. Inter-Regional Exchanges - Physical Flows [Import(+)/ Export(-)]

	Peak Hrs	Off-Peak Hrs		Maximum	Inter-Change		
	(Hrs)	(Hrs)	Import	Time	Export	Time	Net Energy
Elements	(MW)	(MW)	(MW)	(Hrs)	(MW)	(Hrs)	(MkWh)
A. Northern Region Link	S		•				
1.							
2.							
Sub Total NR Links							
B. Western Region Links	3		-				
1.							
2.							
Sub Total WR Links							
C. Southern Region Link	s		-				
1.							
2.							
Sub Total SR Links							
D. Eastern Region Links							
1.							
2.							
Sub Total ER Links							
Total (All Links)							

4. Short-Term Open Access Transaction for the Previous Day (MkWh)

S. No.	From (Including Region)	To (Including Region)	Name of the Trader	Net Exchange
1.				
2.				
4.				
5.				
6.				

5. Frequency Profile

			% of Time				
Frequency Range	< 48.5 Hz	< 49.0 Hz	< 49.5 Hz	49.0 - 50.5 Hz	> 50.0 Hz	> 50.5 Hz	> 51.0 Hz
%							

Instantaneous	Maximum	Instantaneou	ıs Minimum	15-Minutes Bl	ock Maximum	15-Minutes Bl	ock Minimum	Day Average	Frequency Variation Index (FVI [#])
Hz	Time	Hz	Time	Hz	Time	Hz	Time	Hz	

6. Voltage Level at Critical Sub-Stations®

		400 I	ίV		220 KV			
	Maximum		Minimum		Maximum		Minimum	
Sub-Stations	kV	Time	kV	Time	kV	Time	kV	Time
•								

FORMAT-27 Page3/4

7. Major Reservoir Parti	culars									
		Designed		Pres	sent	Last	Year	Last	Day	Month
										Program
										me
	MDDL	FRL	Energy	Level	Energy	Level	Energy	Inflows	Uses	Usage
Reservoirs	(metre)	(metre)	(MkWh)	(metre)	(MkWh)	(metre)	(MkWh)	(MkWh)	(MkWh)	(MkWh)

8. Grid Disturbance/ Significant Events (If Any)

9. System Constraints (If Any

- 10. Weather Conditions Prevailed on the Day of Report & for the Following Day:
- 11. Generating Units Outage Status in ______ Region

As on Date Time 6:00 Hours

11A. Generating Units Revived During Last 24 Hrs. (06:00 Hrs of (Date) to 06:00 Hrs (Date))

					Outage		Revival	Reasons of
S.No.	Stations	Unit No.	Capacity (MW)	Date	Time	Date	Time	outage
	Central Sector							
1.								
2.								
3.								
4.								
	State Sector	•	•	-	•	•	•	
1.								
2.								
3.								
4.								

11B. Generating Units Under Outage (Status at 06:00 Hrs of (Date))

S.No.				C	Outage	Re	vival	Reasons of
5.NO.	Station	Unit No.	Capacity (MW)	Date	Time	Date	Time	outage
	Central Sector							
1.								
2.								
3.								
4.								
	State Sector							
1.								
2.								
3.								
4.								

Total	(MANA/)		
Total	(MW)		

FORMAT-27 Page4/4

12. Transmission Lines Outage Status in Southern Region

As on Date

Time

6:00 Hours

12 A. Transmission Lines Revived During Last 24 Hrs. (06:00 Hrs of

(Date) to 06:00 Hrs

(Date))

			Out	tage	Rev	vival	Reasons of
S.No.	Element Name	Element Type	Date	Time	Date	Time	outage
		Ce	entral Transmissio	n Utility			
1.							
2.							
3.							
4.							
		S	tate Transmission	Utility			
1.							
2.							
3.							
4.							

12 B. Transmission Lines Under Outage (Status at 06:00 Hrs of

(Date))

			Outage		Revival		Reasons of
S.No.	Element Name	Element Type	Date	Time	Date	Time	outage
Central Transmission Utility							
1.							
2.							
3.							
4.							
State Transmission Utility							
1.							
2.							
3.							
4.							

FORMAT-25 RLDCs

@Critical Sub-Station: Sub-Station Where the Steady-State Voltage Lies Outside the Limit of ± 10% of the Normal Value.

FVI =

$$\sum_{n=0}^{\infty} \frac{\sqrt{(50-x_n)^2}}{n}$$

where n= number of readings x_n = frequency at n^{th} reading

^{*}Peak Hours: The Designated Peak Hour of a Region.

^{**}Off-Peak Hours: The Designated Off-Peak Hour of a Region.