



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केंद्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत प्रणाली योजना एवं मूल्यांकन प्रभाग-2  
Power System Planning Appraisal Division-II  
सेवा भवन, रा. क. पुरम, नयी दिल्ली -110066  
Sewa Bhawan, R. K. Puram, New Delhi-110066

[ISO: 9001:2008]

No. 66/5/ PSPA-II /2016/ 344 - 355

Dated: 20-10-2016

To

(As per list Enclosed)

**Subject: 2<sup>nd</sup> Corrigendum issued for minutes of 18<sup>th</sup> meeting of Standing Committee on Power System Planning of ER held on 13.06.2016 at Kolkata-regarding.**

Sir/Madam,

Minutes of the meeting for the 18<sup>th</sup> Standing Committee Meeting on Power System Planning in Eastern Region held on 13.06.2016 at Kolkata were issued vide CEA letter No.66/5/PSPA-2/2016/139-150 dated 19.08.2016. The corrigendum issued for **Item No 6 “Ranchi(New)-Purulia PSP 400 kV D/c line under ERSS-VII”** of the minutes uploaded on the website are as follows:

1. Para 6.12 is added as follows:

**6.12. In view of above discussions, members approved following final and Interim connections:**

**1. Ranchi (New)- Purulia 400 kV D/c line**


- (i) **Interim arrangement:** Ranchi (New)-Purulia 400 kV D/C line will be connected with one circuit of Purulia PSP-Arambagh 400 kV D/C line at suitable location, so as to form Ranchi (New)-Purulia PSP (about 115 km), Ranchi (New)-Arambagh (about 327 km) and Purulia PSP-Arambagh 400 kV lines. This will be implemented by M/s PKTCL.
- (ii) **Final arrangement:** Termination of Ranchi (New)- Purulia (PSP) 400 kV D/c line at New Purulia GIS (under construction by WBSETCL) substation, so as to form Ranchi(New) Purulia (New) GIS (WBSETCL) 400 kV D/C line. This line is being implemented by M/s PKTCL.



2. **Kharagpur (WB)-Chiabasa (PG) 400 kV D/c line**

- (i) **Interim arrangement:** Interconnection of Kharagpur (WB)-Chiabasa (PG) 400 kV D/C line by LILO of one circuit of Kharagpur (WB)-Kolaghat 400 kV D/C line near Kharagpur end, till the 400 kV bays at Kharagpur (WB) are commissioned by WBSETCL as deposit work for POWERGRID. The interim arrangement will be implemented by M/s PKTCL with no additional cost to be recovered as tariff.

Yours faithfully,

  
(Ravinder Gupta)  
Director (PSPA-II)

Copy for kind information to:

- 1) PPS to Chairperson/Member(PS), CEA

**List of addressee:**

1. Member Secretary, Eastern Regional Power Committee, 14, Golf Club Road, Tollygange, <b>Kolkata-700033.</b> Tel. No. 033-24235199 Fax No.033-24171358	2. Director (Projects), Power Grid Corporation of India "Saudamini" Plot No. 2, Sector-29, <b>Gurgaon-122001</b> Tel. No. 0124-2571816 Fax No.0124-2571932
3. Executive Director (System), Damodar Valley Corporation DVC Towers, VIP Road, <b>Kolkata-700054.</b> Tel. 033-23557939 Fax No. 033-23554841	4. Managing Director, Bihar State Power Transmission Company, Vidyut Bhavan, Baily Road, <b>Patna-800021.</b> Tel. 0612-2504442 Fax No. 0612-2504557
5. Director (Transmission), Orissa Power Transmission Corporation Ltd, Jan path, <b>Bhubaneswar-751022.</b> Tel. No. 0674-2540098 Fax No.0674-2541904	6. Director (System Operation), West Bengal State Electricity Transmission Company Ltd, Vidyut Bhavan, 5th Floor, Block-D, Bidhannagar, Sector-II, <b>Kolkata-700091.</b> Tel. No. 033-23370206 Fax No.033-23342243
7. Principal Chief Engineer cum Secretary, Power Department Government of Sikkim, Sikkim. Tel. No. 03592-2022440 Fax No.03592-202927	8. Managing Director, Jharkhand Urja Sancharan Nigam Limited Engineering Building, H.E.C., Dhurwa, Ranchi-834004. Fax-0651-2400799

<p>9. CEO, POSOCO B-9, Qutub Institutional Area, Katwaria Sarai, New Delhi-110016 <b>Tel. No. 26852843</b> <b>Fax No. 2626524525, 26536901</b></p>	<p>10. Director (Technical), NTPC Limited, Engineering Office Complex, A-8, Sector 24, <b>Noida.</b> <b>Tel. No. 24362050</b> <b>Fax No. 24362421</b></p>
<p>11. Executive Director (T&amp;RE), NHPC Ltd, NHPC Office complex, Sector 33, <b>Faridabad-121003.</b> <b>Tel. No. 0129-2255805</b> <b>Fax No. 0129-2277523</b></p>	

**Copy to:**

1. COO (CTU), PGCIL, Saudamini, Plot No. 2, Sector-29, Gurgaon-122001. **Fax No. 0124-2571760/62)**
2. General Manager, Eastern Regional Load Dispatch Center, 14, Golf Club Road, Tollygange, Kolkata-700033. **Tel No. 033-24235867, Fax No. 033-24235809**
3. Director (Commercial), Grid Corporation of Orissa Ltd, Jan path, Bhubaneshwar-751022. **Tel. No. 0674-2541127, Fax No. 0674-254190**