

Central Electricity Authority
System Planning & Project Appraisal Division
Sewa Bhawan, R K Puram, New Delhi – 110066

No. 51/4/SP&PA-2008/ 449-458

Date: June 02, 2008

To

1.The Member Secretary, Southern Regional Power Committee, 29, Race Course Cross Road, Bangalore 560 009. FAX : 080-22259343	2.The Director (Projects), Power Grid Corp. of India Ltd. “Saudamini”, Plot No.2, Sector-29, Gurgaon 122 001, Haryana. FAX : 95124-2571932
3.The Director (Transmission), Transmission Corp. of Andhra Pradesh Ltd., Vidyut Soudha, Hyderabad – 500 082. FAX : 040-66665137	4.The Director (Transmission), Karnataka State Power Transmission Corp.Ltd., Cauvery Bhawan, Bangalore 560 009. FAX : 080 -22228367
5.The Member (Transmission), Kerala State Electricity Board, Vidyuthi Bhawanam, Pattom, P.B. No. 1028, Thiruvananthapuram - 695 004. FAX : 0471-2444738	6. Member (Distribution), Tamil Nadu electricity Board (TNEB), 6 th Floor, Eastern Wing, 800 Anna Salai, Chennai - 600002. FAX : 044-28516362
7.The Director (Power), Corporate Office, Block – I, Neyveli Lignite Corp. Ltd., Neyveli , Tamil Nadu – 607 801. FAX : 04142-252650	8.The Superintending Engineer –I, First Floor, Electricity Department, Gingy Salai, Puducherry – 605 001. FAX : 0413-2334277/2331556
9. Director (Projects), National Thermal Power Corp. Ltd. (NTPC), NTPC Bhawan, Core-7, Scope Complex, Lodhi Road, New Delhi-110003. FAX-011-24360912	10. Director (Operations), NPCIL, 12 th Floor, Vikram Sarabhai Bhawan, Anushakti Nagar, Mumbai – 400 094. FAX : 022- 25991258

Sub: 25th meeting of the Standing Committee on Power System Planning of Southern Region
- Minutes of the meeting – **Issuing of Corrigendum (No# 2)**

Sir,

Minutes of 25th meeting of the Standing Committee on Power System Planning of Southern Region were issued vide our letter of even number dated 24-04-2008. POWERGRID has given observation on Item No. 4 of the minutes, regarding “Advancement of Warangal 400kV S/S”. Based on the observation of POWERGRID, a corrigendum of the minutes of 25th meeting is enclosed at Annex-I.

This issues with the approval of Member(PS).

Yours faithfully,

Encl: Corrigendum (No# 2) to Minutes

(Pardeep Jindal)
Director (I/c) (SP&PA-III)
(Telephone No. 011 26732325)

**Standing Committee on Power System Planning of Southern Region
(SCPSP SR)**

Corrigendum (No# 2) to Minutes of the 25th Meeting of the Standing Committee on Power System Planning of Southern Region held on March 28, 2008 at Hyderabad

Minutes of 25th meeting of the Standing Committee on Power System Planning of Southern Region were issued vide our letter of even number dated April 24, 2008. GM, POWERGRID, vide letter no C\ENG\SEF\S\Standing Committee dated May 30, 2008, has given observation on Item No. 4.0 regarding “Advancement of Warangal 400kV S/S” of the issued minutes.

Based on the observation of POWERGRID, **the Para No. 4.2** of the Minutes of 25th meeting of the Standing Committee on Power System Planning of Southern Region, **is replaced** as given below:

- 4.2** GM, POWERGRID informed that the requirement of Warrangal 400/220 kV substation was for strengthening of the system arising out of growth of demand and redistribution of power flows. Further, this substation was made part of ATS of Neyveli TS-II Expansion as this requirement was coming in the time frame of Neyveli TS-II Expansion generation project. However, now as the generation project is getting delayed, the Warrangal 400/220 kV substation alongwith the LIL0 of Ramagundam – Khammam 400 kV may be completed ahead of commissioning of Neyveli TS-II project. APTRANSCO informed that the 220kV works for drawing power from Warangal were in progress, however, the precise completion schedule of 220 kV shall be informed. GM, POWERGRID informed that in case constituents agree to bear the transmission charges, POWERGRID could commission the Warangal substation matching with the 220kV works of APTRANSCO. It was decided that matter would be discussed in the next SRPC meeting for sharing of transmission charges for the period of advancement.
-