



Government of India  
Ministry of Power  
Central Electricity Authority  
SP&PA Division



Sewa Bhawan, R. K. Puram, New Delhi-110066

[ISO: 9001:2008]

No. 100/1/EC (32) 2013-SP&PA/

Dated: 15<sup>th</sup> May, 2015

To

1. Member (Power System)  
Central Electricity Authority  
Sewa Bhawan, R.K. Puram,  
New Delhi – 110 066.
2. Member (Economic & Commercial),  
Central Electricity Authority  
Sewa Bhawan, R.K. Puram,  
New Delhi – 110 066
3. Adviser,  
Planning Commission,  
Parliament Street,  
New Delhi – 110 001.
4. Director (Transmission)  
Ministry of Power,  
Shram Shakti Bhawan, Rafi Marg,  
New Delhi – 110 001.
5. Director (Projects),  
Power Grid  
Saudamini, Plot No. 2, Sector-29,  
Gurgaon – 122 001.
6. Shri V. V. R. K. Rao  
Former Chairperson, CEA  
B-9/C, DDA Flats, Maya Puri,  
New Delhi -110 064.
7. Shri Ravinder  
Former Chairperson & Member (Power  
System), CEA  
147, Bhagirathi Apartment,  
Sector-9, Rohini, Delhi – 110 085.  
(Tel. 9971568444).

**Subject: 32<sup>nd</sup> meeting of the Empowered Committee on Transmission – Corrigendum reg.**

Sir,

The minutes of the 32<sup>nd</sup> meeting of Empowered Committee on Transmission held on 17<sup>th</sup> January 2014 were circulated vide CEA letter of even no. dated 6<sup>th</sup> February 2014.

It is stated that the note under Para 8 (8) of the above MoM on “**System strengthening for IPPs in Chhattisgarh and other generation projects in Western Region**”, was inadvertently recorded as “CTU would provide 2 no. of 400 kV line bays at the switchyard of Vindhyachal –V TPS of NTPC”. The same may please be read as follows:

- *M/s NTPC to provide space for 2 no. of 400 kV line bays at the switchyard of Vindhyachal –V TPS*
- *Transmission service provider to provide 2 no. of 400 kV line bays at the switchyard of Vindhyachal –V TPS of NTPC*

Yours faithfully,

  
(K. K. Arya)  
Chief Engineer

**Copy to:**

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi – 110 001.
- (ii) COO (CTU), POWERGRID, 'Saudamini', Plot No.2, Sector – 29, Gurgaon – 122 001 (Haryana)
- (iii) CEO, RECTPCL, 12-21, Upper Ground Floor, Antriksh Bhawan, 22, KG Marg, New Delhi – 110 001.
- (iv) CEO, PFC Consulting Ltd, First Floor, Urjanidhi, 1 Barakhmba Lane, New Delhi -110001 (Fax-011-23456170)