



भारत सरकार / Government of India
विद्युत मंत्रालय / Ministry of Power
केन्द्रीय विद्युत प्राधिकरण / Central Electricity Authority
प्रणाली योजना एवं परियोजना मूल्यांकन प्रभाग
System Planning & Project Appraisal Division
सेवा भवन आर. के. पुरम, नई दिल्ली-110066
वेबसाइट / Website: www.cea.nic.in



Sewa Bhawan, R. K. Puram, New Delhi-110066 [ISO: 9001:2008]

No. 26/10/2013-SP&PA/

Date: 5th March, 2013

To,

- | | | | |
|---|----------------------------------------------------------------------------------------------------------------------------------------------------------|----|--------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | The Member (PS),
Central Electricity Authority,
Sewa Bhawan, R. K. Puram,
New Delhi-110066 | 8 | Chief Engineer (Trans),
Nuclear Power Corp. of India Ltd.,
9S30, VS Bhavan, Anushakti Nagar,
Mumbai-400094
Fax 022-25993570 |
| 2 | The Member Secretary,
Western Regional Power Committee,
MIDC Area, Marol, Andheri East, Mumbai
Fax 022 28370193 | 9 | The Executive Director (Engg.),
NTPC Ltd., Engg. Office Complex,
A-8, Sector-24, NOIDA 201301
Fax 0120-2410201/2410211 |
| 3 | The Director (Projects),
Power Grid Corp. of India Ltd.,
"Saudamini", Plot No. 2, Sector-29,
Gurgaon-122001
Fax 0124-2571760/2571932 | 10 | The Chief Engineer,
Electricity Department,
The Government of Goa, Panaji
Fax 0832 2222354 |
| 4 | Chairman and Managing Director,
MPPTCL, Shakti Bhawan,
Rampur, Jabalpur-482008
Fax 0761 2664141 | 11 | Executive Engineer (Projects)
UT of Dadra & Nagar Haveli,
Department of Electricity, Silvassa
Ph. 0260-2642338/2230771 |
| 5 | The Managing Director,
CSPTCL, Dangania,
Raipur (CG)-492013
Fax 0771 2574246/ 4066566 | 12 | Executive Engineer
Administration of Daman & Diu (U.T.)
Department of Electricity
Moti Daman-396220
Ph. 0260-2250889, 2254745 |
| 6 | The Managing Director,
GETCO, Sardar Patel Vidyut Bhawan,
Race Course, Baroda-390007
Fax 0265-2338164 | 13 | GM, WRLDC
Plot no F-3, MIDC Area, Msarol,
Andheri(East) Mumbai-400093
Fax no 022-28235434 |
| 7 | Director (Operation),
MAHATRANSCO, 'Prakashgad', Plot
No.G-9, Bandra-East, Mumbai-400051
Fax 022-26390383/26595258 | 14 | CEO, POSOCO
B-9, Qutab Institutional Area, Katwaria Sarai
New Delhi-110016
Fax 011-26852747 |


Sub: 35th meeting of the Standing Committee on Power System Planning in Western Region

Sir,

The minutes of the 35th meeting of the Standing Committee on Power System Planning in Western Region held on 3rd January 2013 at M.P Hall, Power Grid Township, Gurgaon were issued our letter no.26/10/2013-SP7PA/74-87 dated 04.02.2013.

Based on the comments received from POWERGRID, corrigendum to the above minutes is enclosed at Annexure-I. The same is available at CEA website (www.cea.nic.in at the following link Home page-Wing Specific Document-Power Systems-Standing Committee on Power System Planning-Western Region).

Yours faithfully,


(Ravinder Gupta)
Director

Corrigendum to minutes of the 35th Meeting of Standing Committee on Power System Planning in Western Region held on Thursday 3rd January 2013

POWERGRID vide their letter no. C/SEFW/OA/SCM dated 5th March 2013 has requested for modification of item no. 17.10 of minutes of 35th Standing Committee meeting of WR held on 03.01.2013. POWERGRID had stated that during the meeting it was agreed that considering the advantages of STATCOM over SVC technology, POWERGRID shall explore the installation of STATCOM at the location identified for dynamic compensation.

Accordingly, the modified **item no. 17.10** of minutes of the 35th meeting of the Standing Committee on Power System Planning in Western Region held on 3rd January 2013 at M.P Hall, Power Grid Township, Gurgaon is as given under:

- "17.10 After further discussions Static Var Compensators / STATCOMs of ± 400 MVAR was agreed at Gwalior, Aurangabad, Sholapur and Satna substations of POWERGRID, in first phase, in Western Region. The choice of SVCs / STATCOMs would be evaluated through relevant studies for technology selection."