

भारत सरकार/ Government of India
विद्युत मंत्रालय / Ministry of Power
केंद्रीय विद्युत प्राधिकरण/ Central Electricity Authority
प्रणाली योजना एवं परियोजना मूल्यांकन प्रभाग
System Planning & Project Appraisal Division
सेवा भवन, आर.के. पुरम, नई दिल्ली - 110066
Sewa Bhawan, R.K. Puram, New Delhi - 110066

No. 51/4/(37th)/SP&PA-2014/1796 - 1809

Date: 09-October-2014

Sub: **37th meeting** of the Standing Committee on Power System Planning of **Southern Region - Corrigendum to Minutes** of the meeting


Sir,

The minutes of **37th meeting** of the Standing Committee on Power System Planning of Southern Region were issued vide our letter No. 51/4/(37th)/SP&PA-2014/1729-42 dated 22 September, 2014. Based on observations/comments received from SRLDC and POSOCO, corrigendum to the above minutes is enclosed at Annex-I.

It is also available at CEA's website (www.cea.nic.in).

This is issued with the approval of Member(Power System), CEA.

Yours faithfully,


09/10/2014
(प्रदीप जिंदल /Pardeep Jindal)

निदेशक (प्र यो एवं प म्)/Director (SP&PA) Division,
(Tel: 011-26198092, Fax: 011-26102945)

To

1. The Member Secretary, Southern Regional Power Committee, 29, Race Course Cross Road, Bangalore 560 009. FAX : 080-22259343	2. The Director (Projects), Power Grid Corp. of India Ltd. "Saudamini", Plot No.2, Sector-29, Gurgaon 122 001, Haryana. FAX : 95124-2571932
3. CEO, POSOCO, B-9, Qutub Institutional Area, Katwaria Sarai, New Delhi-110016	4. The Director (Transmission), Karnataka State Power Trans. Corp.Ltd., Cauvery Bhawan, Bangalore - 560 009. FAX : 080 -22228367

5. The Director (Transmission), Transmission Corp. of Andhra Pradesh Ltd., (APTRANSCO) Vidyut Soudha, Hyderabad – 500 082. FAX : 040-66665137	6. The Director (Grid Transmission and Management), Transmission Corp. of Telangana Ltd., (TSTRANSCO) Vidyut Soudha, Khairatabad Hyderabad – 500 082. FAX : 040-23321751
7. The Member (Transmission), Kerala State Electricity Board, Vidyuthi Bhawanam, Pattom, P.B. No. 1028, Thiruvananthapuram - 695 004. FAX : 0471-2444738	8. Member (Distribution), Tamil Nadu electricity Board (TNEB), 6 th Floor, Eastern Wing, 800 Anna Salai, Chennai - 600002. FAX : 044-28516362
9. The Director (Power), Corporate Office, Block – I, Neyveli Lignite Corp. Ltd., Neyveli , Tamil Nadu – 607 801. FAX : 04142-252650	10. The Superintending Engineer –I, First Floor, Electricity Department, Gingy Salai, Puducherry – 605 001. FAX : 0413-2334277/2331556
11. Director (Projects), National Thermal Power Corp. Ltd. (NTPC), NTPC Bhawan, Core-7, Scope Complex, Lodhi Road, New Delhi-110003. FAX-011-24360912	12. Director (Operations), NPCIL, 12 th Floor, Vikram Sarabhai Bhawan, Anushakti Nagar, Mumbai – 400 094. FAX : 022- 25991258

Copy to:

1.	The Director (Projects), Power Grid Corp. of India Ltd. “Saudamini”, Plot No.2, Sector-29, Gurgaon 122 001, Haryana. FAX : 95124-2571932
2.	GM, SRLDC, 29, Race Course Cross Road, Bangalore 560 009 FAX – 080-22268725

Corrigendum#1:

Corrigendum to Minutes of 37th Meeting of the Standing Committee on Power System Planning in Southern Region (SCPSPSR) held on 31st-July-2014 at NRPC, Katwaria Saria, New Delhi

The minutes of **37th meeting** of the Standing Committee on Power System Planning of Southern Region were issued vide our letter No. 51/4/(37th)/SP&PA-2014/1729-42 dated 22 September, 2014. Following corrigendum is issued based on observations/comments received from SRLDC, POSOCO received vide their letters No i) एसआरएलडीसी/अमप्र/2014 ii) NLDC/Planning/761 dated 24th Sep, 2014

Corrigendum to para 4.4 of the minutes: The para 4.4 is modified as given below:

4.4 APTRANSCO informed that the transmission system associated with evacuation of Hinduja Power Project shall be completed in a year. SRLDC stated that since there are no loads at Narsaraopeta, the combined power from gas generation in Vemagiri area and Hinduja units may be reduced. In this context SRLDC informed that it would be difficult to accommodate Vemagiri gas generation more than 600 MW along with full import at Gazuwaka and Hinduja generation. SRLDC informed that in such condition the import at Gazuwaka may have to be reduced or ISGS in Vizag area may have to be curtailed. APTRANSCO informed that in case the full ATS (including strengthening) is not available the generation at Hinduja or Gas generation at Vemagiri would be curtailed. Representative from NTPC also emphasised that ISGS should not be reduced to accommodate evacuation of plant with incomplete ATS. APTRANSCO informed that as a new capital of Andhra Pradesh is being envisaged to be built in the Narsaraopeta/Vijayawada area, the load in the area is likely to increase.

Corrigendum to para 12.3 of the minutes: The para 12.3 is modified as given below:

12.3 POSOCO suggested that ‘One and half breaker’ may be considered in place of ‘Double bus’ scheme for increased reliability, which was agreed.

Corrigendum to para 17.13 of the minutes: The para 17.13 is modified as given below

17.13 ED, SRLDC informed that as far as System Operator is concerned more lines are advantages. Hence, both 765kV Vemagiri- Khammam – Hyderabad as well as 765kV Vemagiri-Chilikaluripeta- Cuddapah may be considered for implementation.