

भारत सरकार/ Government of India  
विद्युत मंत्रालय / Ministry of Power  
केंद्रीय विद्युत प्राधिकरण/ Central Electricity Authority  
प्रणाली योजना एवं परियोजना मूल्यांकन प्रभाग  
System Planning & Project Appraisal Division  
सेवा भवन, आर.के. पुरम, नई दिल्ली - 110066  
Sewa Bhawan, R.K. Puram, New Delhi - 110066

No. 51/4/(38<sup>th</sup>)/SP&PA-2015/1318-32

Date: 9-June-2015

Sub: **38th meeting** of the Standing Committee on Power System Planning of **Southern Region - Corrigendum to Minutes** of the meeting


Sir,

The minutes of **38th meeting** of the Standing Committee on Power System Planning of Southern Region were issued vide our letter No. 51/4/(38<sup>th</sup>)/SP&PA-2015/731-744 dated 23 March, 2015. Based on observations/comments received from TANTRANSOCO, corrigendum to the above minutes is enclosed at Annex-I.

It is also available at CEA's website ( www.cea.nic.in ).

This is issued with the approval of Member(Power System), CEA.

Yours faithfully,

  
(प्रदीप जिंदल /Pardeep Jindal)

निदेशक (प्र यो एवं प मू)/Director (SP&PA) Division,  
(Tel: 011-26198092, Fax: 011-26102945)

To

1. The Member Secretary, Southern Regional Power Committee, 29, Race Course Cross Road, <b>Bangalore 560 009.</b> FAX : 080-22259343	2. The Director (Projects), Power Grid Corp. of India Ltd. "Saudamini", Plot No.2, Sector-29, <b>Gurgaon 122 001, Haryana.</b> FAX : 95124-2571932
3. CEO, POSOCO, B-9, Qutub Institutional Area, Katwaria Sarai, <b>New Delhi-110016</b>	4. The Director (Transmission), Karnataka State Power Trans. Corp.Ltd., Cauvery Bhawan, <b>Bangalore - 560 009.</b> FAX : 080 -22228367

5. The Director (Transmission), Transmission Corp. of Andhra Pradesh Ltd., (APTRANSCO) Vidyut Soudha, <b>Hyderabad – 500 082.</b> FAX : 040-66665137	6. The Director (Grid Transmission and Management), Transmission Corp. of Telangana Ltd., (TSTRANSCO) Vidyut Soudha, Khairatabad <b>Hyderabad – 500 082.</b> FAX : 040-23321751
7. The Member (Transmission), Kerala State Electricity Board, Vidyuthi Bhawanam, Pattom, P.B. No. 1028, <b>Thiruvananthapuram - 695 004.</b> FAX : 0471-2444738	8. Member (Distribution), Tamil Nadu electricity Board (TNEB), 6 <sup>th</sup> Floor, Eastern Wing, 800 Anna Salai, <b>Chennai - 600002.</b> FAX : 044-28516362
9. The Director (Power), Corporate Office, Block – I, Neyveli Lignite Corp. Ltd., <b>Neyveli , Tamil Nadu – 607 801.</b> FAX : 04142-252650	10. The Superintending Engineer –I, First Floor, Electricity Department, Gingy Salai, <b>Puducherry – 605 001.</b> FAX : 0413-2334277/2331556
11. Director (Projects), National Thermal Power Corp. Ltd. (NTPC), NTPC Bhawan, Core-7, Scope Complex, Lodhi Road, <b>New Delhi-110003.</b> FAX-011-24360912	12. Director (Operations), NPCIL, 12 <sup>th</sup> Floor, Vikram Sarabhai Bhawan, Anushakti Nagar, <b>Mumbai – 400 094.</b> FAX : 022- 25991258

**Copy to:**

1.	COO(CTU-Plg), Power Grid Corp. of India Ltd. “Saudamini”, Plot No.2, Sector-29, <b>Gurgaon 122 001, Haryana.</b> FAX : 95124-2571932
2.	GM, SRLDC, 29, Race Course Cross Road, <b>Bangalore 560 009</b> FAX – 080-22268725

Corrigendum#1:

**Corrigendum to Minutes of 38th Meeting of the Standing Committee on Power System Planning in Southern Region (SCPSPSR) held on 7 March-2015 at NRPC, Katwaria Saria, New Delhi**

---

1. The minutes of **38th meeting** of the Standing Committee on Power System Planning of Southern Region were issued vide our letter No. **51/4/(38<sup>th</sup> )/SP&PA-2015/731-744 dated 23 March, 2015.**
2. Based on observations/comments received from TANTRASCO vide their letters No **CE/Plg.&R.C./SE/SS/EE1/AEE1/F.38<sup>th</sup> Stg Comm Modification/D.172 dt 5.5.2015** following corrigendum has been suggested
  - 2(i) *Modification suggested by TNEB to the earlier minuted **para 2.4** of the minutes of 38<sup>th</sup> meeting of SCPSPSR is given below ('deletion' in strikethrough and 'addition' in italics)*
    - 2.4** Accordingly, the minutes of 37<sup>th</sup> Standing Committee of Power System Planning of Southern Region along with the Corrigendum, as circulated were confirmed.  
  
Further, the scope under Connectivity for Udangudi Power Project Stage-I (2x660MW) of Para 3.8 of the Minutes is now modified as below:  
Connectivity for Udangudi Power Project Stage-I (2x660MW):
      - (i) 400kV DC Quad line to the Udangudi Pooling station.
      - (ii) 2X125 MVA<sub>r</sub>, 400kV bus reactor at Udangudi Pooling station. *Udangudi Stage- I switchyard.*
  - 2(ii) *Modification suggested by TNEB to the earlier minuted **para 8.3** of the minutes of 38<sup>th</sup> meeting of SCPSPSR is given below: ('deletion' in strikethrough and 'addition' in italics)*
    - 8.3** TNEB informed that reactor at Kayathar end of Kayathar- Karaikudi line was not shifted and instead a new reactor was installed at ~~Mettur Stage III end~~ *Thiruvalem end* of Thiruvalem- MTPS Stage III 400kV D/C line
3. In view of above, the **Para 2.4 and Para 8.3** are being modified as given below:
  - Para 2.4:** Accordingly, the minutes of 37<sup>th</sup> Standing Committee of Power System Planning of Southern Region along with the Corrigendum, as circulated were confirmed.  
  
Further, the scope under Connectivity for Udangudi Power Project Stage-I (2x660MW) of Para 3.8 of the Minutes is now modified as below:  
Connectivity for Udangudi Power Project Stage-I (2x660MW):
    - (i) 400kV DC Quad line to the Udangudi Pooling station.
    - (ii) 2X125 MVA<sub>r</sub>, 400kV bus reactor at Udangudi Stage- I switchyard
  - Para 8.3 :** TNEB informed that reactor at Kayathar end of Kayathar- Karaikudi line was not shifted and instead a new reactor was installed at Thiruvalem end of Thiruvalem- MTPS Stage III 400kV D/C line.