



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट प्रभाग
Power Communication Development Division

No. CEA/PCD/106th CLPTCC Meeting/2018/

Date: 15-May-2018

To,

All Central PTCC Members

(As per attached list)

Subject: Additional agenda points 106th Central Level Power and Telecommunication Committee (CLPTCC) meeting –reg:

Sir,

In continuation to our letter of even no. dated 1st May 2018, the additional Agenda points received subsequently are attached. A copy of letter from Telangana Transco is also attached at Annexure-V. Telangana Transco has furnished suggestions/ feedback regarding computerization of PTCC process.

(S.P. Abraham)

Director.

Additional Agenda Points for 106th CLPTCC meeting to be held at Mahabaleshwar, Maharashtra 25/05/2018

D.1. Agenda from PGCIL, SRTS-II

PGCIL, SRTS-II vide mail dated 25/04/2018 (copy enclosed as **Annexure-I**) has sent agenda for the meeting.

Members may deliberate

D.2. Agenda from PGCIL, SRTS-I

AGM, PGCIL, SRTS-II vide mail dated 02/05/2018 (copy enclosed as **Annexure-II**) has sent agenda for the meeting.

Members may deliberate

D.3. Agenda from PGCIL, WRTS-II

CM, PGCIL, WRTS-II vide mail dated 03/05/2018 (copy enclosed as **Annexure-III**) has sent agenda for the meeting.

Members may deliberate

D.4. BSNL-Status in respect of items C2 to C8 of main agenda.

The Status in respect of items C2, toC8 above as reported by BSNL is enclosed at **Annex-IV**

D.5. Telangana –Transco- feedback on PTCC computerization.

Suggestions/Feedback for development of PTCC portal received from TS-Transco is enclosed at **Annexure-V**

**Agenda from Power Grid Corporation of India Ltd, SRTS-II, Bangalore for 106th
Central Level PTCC meeting at Mumbai**

For Karnataka State

Name of Transmission Line / Scheme	PTCC Status	PTCC file #
400kV D/C Hiriyur-Mysore line (Ultra Mega Solar Park - Phase 2) (Karnataka)	<ul style="list-style-type: none"> ➤ Application submitted on 08.07.17. ➤ South Western Railways NOC issued on 10.10.17 ➤ Directorate General of Signals NOC issued on 28.07.17 ➤ Field level marking getting delayed inspite of continuous follow up with SSA's. 	Ref: 103278 SKT -1739
400kV D/C Madhugiri (Tumkur) - Yelahanka Line (SRSS-13) (Karnataka)	<ul style="list-style-type: none"> ➤ BSNL, Chennai forwarded the proposal to CEA, Delhi on 29.04.2015 ➤ CEA Inspection done on 29.03.18. ➤ Proposal with CEA for issue of I.V. calculations. 	KNK / 2784 CEA # 810

For Tamil Nadu State:

Name of Transmission Line / Scheme	PTCC Status	PTCC file #
LILO of 230 kV S/C Neyveli - Bahour line at Karaikal (TN)	<ul style="list-style-type: none"> ➤ Application submitted on 28.07.17 ➤ Southern Railways letter sent to CEA on 16.09.17 for I.V. calculation. ➤ Directorate General of Signals issued NOC on 24.08.17. ➤ File forwarded by BSNL Chennai to CEA for I.V. calculation on 28.03.18. 	Ref: 103335 STN - 1767



पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड

(भारत सरकार का उद्यम)

POWER GRID CORPORATION OF INDIA LIMITED

(A Government of India Enterprise)



765/400 कि.वो. कर्नूल उप केंद्र, कर्नूल-नन्द्याल हाईवे रोड, 23 KM स्टोन के पास, ओर्वकल (गांव और मंडल), कर्नूल जिला. (ऑ.प्र.)
765/400 KV Kumool Sub-Station, Kumool-Nandyal Highway Road, Near 23 KM Stone, ORVAKAL (Vill. & Mdl.), Kumool District. (A.P.)
दूरभाष / Phone : 08518 - 202090 ई-मेल / E-mail : caokumool@gmail.com

Ref : SRTS-I : RPHVDC : PTCC: Date : 30.04.2018

To
The Director (PTCC)
Central Electricity Authority
Power Communication Development Division
NRPC Building, Katwaria sarai
New Delhi

Dear Sir

Sub : \pm 800 kV Raigarh-Pugalur HVDC Transmission Line construction – PTCC approval -Reg
Ref : Your letter No.CEA /PCD/106th CLPTCC meeting/2018/561 Dtd 2.4.18

With reference to the above , the following agenda is submitted for kind consideration of 106th meeting of CLPTCC proposed to be held during May 2018.

Under HVDC Bipole link between western Region (Raigarh Chhattisgarh) to Southern Region (Pugalur Tamil Nadu)-North Trissur (Kerala) scheme-I Raigarh-Pugalur 6000MW Transmission system , \pm 800 kV Raigarh-Pugalur HVDC Transmission Line is under construction and the works are in various stages of implementation. The above transmission line passes through the states of Chhattisgarh, Maharashtra, Telangana, Andhra Pradesh and Tamil Nadu. As the subject Transmission line is envisaged to carry DC currents, there shall be no induction in the adjacent communication systems. Therefore \pm 800 kV Raigarh-Pugalur HVDC Transmission Line may be considered for exemption from PTCC approval.

Submitted for kind consideration please

Thanking you sir

Yours faithfully
For POWERGRID

(A.C. SANKARAIAH)

ADDL. GENERAL MANAGER / SRTS-I

+/-800kV RP HVDC TLC

**Agenda points from PGCIL, WR-II, Vadodara for the 106th
Central PTCC Meeting to be held on 25th May-2018 at Mahabaleshwar,
Maharashtra.**

FOR M.P. Portion

1. **765 KV D/C Vindhyachal pooling - Jabalpur pooling transmission line under system Strengthening scheme associated with Vindhyachal - V : {Case No. CEA: MP-406; BSNL- MP-708}**
(Case submitted to 17/03/16 to all concerned)
 1. NOC received form Directorate General of signals on dated 10/04/17.
 2. Vide letter Dt. 02/06/2016, WCR-Jabalpur forwarded the Railway telecom details to CEA New-Delhi office.
 3. Vide letter dated 06/04/18, DET-PTCC-Mumbai has forwarded the BSNL telecom details to CEA New-Delhi office for Induced voltage calculation. IV calculation awaited.
 4. Line is targeted for commissioning by August-2018 and I.V calculation is urgently to be processed.

FOR Gujarat Portion

1. Green Energy Corridor Projects :

(A) 400 KV D/C Banaskantha - Chittorgarh TL :- (Target Completion:- Feb-2017) Case submitted to 14/04/16 to all concerned) (BSNL Case No. GUJ - 2341; CEA Case no.- GUJ-718)

1. Railway telecom details from Western railway on dated 03/11/2015 (SG.158/28/12-637) are already forwarded to Director-PTCC-CEA-New Delhi for further processing.
2. Vide letter dated 04/04/17, DET PTCC-Mumbai forwarded the telecom details to Director-PTCC-CEA-New Delhi.
3. NOC received form Directorate General of signals on dated 01/06/2016.
4. Vide letter dated 25/04/2017 & 01/09/17, requested to Director-PTCC-CEA-New Delhi for processing of I.V. calculation & expediting the PTCC case.
5. Vide letter Dt. 27/04/18, EPR details and revised soil resistivity details forwarded to CEA New-Delhi office.

2. 400 KV D/C Mundra-Bhuj Pooling SS transmission line associated with tr.system for system strengthening associated with Mundra UMPP Part-B. (Case submitted to 19/05/17 to all concerned) (CEA Case No. GUJ -728; BSNL Case No.GUJ-2452)

1. Railway telecom details from Western railway on dated 12/09/2017 (SG.158/28/12-755) are already forwarded to Director-PTCC-CEA-New Delhi for further processing.
2. NOC received form Directorate General of signals on dated 04/07/2017.

3. Vide letter Dt. 23.10.17, BSNL telecom details forwarded to CEA New-Delhi office for IV calculation.
4. The line is targeted for commissioning by August-2018 and I.V details are to be expedited.

3. **LILO of 220kV D/C Vapi - Khadoli transmission line at Vagchiba Sub- station "associated with the UT of Dadar & Nagar Haveli (Case submitted to 12/03/18 to all concerned) (BSNL Case No. GJ-2461)**

1. Vide letter Dt. 28.03.18, BSNL telecom details forwarded to CEA New-Delhi office for IV calculation. IV calculation awaited.

4. **400 KV D/C Banaskantha (PG) - Banaskantha (Radhanesda) transmission line associated with tr. System for Ultra Mega Solar Park (700 MW) at Banaskantha (Radhanesda)-Gujarat. (BSNL case No. -2459, CEA case No. GJ-740)**

1. Vide letter Dt. 06.03.18, BSNL telecom details forwarded to CEA New-Delhi office for IV calculation. IV calculation awaited.
2. Vide letter dt. 20.03.18, Western Railway Mumbai forwarded the railway telecom details to CEA New-Delhi office.

C-2

BSNL COMMENTS ANNEX-IVMPPTCL AGENDA FOR 106TH CLPTCC MEETING :

SR NO	West zone no/CEA no	Unique registration no	Pending with	STATUS
1	MP-440/ MP-403	Const of 220KV DCSS line from 220KV S/S Rajgarh to 100MW OF WIND ENERGY power plant at Badnawar Distt : Dhar.	1.CEA 2.MPPT CL	1.Railway(WR) Awaited.2. vide CEA ltr dt 28.3.18, some queries asked from MPPTCL BY CEAI.e physical verification of soil resistivity, submission of EPR for 650V, 7KV & 10KV for proposed S/S, etc.
2	MP-441/ MP-404	220KV DCSS Shujalpur-Narsingarh from existing 220KV S/S Shujalpur to 132KV S/S Narsingarh (to be upgraded 220KV S/S).	1.CEA	1.Defence awaited.
3	MP-482/ MP-418	Const of 220KV inter connector from 400KV S/S(PGCIL),Betul to 220KV S/S (MPPTCL), Betul.	1.CEA	1.CR issued NoC vide ltr dt 17.8.17.2. BSNL TD FWD ON 27.3.18
4	MP-487/ MP-419	LILO of both ccts of DAMOH-SAGAR 220KV line at 400KV S/S(PGCIL), Damoh.	1.BSNL for RAC	1.RAC ISSUED ON 20/04/2018.
5	MP-491/ MP-421	LILO of 220KV Satna(MPPTCL)-Chatarpur line at 400kv S/S PGCIL Satna.	1.BSNL	1.Defence NoC issued vide ltr dt 10.10.17.2.TCD from WCR issued vide ltr dt 29.8.17.3. BSNL TD waited from TDM Satna since 5.9.17.
6	MP-501/ MP-422	LILO of one cct of 220KVBhopal-Hoshangabad DCDS line at S/S Adampur	1.BSNL for RAC	1.IV calculation recd.2. Only NoC from WCR & WR pending. Note: NoC issued on 18.4.18 by WCR.
7	MP-492/ MP-420	LILO of both ccts of Sarni-Pandhuna DCDS line at 400KV S/S Betul (PGCIL).	1.CEA	.1. TCD from CR, Send vide ltr dt 30.8.17 while NoC from Defence send on 29.9.17.2. BSNL TD send on 27.3.18
8	MP-512/ -----	LILO of both ccts of 220KV Malanpur – Mehgaon DCDS line at praposed 400/220KV S/S CWRTL, Morena(Rithora).	1.BSNL 2.NCR, Allahab ad 3.Defen ce	.1. BSNL TD awaited from GM TD Morena since 11.11.2017.
9	MP-525/ -----	Const of 220kv dcds from 220 kv s/s sabalgarh to 400/220kv s/s Morena CWRTL(Rithora).	1.NCR, Allahab ad 2.CR	1. Defence NoC issued vide ltr dt 07.03.18.2. BSNL TD send on 27.3.18.

C-2

10	MP-521/ -----	LILO of second cct of 220KV Birsinghpur-Amarkantak line at 220KV S/S Shadol.	1.BSNL 2.SECR, Bilaspur 3.Defen ce	1. . BSNL TD awaited from TDM, Shadol, since 01.02.2018.
11	MP-519/ -----	Construction of LILO 400KV Seoni-Bhilai at proposed 400/132KV S/S Kiranpur.	1.BSNL 2.SECR, Bilaspur	1. Defence NoC issued vide ltr dt 06.03.18.2. BSNL TD awaited from TDM Balaghat since 1.2 18
12	New case/ -----	Construction of 400KV DCDS line from Ashta(400KV S/S) TO Ujjain (400KV S/S).	1.BSNL 2.WR 3.Defen ce	Case not registered yet.
13.	MP-518/--- -----	Construction of 220KV DCDS line from 400KV S/S Julvaniya to 132KV Sendhwa.	1.BSNL 2.WR 3.Defen ce	1.BSNL TD is awaited from TDM Khargone since 01/02/2018.
14.	MP-539/--- -----	Construction of 220KV DCDS Julwania - Kukshi line from 400KV S/S Julwania to proposed 220KV S/S kukshi.	1.BSNL 2.WR 3.Defen ce	1. BSNL TD is awaited from TDM Khargone since 17/03/2018.
15.	MP-538/--- -----	Construction of LILO of both ckt 220KV Badnagar-Ratlam DCDS line at Badnawar400KV s/s	1.BSNL 2.WR 3.Defen ce	1 BSNL TD is awaited from GMTD Ujjain since 17/03/2018.
16	MP-530/--- -----	Construction of LILO of 2 ckt Bansagar-Satna 220KV line at Kotar 220KV S/S.	1.BSNL 2.WCR 3.Defen ce	1. BSNL TD is awaited from TDM Satna since 26/02/2018.2. WCR issued NoC ON DT 23/2/18.
17	MP-529/--- -----	Construction of 220KV DCDS line from 400KV S/S Khandwa (PGCIL) to 220KV Chhanera	1.BSNL 2.CR 3.Defen ce 4.WR 5.Defen ce	1.BSNL TD is awaited from TDM Satna since 26/02/2018.2. WCR & SCR ssued TD vide ltr dt 21/3/18 & 13/3/18 respectively
18	New case/ -----	Construction of LILO of both cct of 220KV DCDS Badod-Kota/Modak line at 220KV S/S Suwasra.	1.BSNL 2.WCR 3.Defen ce	1. New case: Not yet registered.2.RLY Action : case sent to division for S&T detail on 12/3/18.

C.3 Agenda received from Kerala State Electricity Board limited (KSEBL)

Kerala State Electricity Board limited (KSEBL) vide letter dated 09/04/18 and 19/4/18 has sent agenda for the meeting, a copy is enclosed at Annex-V.

Work Order No	CEA's Regn No	Name of the line	Remarks by DE(PTCC)
SKL11072017 1726	KEL-324	220/110 KV line from Brahmapuram to Thuthiyoor and 220 cable from Thuthiyoor to Kaloor	Discussed in the SLPTCC meeting held on 25-04-2018. KSEB informed that the power route is being diverted because of existence of bunch of BSNL cables in the route, found after joint inspection and hence fresh proposal will be submitted.
SKL23112017 1925	KEL- 325	220 KV DC line through MC MV (220 and 110 KV towers) from prop. 220 KV SS Kothamangalam to loc. Karukodam to connect the existing Moolamattom (Idukki) SS	BSNL TD sent on 18.04.2018 to CEA/New Delhi It is found that BSNL Pilaar/Cable of Kothamangalam is within the EPR zone of the prop.Kothamangalam 220 KV SS Hence both KSEB and BSNL SSA have been directed on 19.04.2018 to conduct a joint inspection and give a detailed report before issue of RAC.
SKL17042018 2082		220 KV DC line from 440 KV PGCIL Pallikara SS to prop. 220 KV SS at Aluva.	Request initiated by KSEB authorities in the PTCC WEB portal on 12/04/2018. Case registered on 17/04/2018. BSNL TD awaited from Ernakulam SSA.

C-4: No Comments from BSNL.

C.5 Agenda received from APTRANSCO (Transmission Corporation of Andhra Pradesh Limited):

This agenda is regarding submission of BSNL details for 400 KV TMDC line of length 110 Kms from Sattenapally SS to Podili SS. BSNL details have to be collected from two BSNL SSAs viz, Ongole and Guntur. Guntur SSA have submitted the details in a proper manner as per PTCC guide lines. The details received from Ongole SSA have to be returned to BSNL SSA twice for re submission , since the details were not marked on the topo map properly. The case was discussed in the last SLPTCC meeting also. Finally the comprehensive list of BSNL details pertaining to Ongole SSA and Guntur SSA along with master copy of the topo map have been submitted to CEA/New Delhi for IV computation on 25.04.2018.

C-6

CSPTCL AGENDA FOR 106TH CLPTCC MEETING : (CHHATTISGARH STATE)

SR NO	West zone no/CEA no	Unique registration no	Pending with	STATUS
1.a	CG-54/ -----	<u>400KV D/C line from Marwa TPP-Raipur (Raita) (MBI/CG-54)</u>	RAC ISSUED	1. RAC issued on 18/07/17 and Copy of RAC is provided to CSPTCL, Raipur on 24/04/18 via Email.
1.b	CG-55/ -----	<u>400KV LILO line from Korba (West) – Khedamara line .</u>	1. RAC ISSUED	1. RAC issued on 18/07/17 and Copy of RAC is provided to CSPTCL, Raipur on 24/04/18 via Email.
1.c	CG-72/ -----	<u>400KV D/C line from Korba (West) – Khedamara (MBI/CG-72).</u>	1.CEA	1. For IV calculation since 23/9/17.
1.d	CG-104/ -----	<u>400KV Raita (Raipur) to Jagdalpur line (MBI/CG-104).</u>	1.ECoR 2.CSPTCL	1. BSNL_TD is forwarded to CEA,ND. 2. RD/NOC is awaited from ECoR, Bhubhneswar .3. EPR detail is awaited from CSPTCL, Raipur since 09/03/17.
2.a	CG-41/ -----	<u>220KV D/C line from 220KV CSPTCL Raigarh S/s – 400KV PGCIL S/s Raigarh:</u>	1.SECR, Bilaspur	1. NOC on IV calculation is awaited from SECR, Bilaspur since 17/11/14. Remandered on 01/03/17.
2.b	CG-42/ -----	<u>220KV D/C line from 220KV Jindal Power Plant Tamnar – 220KV CSPTCL Raigarh S/s</u>	1.BSNL for RAC	1. IV calculation recd. 2.Only NoC from WCR & WR pending. Note: NoC issued on 18.4.18 by WCR.
2.c	CG-51/ -----	<u>220KV D/C line from Chhuri – Mopka (MBI/CG-51):-</u>	1.CEA, 2.SECR, Bilaspur	1. TD is forwarded to CEA, ND on 04/04/17. 2. RD/NOC is awaited from SECR, Bilaspur since 02/01/12.

C-7

RRVNL AGENDA FOR 106TH CLPTCC MEETING (RAJSTHAN RAJYA VIDUAT PRASARAN NIGAM LIMITED)

SR NO	North zone no/CEA no	Unique registration no	Pending with	STATUS
1	-----/- -----	400KV D/C Barmar-Bhinmal line	1.CEA	1.BSNL TD ALREADY SEND.2. IV Calculation awaited from CEA, ND.
2	-----/ -----	400KV D/C Suratgarh TPS-Babai I line	1.CEA	1. BSNL TD ALREADY SEND. 2. IV Calculation awaited from CEA, ND.
3	-----/ -----	220KV D/C Bhiwadi- TPS Mundana of DFCC line.	1.CEA	1. BSNL TD ALREADY SEND. 2. IV Calculation awaited from CEA, ND
4	-----/ -----	220KV S/C Kalisindh-Bhawanimandi line.	1. CEA	1. BSNL TD ALREADY SEND. 2. Case is pending for line route inspection by CEA authority.
5	-----/ -----	220KV S/C Ajmer-Bherunda line	1. CEA	1. BSNL TD ALREADY SEND. 2. IV Calculation awaited from CEA, ND
6	-----/ -----	220KV D/C Bhadla-M/S SUCRL 220/33KV PSS1 BADLA Solar park phase III line.	1. CEA	1. BSNL TD ALREADY SEND. 2. . IV Calculation awaited from CEA, ND

C-8

PSTPCL AGENDA FOR 106TH CLPTCC MEETING (PUNJAB STATE TRANSMISSION CORPORATION LIMITED)

SR NO	North zone no/CEA no	Unique registration no	Pending with	STATUS
1	-----/- -----	400KV Ludhiana-220 KV Doraha S/C line on D/C towers.	1.BSNL	1.BSNL TD Awaited.
2	-----/ -----	220KV line from 400K Mukatsar-220KV Kotakpura(Sandhwan).	1. BSNL	1. .BSNL TD Awaited.
3	-----/ -----	LILO of one cct of 220KV GHTP-Talwandi Saboo, at 220KV S/S, Maur.	1. BSNL	1. .BSNL TD Awaited.
4	-----/ -----	220KV line from 400KV PGCIL Moga to 220KV Mehal Kalan.	1. CEA	1. BSNL TD FORWARDED TO CEA ND.
5	-----/ -----	220KV line LILO S/C Humbran-Ferozpur Road Ludhiana at Ladowal.	1. CEA	1. BSNL TD FORWARDED TO CEA ND.
6	-----/ -----	220KV Goindwal Sahi - Botianwala D/C line.	RAC ISSUED	1.RAC HAS BEEN ISSUED IN YEAR 2014.
7	-----/ -----	220KV Makhu-Algon.	RAC ISSUED	1.RAC ISSUED ON 18/04/2018..
8	-----/ -----	220KV line Abohar-Malout S/C on D/C.	1.BSNL	1. .BSNL TD Awaited.
9	-----/ -----	220KV D/C line from 400 kv Nakodar to 220KV Ladowal.	1. CEA	1. BSNL TD FORWARDED TO CEA ND ON 20/04/2018.
10	-----/ -----	LILO of one cct of 220KV BBMB Jalandhar-220KV Pong D/C line at 220KV S/S Alawalpur.	1. CEA	1. BSNL TD FORWARDED TO CEA ND ON 20/10/2017.
11	-----/ -----	LILO of 220KV Himmatpura to Jagraon line at 220KV S/S Ajitwal.	1. BSNL	1.BSNL TD RECEIVED AND SAME WILL BE FORWARDED TO CEA ND SHORTLY.
12	-----/ -----	LILO of 220KV between 400KV Moga & 220KV S/S Himmatpura at Badni Kalan.	1. BSNL	1.BSNL TD RECEIVED AND SAME WILL BE FORWARDED TO CEA ND SHORTLY
13	-----/ -----	220KV line Talwandi Sabo – Maiser Khana (Railway deposit work)	-	1.PRAPOSAL NOT RECEIVED HENCE CASE MAY BE REMOVED FROM LIST.

TRANSMISSION CORPORATION OF TELANGANA LIMITED

From:
The Chief Engineer,
Construction,
TSTRANSCO,
Vidyut Soudha,
Hyderabad -500 082.

To,
The A.G.M (Tech),
O/o. CGM QA & Inspection Circle,
Sanchar Vikas Bhavan,
Residency Road, Jabalpur-482001

Lr.No. CPT 320/SE-Const/ F.Digitization of PTCC/ D.No. 525 /2018, Dt: 07 .05.2018.

Sir,

Sub: - TSTransco - Computerization of PTCC - Route approval process - Suggestions/Feedback for development of PTCC Portal -submitted - Reg.

Ref:- NO. TD/LP-2015/Digitization of PTCC Dated:15.03.2018

* * *

In reference to the letter cited above, where in it has informed that computerization of route approval process was discussed during the last CLPTCC meeting held at Cochi on 10th Nov,2017, and decided that subcommittee to be formed for review and study the suggestion/feedback for development of PTCC Portal and requested to submit the feedback and suggestions from all the stake holders.

In view of the above the following suggestions/feedback are here with submitted for consideration in the development PTCC portal.

1. **Login Problem :** As and when we login to the portal it shows “ **Something went wrong. Try again**” or “**STRUTS PROBLEM REPORT**” frequently. (Screen shots enclosed). On enquiry, it was made to understand that the problem has occurred due to non availability of the servers. Exclusive servers may be provided for better utilization of portal.
2. **Data Entry :**
 - i. There is no limitation of characters for the entry of the data in the portal for each line but it is observed that, it is getting hanged frequently due to entry of more characters in each line. The same may be resolved.
 - ii. **Details sent Through :** Only **Postal/ Courier** is available. **By Hand** may be included as some of the proposals are submitted by hand due to urgency.
 - iii. **Postal/Courier Regn. No:** It should not be mandatory as the proposals are sending through ordinary post and no registration number is available to enter in it.
 - iv. **Postal Sent Date :** It is not required at initial page(1st page). The proposals are sent to concerned DE/PTCC by post/courier duly mentioning the PTCC request No., only after uploading the proposal in the portal. So it is not possible to enter the date of sending through post.
 - v. **Other details of postal/Courier :** It is not required at initial page(page 1) as above.

Postal/Courier details are not required at this page of uploading the proposal. The same may be provided at the Pending Dispatch details as we are uploading the PTCC proposal first and sending the hardcopies to the concerned DET/PTCC duly mentioning the request No. generated in the portal.

The above (ii), (iii),(iv) and (v) column may be deleted from the first page of portal. These details may be provided at “PENDING DISPATCH” after getting the Unique registration No. from concerned DE/PTCC.


3. **No. of Circuits :** Make this column to enter only numerical values (i.e if SC line 1, DC line 2 and Multicircuit line 3 or 4) as few are entering numbers others are entering text (like DC , SC , DC/SC , MC).

Agenda
PTO

MCR 123

4. At Some times, after filling the first page in the portal for new proposal, instead of appearing only "NEXT" button, "SUBMIT" button is also appearing along with "NEXT". It is requested to make only "NEXT" button to appear instead of both.
5. After selection of the concerned departments in 2nd page of new proposal, "SUBMIT" button is appearing before uploading the required documents and on selection of "SUBMIT" button the proposal is updated without uploading the documents.
Due to power failure or network problem, we are unable to upload the required documents in the portal after filling all information (1st page) and selecting the concerned departments (2nd page). Facility of intermediate save may be provided.
As such it is requested to provide the "SUBMIT" instead of "CLOSE" button, only after uploading documents for submission of new proposals and "NEXT" button may be provided at 2nd page instead of "SUBMIT".
6. Further, it is also to inform that, many times the documents are not uploading properly due to restrictions in file type and size. Sometimes, if browsed the documents after few seconds again and upload, it is getting uploaded. The same may be rectified.
Instructions may be made available in the uploading documents page for proper uploading of documents. (Like type and size of the documents to be uploaded, whether Topo map should be uploaded or not, the details of documents to be uploaded).
7. **Track word order:**
The proposals are sent to concerned DE/PTCC, Railway, Defence at a time and the proposals are processed in parallel.
At present, in pending/track details, it showing the status of proposal with one department only instead of status in all departments.
So, it is requested to provide the tracking/ checking of the status of the proposal sent, in all departments at any point of time.(Sometimes proposals also sent to 2 or 3 railway departments like SCR, SR, SWR)
Further, it is to submit that the contact no. of the concerned officers are not updated in the portal. Please arrange to update the same for pursuing with the concerned department.
8. **Work Process Remarks/ Accepting the compiled list:** In the work process remarks & Accepting the compiled list, all the work orders No. are available in the list of select work orders. It is requested to made available only the work orders for which RACs are not issued/ are under process. On issue of RAC, the concerned work order may be automatically delisted from the list of select work orders.(sometimes other state utility cases are appearing).
9. **Download RAC/other certificates of Reports Tab:**
While selecting the Work order No. for downloading RACs, other state utility work orders are appearing. The same may be rectified to appear only the respective state utility work order No. for downloading the RAC/other certificates.
Further, it is requested that, while development of version-2 of PTCC portal, the portal may be redesigned with the latest user friendly applications available as the existing portal is not user friendly and giving frequent troubles.

Yours faithfully,


CHIEF ENGINEER
CONSTRUCTION

Copy to :

The Chief Engineer ,Central Electricity Authority & Co-chairman, Central PTCC, PCDD, NRPC Complex, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016.

The Divisional Engineer (Telecom), Telecom (T&D Circle) Bharat Sanchar Nigam Ltd., 1st Floor, Rajbhavan Exchange, 26, Sardar Patel Road, Guindy, Chennai – 600 032.

The Divisional Engineer-1/2, O/o CE/Construction/ VS/ Hyderabad