

## Transmission Corporation of Telangana Limited

Vidyut Soudha, Hyderabad – 500 082. PABX:23396000  
(CIN No:U40102AP2014SGC094248) Website:transco.telangana.gov.in

From  
Chairman & Managing Director,  
TS TRANSCO,  
Vidyut Soudha, Hyderabad

To  
The Chairman,  
Central Electricity Authority,  
New Delhi-110066

Lr.No.CMD/TSTransco/SE/PS/DE-SS/F-TP/D.No.52 /15, dt.28-04-15.

Sir,


Sub: TS Transco Transmission Plan- Calling for an emergency  
Standing Committee Meeting-Requested -Reg.

\* \* \*

Post bifurcation, the State of Telangana has faced severe power shortage problems for various reasons. To mitigate the situation various short-term measures were taken. A comfortable power supply situation has been achieved in the State presently. We are very much grateful for the help and support extended by Ministry of power, GoI and CEA during the crucial phase.

To address this issue permanently and make "Telangana a Power Surplus State", an ambitious plan of capacity addition has been taken up. This includes setting up of Kakatiya TPP Stg-II (1X600 MW), Kothagudem TPS Stg-VII (1X800 MW), Manuguru TPP (4X270 MW) & Damercharla TPP (5X800 MW). Apart from this M/s NTPC is also setting up a 4000 MW TPP as mandated by State Reorganization Act. With the support extended by Telangana State Government and lending agencies, most of these projects have already achieved financial closures and the zero date would commence soon. This would also help us in accomplishing the mission of 9hrs daytime Agricultural supply as promised by Hon'ble Chief Minister of Telangana "24X7 Power For All" as envisaged by Government of India and sooner than expected.

Member(PS) MSL  
(E/SB/PA) 06.05



To evacuate this huge quantum of power an adequate & robust transmission network must be in place. Transmission Corporation of Telangana together with M/s Power Grid Corporation have prepared a comprehensive transmission plan, which would meet the transmission requirements on account of Capacity Addition as well as anticipated load growth is herewith enclosed.

(Further as per the studies conducted, the 400kV Twin Moose DC lines between Maheshwaram 765 kV PGCIL SS - Maheshwaram 400 kV TS SS and Dichipally 765 kV PGCIL SS - Dichipally 400 kV TS SS needs to be enhanced to "Quad Moose" lines and the same may also please be approved.) ?

We solicit the support of CEA and request to call for an emergency Standing Committee meeting, at the earliest, so as to take up the issue as a "Table Item" in the forthcoming SRPC/TCC meeting scheduled to be held on 11<sup>th</sup> & 12<sup>th</sup> May 2015, which would help us in faster implementation of the plan.


Thanking you,

Yours faithfully,


b. a. l

CHAIRMAN AND MANAGING DIRECTOR  
TSTRANSCO


## TELANGANA SYSTEM STUDIES (2018-19 TIME FRAME)



TELANGANA SYSTEM STUDIES (2018-19 TIME FRAME)




**TELANGANA SYSTEM STUDIES (2018-19 TIME FRAME)**




Bus - Busbar voltage (kV)  
BSC - Busbar switchgear  
MVA - MVA rating  
Equipment - MVA/Avar  
KV - <=110,000 <=120,000 <=130,000 <=140,000 <=150,000 <=160,000 <=170,000 <=180,000 <=190,000 <=200,000 <=210,000 <=220,000 <=230,000 <=240,000 <=250,000 <=260,000 <=270,000 <=280,000 <=290,000 <=300,000 <=310,000 <=320,000 <=330,000 <=340,000 <=350,000 <=360,000 <=370,000 <=380,000 <=390,000 <=400,000 <=410,000 <=420,000 <=430,000 <=440,000 <=450,000 <=460,000 <=470,000 <=480,000 <=490,000 <=500,000 <=510,000 <=520,000 <=530,000 <=540,000 <=550,000 <=560,000 <=570,000 <=580,000 <=590,000 <=600,000 <=610,000 <=620,000 <=630,000 <=640,000 <=650,000 <=660,000 <=670,000 <=680,000 <=690,000 <=700,000 <=710,000 <=720,000 <=730,000 <=740,000 <=750,000 <=760,000 <=770,000 <=780,000 <=790,000 <=800,000 <=810,000 <=820,000 <=830,000 <=840,000 <=850,000 <=860,000 <=870,000 <=880,000 <=890,000 <=900,000 <=910,000 <=920,000 <=930,000 <=940,000 <=950,000 <=960,000 <=970,000 <=980,000 <=990,000 <=1000,000


TELANGANA SYSTEM STUDIES (2018-19 TIME FRAME)



## TELANGANA SYSTEM STUDIES (2018-19 TIME FRAME)




## TELANGANA SYSTEM STUDIES (2018-19 TIME FRAME)




Bus - Bus sections (kV)  
Branch - KV/MVA  
Equipment - AMVA Meter  
MV - <=110,000 <=132,000 <=220,000 <=330,000 >=400,000 >=765,000 >=765,000

## TELANGANA SYSTEM STUDIES (2021-22 TIME FRAME)




Bus = Bus voltage (kV)  
 Branch = MW/Var  
 Equipment = MW/Var  
 kV = <=110,000 &gt;132,000 &lt;=220,000 &lt;=330,000 &lt;=400,000 &lt;=765,000 &gt;765,000

## TELANGANA SYSTEM STUDIES (2021-22 TIME FRAME)




Bus • Base voltage (kV)  
Branch - kVA/Mvar  
Equipment - MV/Mvar  
KV: <=110.000, <=132.000, <=220.000, <=330.000, <=400.000, <=450.000, <=765.000

TELANGANA SYSTEM STUDIES (2021-22 TIME FRAME)




## TELANGANA SYSTEM STUDIES (2021-22 TIME FRAME)




Bus: Base voltage (kV)  
 Branch: MW/Mvar  
 KV:  $\times 10^3$  MVA  
 $\rightarrow$ : 200 MVA  
 $\leftarrow$ : 200 MVA  
 $\leftrightarrow$ :  $>765$  MVA  
 Circle with dot: 200 MVA  
 Circle with cross:  $>765$  MVA

## TELANGANA SYSTEM STUDIES (2021-22 TIME FRAME)



**TELANGANA SYSTEM STUDIES (2021-22 TIME FRAME)**



## PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(FIE)

MON, AFR 27 2015 14:49

AREA TOTALS  
IN MW/MVAR

		FROM -----AT AREA BUSSES-----				TO LINE				-NET INTERCHANGE-			
X-- AREA -- X		FROM GEN- ERATION	IND ATORS	TO IND MOTORS	TO GENERATIN	TO BUS SHUNT	GNE BUS DEVICES	TC SHUNT CHARGING	FROM LOSSSES	TO TIE LINES	TO TIES + LOADS	DESIRED NET THT	
1	NORTH	42687.3 -6612.4	0.0 0.0	0.0 0.0	65153.7 16520.1	0.0 -5459.4	0.0 0.0	2.3 72457.2	0.0 30475.5	2571.5 -25040.2	-25040.2 2315.0	0.0 0.0	
	NBT/EAST	4148.4 -1306.2	0.0 0.0	0.0 0.0	3159.0 956.2	0.0 4883.6	0.0 0.0	0.0 2023.0	0.0 7677.6	182.3 1488.2	807.1 -2979.7	797.1 -2981.7	
3	WEST	83786.7 -5953.3	0.0 0.0	0.0 0.0	64271.9 9396.1	0.0 -9101.0	0.0 0.0	0.0 50406.3	0.0 101354.6	3612.7 49774.9	15902.1 -5075.0	15902.1 -5075.0	
	EAST	46826.3 -6003.1	0.0 0.0	0.0 0.0	25959.8 5201.9	0.0 -2464.6	0.0 0.0	202.9 9216.0	0.0 34262.7	1096.0 13648.0	19567.6 2658.4	19567.6 2660.4	
5	SOUTH	52560.7 54.2	0.0 0.0	0.0 0.0	62958.5 20715.3	0.0 508.2	0.0 0.0	0.0 14580.1	0.0 58604.5	1510.6 19168.8	-11908.4 3686.4	-11908.4 3686.4	
	BHUTAN	2005.9 -591.5	0.0 0.0	0.0 0.0	318.2 114.5	0.0 119.6	0.0 0.0	0.0 94.4	0.0 500.4	6.7 146.7	1680.9 -566.4	1680.9 -566.4	
7	BANGLADESH	0.0 0.0	0.0 0.0	0.0 0.0	1000.0 50.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 113.9	9.2 102.5	-1009.2 -38.7	-1009.2 -38.7	
	COLUMN TOTALS	232015.2 -20412.4	0.0 0.0	0.0 0.0	222821.1 52954.2	0.0 -11513.7	0.0 0.0	205.2 98313.4	0.0 274970.9	8989.0 114804.7	0.0 0.0	0.0 0.0	

## OUTPUT FOR ZONE 51 [TELANGANA ]

## OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS NOT APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

X-----	BUS -----X		THREE PHASE FAULT /I+/	X-----LG FAULT---X	/AN(I+)/	/3I0/	AN(I+)
514001	[RSTP	400.00]	AMP	38036.8	-86.95	38654.9	-86.88
514002	[HYDR	400.00]	AMP	34265.8	-85.78	23318.6	-80.89
514003	[NSAG	400.00]	AMP	32621.8	-85.23	22098.2	-81.39
514004	[KHAM	400.00]	AMP	43325.3	-86.57	31845.4	-82.96
514009	[CHAND-SR	400.00]	AMP	6461.4	-85.18	4015.8	-78.84
514011	[SSLBPH4	400.00]	AMP	21282.7	-86.31	18950.5	-85.56
514012	[HYDR-AP4	400.00]	AMP	25698.8	-85.81	17921.3	-81.46
514020	[RAM-PVT4	400.00]	AMP	26712.9	-86.22	21357.0	-82.39
514021	[DICHPAL4	400.00]	AMP	36504.2	-86.89	25396.4	-81.77
514022	[GAJWEL4	400.00]	AMP	31698.6	-85.91	20654.2	-80.33
514023	[MAHABUB4	400.00]	AMP	34228.7	-86.39	22534.4	-81.87
514029	[AKTIA-G	400.00]	AMP	28241.4	-86.70	25425.8	-85.74
514031	[SINGARENI	400.00]	AMP	21340.9	-87.82	22550.6	-87.85
514049	[KOTH-IV	400.00]	AMP	15720.3	-85.98	13112.5	-84.67
514051	[MAILARM4	400.00]	AMP	31942.7	-85.96	21190.7	-80.94
514052	[MALKARM4	400.00]	AMP	22185.4	-85.84	15504.3	-81.80
514060	[SURYPET4	400.00]	AMP	30660.5	-86.45	20416.4	-82.16
514061	[NIZAMABAD	400.00]	AMP	34951.5	-87.20	24174.8	-82.09
514062	[NIRMAL	400.00]	AMP	20563.0	-86.26	14162.6	-81.53
514078	[WARANGAL NEW	400.00]	AMP	37947.7	-87.55	28714.2	-83.55
514079	[WARN4	400.00]	AMP	38397.8	-87.23	29175.8	-83.20
514080	[KOTH-VII	400.00]	AMP	29049.0	-87.58	22026.5	-85.87
514095	[BOMMANAFALLY	400.00]	AMP	39238.4	-87.45	29117.5	-84.88
514100	[NARSAPUR	400.00]	AMP	32306.5	-85.90	21399.7	-80.61
514101	[MAHESWRM	400.00]	AMP	49815.7	-87.11	35614.6	-83.00
514104	[MAHESH-TS	400.00]	AMP	48810.6	-86.93	34417.9	-82.67
514105	[RAMADAGU	400.00]	AMP	29730.2	-86.50	20182.4	-81.59
514106	[TIPPAPUR	400.00]	AMP	32419.4	-86.30	21725.6	-81.17
514107	[CHOPPADANDI	400.00]	AMP	27687.1	-86.32	18302.9	-81.19
514108	[MYDARAM	400.00]	AMP	21107.4	-86.55	13663.6	-81.79
514131	[MANIKONDA	400.00]	AMP	22036.3	-86.32	13883.9	-81.59
514134	[MANUGURU	400.00]	AMP	21807.4	-88.07	17892.5	-87.31
514135	[ASUPAKA	400.00]	AMP	7530.6	-84.93	4482.7	-78.08
514152	[DINDI	400.00]	AMP	14586.9	-86.01	10109.2	-83.09
514164	[PARIGI	400.00]	AMP	18858.1	-86.45	11909.4	-82.28
514165	[JANAGAON	400.00]	AMP	27756.1	-86.56	18016.3	-82.43
514169	[DAMARCHARLA	400.00]	AMP	32616.0	-87.63	26719.7	-86.83
514170	[CHOUTTUPPAL	400.00]	AMP	11502.7	-85.86	7464.5	-82.53
514171	[MADARAM	400.00]	AMP	18964.1	-86.54	11822.6	-82.16
514172	[NANCHRLAKOTA	400.00]	AMP	17610.4	-86.51	10984.8	-82.22
518051	[HYDR_800	765.00]	AMP	32430.2	-87.78	21217.9	-82.65
518062	[NIZAMABAD	765.00]	AMP	22997.8	-87.58	14236.7	-81.66
518079	[WARN800	765.00]	AMP	29870.2	-87.70	19130.1	-82.30

FROM AREA	5	SOUTH						
TO AREA	3	WEST	X-----X	X-----X	TO AREA BUS -----X	CRT	MW	VAR
X-----X FROM AREA BUS -----X			BUS# X-- NAME --X BASKV	BUS# X-- NAME --X BASKV	2DC	-497.0	251.6	TWO TRM DC "11"
BUS# X-- NAME --X BASKV			400.00*	374007 BHADRA4	2DC	-497.0	251.6	TWO TRM DC "12"
514009 CHAND-SR	400.00*		400.00*	374007 BHADRA4	2DC	-497.0	251.6	TWO TRM DC "13"
514009 CHAND-SR	400.00*		314029 RAIGARH_POOL400.00	314029 RAIGARH_POOL400.00	2DC	-1908.8	783.1	TWO TRM DC "14"
514016 FUGALUR-NEW	400.00*		314029 RAIGARH_POOL400.00	314029 RAIGARH_POOL400.00	2DC	-1908.8	783.1	TWO TRM DC "15"
514016 FUGALUR-NEW	400.00*		378040 SHOLAPUR-PG	378040 SHOLAPUR-PG	4	-1748.9	79.8	
518029 DUMY_BU	765.00		378021 WARDHA	378021 WARDHA	1	-332.8	52.4	
518062 NIZAMABAD	765.00*		378021 WARDHA	378021 WARDHA	2	-332.8	52.4	
518062 NIZAMABAD	765.00		378091 WARORA_POOL	378091 WARORA_POOL	1	-433.3	209.8	
518079 WARN800	765.00		378091 WARORA_POOL	378091 WARORA_POOL	2	-433.3	209.8	
518079 WARN800	765.00		374050 KOLHAPURPG	374050 KOLHAPURPG	1	623.5	4.9	
524015 NARDR-NW	400.00*		374050 KOLHAPURPG	374050 KOLHAPURPG	2	623.5	4.9	
524015 NARDR-NW	400.00*					-6845.6	2695.4	
TOTAL FROM AREA	5	TO AREA	3					
TO AREA	4	EAST	X-----X	X-----X	TO AREA BUS -----X	CRT	MW	VAR
X-----X FROM AREA BUS -----X			BUS# X-- NAME --X BASKV	BUS# X-- NAME --X BASKV	2DC	-1004.8	-413.0	TWO TRM DC "10"
BUS# X-- NAME --X BASKV			400.00	424019 TALCHER	400.00*	-323.2	175.5	TWO TRM DC "11"
524011 KOIAR	400.00		424099 GAZUWAKA_ER	424099 GAZUWAKA_ER	2DC	-323.2	175.5	TWO TRM DC "12"
514010 GAZU-SR	400.00*		424099 GAZUWAKA_ER	424099 GAZUWAKA_ER	2DC	-1004.8	-413.0	TWO TRM DC "13"
514010 GAZU-SR	400.00*		424019 TALCHER	424019 TALCHER	2DC	-1004.8	-413.0	TWO TRM DC "14"
524011 KOIAR	400.00		428014 ANGUL	428014 ANGUL	1	-1188.3	125.8	
518091 SRI_POOL	765.00		428014 ANGUL	765.00*	2	-1188.3	125.8	
518091 SRI_POOL	765.00					-5032.6	-223.4	
TOTAL FROM AREA	5	TO AREA	4					
TOTAL FROM AREA	5	SOUTH					-11878.2	2472.0



## PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)

MON, APR 27 2015 14:50

ZONE TOTALS

X--- ZONE X- RATION

FROM GENE- FROM TMD

TO ZONE BUSES-----

TO IND

TO BUS

TO LINE/

TO SHUNT

FROM

GENE/BUS

SHUNT CHARGING

LOSSES

TO TIE LINES

TO TIES + LOADS

IN MW/MVAR

-NET INTERCHANGE-

-2067.0

-672.7

-672.7

-98.4

-98.4

3280.5

2791.6

2791.6

3192.1

-838.7

-838.7

253.2

-2466.5

-2466.5

396.2

4815.4

9144.1

44.4

1047.2

2835.0

268.5

-3103.1

-3103.1

3468.9

13261.6

3197.9

-816.0

-816.0

3565.2

15361.3

4532.2

2829.4

353.9

-1985.6

-3106.7

3197.9

-3103.1

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

-2466.5

ZONE TIE LINE  
INTERCHANGE

## FROM ZONE 51 TO TELANGANA

TO ZONE 50 ANDHRA	TO ZONE BUS ---X	X----- TO ZONE BUS ---X	X----- TO ZONE BUS ---X	CRT	MW	MVAR
X--- FROM ZONE BUS ---X	BUS# X-- NAME --X	BUS# X-- NAME --X	BUS# X-- NAME --X			
512003 NSAG	220.00*	512005 VIJA	220.00	1	-6.4	-10.4
512049 KOTH	220.00*	512050 LILSLRU	220.00	2	-6.4	-10.4
512060 SURYAPET2	220.00*	512050 LILSLRU	220.00	1	20.0	4.2
512003 NSAG	220.00	512073 SRIS	220.00*	2	20.0	4.2
512003 NSAG	220.00	512073 SRIS	220.00*	3	20.0	4.2
512049 KOTH	220.00*	512005 VTJA	220.00	1	119.1	-23.5
512049 KOTH	220.00*	512050 LILSLRU	220.00	1	-58.4	11.9
512174 HUZHARANAGAR	220.00*	512035 CHILAKAL	220.00	1	-71.6	5.6
512106 BRAHMTR	220.00*	512103 BRAHMTR	220.00	2	63.9	10.5
512152 DINDE	220.00*	512073 SRIS	220.00	1	65.8	42.0
512152 DINDE	220.00*	512073 SRIS	220.00	2	-55.2	19.4
512174 HUZHARANAGAR	220.00*	512035 CHILAKAL	220.00	1	-59.7	-8.4
514003 NSAG	400.00*	514025 RULR-MEW	400.00*	1	62.6	24.2
514003 NSAG	400.00*	514098 FSG-3	400.00	1	155.5	-80.3
514004 KHAK	400.00*	514005 VJK	400.00	2	155.5	80.3
514011 SSBPH4	400.00*	514016 L2POOL	400.00*	1	-192.8	32.0
514011 SSBPH4	400.00*	514015 PURSOC4	400.00*	1	205.4	-195.5
514011 SSBPH4	400.00*	514066 TJS-AF	400.00	1	-29.5	-104.1
514011 SSBPH4	400.00*	514106 VJ3-AF	400.00*	3	-29.6	-20.3
514023 MABUBA	400.00*	514133 UVKND	400.00	1	55.6	152.6
514023 MABUBA	400.00*	514133 UVKND	400.00	2	65.6	-152.6
514052 MALKARMA	400.00	514090 VITP-TV	400.00*	2	-164.5	24.4
514060 SURYET4	400.00	514030 VITP-TV	400.00*	1	-42.9	69.1
514060 SURYET4	400.00*	514111 KVROTA40	400.00	1	-209.8	-18.5
514060 SURYET4	400.00*	514111 KVROTA40	400.00	2	209.8	18.5
514101 MAHESMR	400.00*	514013 KUNNOOLA	400.00	1	57.0	-13.3
514175 ASUPASA	400.00	514016 VIZPOOL	400.00*	1	-194.9	16.7
518051 HYDR-200	765.00*	518053 KUR400	765.00	1	71.0	-205.1
518051 HYDR-200	765.00*	518053 KUR400	765.00	2	71.0	205.1
518078 WARNS00	765.00*	518013 PATA800	765.00	1	70.1	243.7
518078 WARNS00	765.00*	519030 GATPA900	765.00	2	-70.1	-249.7
TOTAL FROM ZONE 51 TO ZONE 50	51	-249.7	-827.7	-1253.9		

TO ZONE 52 KARNATAKA

X--- FROM ZONE BUS ---X

BUS# X-- NAME --X BASKV BUS# X-- NAME --X BASKV CRT MW MVAR

512019 JUBLIPKA 220.00\* 522003 FATEC 220.00 1 -63.6 14.6

510019 JUBLIPKA 220.00\* 522003 SATC 220.00 2 -58.6 14.6

510033 NAHABA4 400.00\* 522003 SATC 400.00 1 -53.6 14.6

TOTAL FROM ZONE 51 TO ZONE 52

## PTI INTERACTIVE POWER SYSTEM SIMULATOR -PSS(R)E

MON, APR 27 2015 14:50

FROM :----- km

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E  
 MCN, APR 27 2015 14:50  
 ZONE TOTALS  
 IN MW/MVAR

	FROM -----AT ZONE BUSES-----	TO EUS	TO LINE CHARGING	FROM LOSSES	TO TIE LINES	NET INTERCHANGE- TO TIES + LOADS
FROM IND TO IND LOA	GENE- GNE	BUS DEVICES	SHUNT	TO	TO TIES	
GEN- MTRS	RATN GENERATN		SHUNT	LOSSES	LOADS	
X - ZONE - X1 RATION						
51 10428.0	0.0	0.0	0.0	0.0	253.2	-2067.0
TELMANGANA -2057.3	0.0	0.0	0.0	0.0	3192.1	-98.4
58 TSL LOAD	0.0	0.0	0.0	0.0	0.0	0.0
COLUMN TOTALS	10428.0	0.0	12241.7	0.0	253.2	-2067.0
TOTALS	-2057.3	0.0	4023.7	618.0	3192.1	-98.4

## PTI INTERACTIVE POWER SYSTEM SIMULATOR -PSS(R)E

MON, APR 27 2015 12:12  
APR 27 2015FROM -----AT AREA BUSFE  
GEN- FROM

X- AREA X--

MON, APR 27 2015 14:52  
APR 27 2015

X- AREA X--

MON, APR 27 2015 14:52  
APR 27 2015

## PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E

MON, APR 27 2015 14:52  
APR 27 2015

X- AREA X--

SUBSYSTEM		LOADING ABOVE		OUTPUT FOR ZONE 51 (TELANGANA ) (EXCLUDED: LINES; BREAKERS AND SWITCHES)		LOADING		RATING PERCENT	
LOADING CHECK (INCLUDED: TRANSFORMERS)		(INCLUDED: TRANSFORMERS)		TO BUS		CKT		RATING	
MVA LOADINGS		FROM BUS		NAME		AREA		PERCENT	
BUS#	X-- NAME	FROM BUS	X-- AREA	BJS#	X-- NAME	TO BUS	X-- AREA	CKT	RATING
511001	RSTP	132.00	5	514001	RSTP	60.00*	5	1	400.00*
512001	HYDR	220.00	5	514002	HYDR-AP4	400.00*	5	1	400.00*
512001	RMGD	220.00	5	514012	GAJWELA	400.00*	5	2	569.9
512002	HYDR	220.00	5	514022	GAJWELA	400.00*	5	1	834.4
512002	HYDR2	220.00	5	514022	GAJWELA	400.00*	5	1	945.0
512012	HYDR2	220.00	5	514023	MARHABA	400.00*	5	1	634.0
512022	GAJWEL2	220.00	5	514023	MARHABA	400.00*	5	1	630.0
512022	GAJWEL2	220.00	5	514051	MAILARMA	400.00*	5	1	473.0
512022	GAJWEL2	220.00	5	514052	MAILARMA	400.00*	5	1	1130.0
512023	MEERBOING	220.00	5	514052	MAILARMA	400.00*	5	1	92.1
512023	MEERBOING	220.00	5	514052	MAILARMA	400.00*	5	1	791.7
512051	MAILRM	220.00	5	514060	SURYPET4	400.00*	5	1	315.0
512051	MAILRM	220.00	5	514060	SURYPET4	400.00*	5	1	290.0
512052	MALKARAM	220.00	5	514079	WARN4	400.00*	5	2	315.0
512052	MALKARAM	220.00	5	514079	WARN4	400.00*	5	2	190.3
512060	SURYPET2	220.00	5	514100	NARSAPUR	400.00*	5	1	315.0
512060	SURYPET2	220.00	5	514100	NARSAPUR	400.00*	5	2	315.0
512079	WRNG	220.00	5	514100	NARSAPUR	400.00*	5	1	190.3
512100	NARSAPUR2	220.00	5	514164	PARIGLI	400.00*	5	1	60.4
512100	NARSAPUR2	220.00	5	514164	PARIGLI	400.00*	5	2	315.0
512100	NARSAPUR2	220.00	5	514164	PARIGLI	400.00*	5	1	60.4
512160	PARIGLI-LI	220.00	5	514164	PARIGLI	400.00*	5	2	315.0
512160	PARIGLI-LI	220.00	5	514164	PARIGLI	400.00*	5	1	60.4

PTI INTERACTIVE POWER SYSTEM SIMULATOR - PSS(R)E

MON, APR 27 2015 12:2 AREA TOTALS

MON, APR 27 2015 12:14

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E

OUTPUT FOR ZONE 51 (TELANGANA, 1  
BREAKERS AND SWITCHES; TRANSFORMERS)

SUBSYSTEM LOADING CHECK (INCLUDED: LINES) (EXCLUDED: BREAKERS AND SWITCHES; TRANSFORMERS)

A:

CURRENT LOADINGS ABOVE 100.0 % OF RATING SET A:

X-----X	X-----X	X-----X	X-----X	X-----X	RATING	PERCENT
FROM BUS	---	TO BUS	---	CRT	LOADING	
X-----X	X-----X	X-----X	X-----X	X-----X	X-----X	X-----X
BUS#	NAME	BUS#	NAME	CRT	LOADING	RATING
X--	--X	X--	--X	X--	X--	X--
BUS#	AREA	BUS#	AREA	CRT	LOADING	RATING
5	514169	5	514169	5	5	5
514104	MAHESH-TS	400.00	514169	1	734.2	107.8
514104	MAHESH-TS	400.00	DAMARCHARLA	2	734.2	681.0
			DAMARCHARLA	5	681.0	107.8

## OUTPUT FOR ZONE 51 [TELANGANA ]

## OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS NOT APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

X-----	BUS	X-----X	THREE PHASE FAULT /I+/-	X----LG FAULT---X AN(I+)	/3I0/-	AN(I+)
514001	[RSTP	400.00]	AMP 38322.9	-86.91	38001.0	-87.05
514002	[HYDP	400.00]	AMP 34905.2	-85.74	19123.3	-79.02
514003	[NSAG	400.00]	AMP 32905.0	-85.19	16788.9	-77.96
514004	[KHAM	400.00]	AMP 43752.4	-86.53	26737.0	-81.19
514009	[CHAND-SR	400.00]	AMP 6469.6	-85.17	4008.9	-78.88
514011	[SSLBPH4	400.00]	AMP 21375.9	-86.29	18480.2	-85.79
514012	[HYDR-AP4	400.00]	AMP 25992.8	-85.78	13746.8	-78.92
514020	[RAM-PVT4	400.00]	AMP 26858.5	-86.20	21107.9	-82.51
514021	[DICHPAL4	400.00]	AMP 36924.9	-86.86	16729.7	-79.69
514022	[GAJWEL4	400.00]	AMP 32270.3	-85.87	18348.0	-79.70
514023	[MAHABUB4	400.00]	AMP 35022.0	-86.37	16881.4	-79.79
514029	[KAKTIA-G	400.00]	AMP 28493.3	-86.67	23827.3	-86.31
514031	[SINGARENI	400.00]	AMP 21435.0	-87.80	22225.4	-87.95
514049	[KOTH-IV	400.00]	AMP 15766.2	-85.97	12816.7	-84.72
514051	[MAILARM4	400.00]	AMP 32585.3	-85.91	15958.2	-79.33
514052	[MALKARM4	400.00]	AMP 22407.5	-85.81	11127.2	-78.50
514060	[SURYPET4	400.00]	AMP 30895.5	-86.42	16091.5	-80.27
514061	[NIZAMABAD	400.00]	AMP 35301.8	-87.18	14469.7	-79.14
514062	[NIRMAL	400.00]	AMP 20677.9	-86.24	11471.2	-80.47
514078	[WARANGAL NEW	400.00]	AMP 38277.5	-87.53	17109.7	-80.47
514079	[WARN4	400.00]	AMP 38748.3	-87.21	19086.4	-80.61
514080	[KOTH-VII	400.00]	AMP 29243.6	-87.56	20561.9	-85.25
514095	[BOOMMANAPALLY	400.00]	AMP 39965.6	-87.43	26416.0	-83.59
514100	[NARSAPUR	400.00]	AMP 32894.7	-85.85	16738.0	-79.33
514101	[MAHESWRM	400.00]	AMP 52107.5	-87.08	21405.5	-79.18
514104	[MAHESH-TS	400.00]	AMP 51332.3	-86.90	21746.7	-79.27
514105	[RAMADAGU	400.00]	AMP 30180.0	-86.47	17360.4	-80.64
514106	[TIFFPAPUR	400.00]	AMP 33310.0	-86.28	19607.0	-80.74
514107	[CHOPPADANDI	400.00]	AMP 28156.3	-86.29	16093.9	-80.47
514108	[MYDARAM	400.00]	AMP 21333.2	-86.53	11732.2	-80.27
514131	[MANIKONDA	400.00]	AMP 22307.4	-86.29	11102.3	-79.52
514134	[MANUGURU	400.00]	AMP 21876.1	-88.06	17250.1	-87.08
514135	[ASUPAKA	400.00]	AMP 7538.7	-84.93	4174.6	-79.43
514152	[DINDI	400.00]	AMP 15926.3	-86.11	6523.4	-79.41
514164	[PARIGI	400.00]	AMP 19160.0	-86.44	8568.8	-79.20
514165	[JANAGAON	400.00]	AMP 29321.3	-86.57	15755.2	-80.31
514169	[DAMARCHARLA	400.00]	AMP 50285.0	-88.46	47158.8	-88.57
514170	[CHOUTTUPPAL	400.00]	AMP 12594.7	-85.96	5823.2	-79.64
514171	[MADARAM	400.00]	AMP 19232.6	-86.53	9089.0	-79.47
514172	[NANCHRLAKOTA	400.00]	AMP 17859.2	-86.50	8240.1	-79.33
518051	[HYDR_800	765.00]	AMP 33100.2	-87.79	1906.6	-77.11
518062	[NIZAMABAD	765.00]	AMP 23196.1	-87.57	1584.1	-77.07
518079	[WARN800	765.00]	AMP 30194.0	-87.69	1987.0	-77.20

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E

MON, APR 27 2015 12:10  
ZONE TOTALS  
IN MW/MVAR

-NET INTERCHANGE-



PTI INTERACTIVE POWER SYSTEM SIMULATOR - PSS(R)E

MON, APR 27 2015 12:12  
AREA TIE LINE  
INTERCHANGE

FROM ZONE . 51 TELANGANA

TO ZONE	50 ANDHRA	X--- FROM ZONE BUS	X---X BASKV	X---- TO ZONE BUS	X---X BASKV	CRT	MW	MVAR	TWO TRM DC "11"
X--- FROM ZONE	37 IPP	BUS# X-- NAME	--X BASKV	BUS# X-- NAME	--X BASKV	400.00	-497.0	-6.0	251.6 TWO TRM DC "11"
512003 NSAG	220.00*	512005 VJJA	220.00	512005 VJJA	220.00	1	3.7	-6.0	251.6 TWO TRM DC "12"
512003 NSAG	220.00*	512005 VJJA	220.00	512005 VJJA	220.00	2	3.7	-6.0	
512003 NSAG	220.00*	512050 SRIS	220.00*	512050 SRIS	220.00*	1	-2.7	11.3	
512003 NSAG	220.00	512073 SRIS	220.00*	512073 SRIS	220.00*	2	-2.7	11.3	
512003 NSAG	220.00	512073 SRIS	220.00*	512073 SRIS	220.00*	3	-2.7	11.3	
512049 KOTH	220.00*	512050 LISLU	220.00	512050 LISLU	220.00	1	-94.5	32.3	
512049 KOTH	220.00*	512050 LISLU	220.00	512050 LISLU	220.00	2	-76.5	22.0	
512055 SURYAPET2	220.00*	512035 CHILAKAL	220.00	512035 CHILAKAL	220.00	1	71.2	5.1	
512104 WANPRTHY	220.00*	512103 BRAHMTR	220.00	512103 BRAHMTR	220.00	2	93.7	53.9	
512152 DINDI	220.00*	512073 SRIS	220.00	512073 SRIS	220.00	1	103.4	3.2	
512174 HUZURANAGAR	220.00*	512035 CHILAKAL	220.00	512035 CHILAKAL	220.00	2	22.5	-36.6	
514003 NSAG	400.00	514026 KUPL-HEN	400.00*	514026 KUPL-HEN	400.00	1	-82.4	-33.8	
514003 NSAG	400.00*	514995 ESC-3	400.00	514995 ESC-3	400.00	2	121.0	84.4	
514003 NSAG	400.00*	514999 FSC-4	400.00	514999 FSC-4	400.00	1	121.0	84.4	
514004 SHAM	420.00*	514005 VJJA	400.00*	514005 VJJA	400.00*	1	37.7	-11.1	
514014 KHAK	420.00*	514016 LAROC	400.00*	514016 LAROC	400.00*	1	-189.9	67.3	
514014 KHAK	400.00*	514015 KURNOC4	400.00	514015 KURNOC4	400.00	1	205.6	-74.2	
514014 SULBPH4	400.00*	514026 VJJA-SF	400.00	514026 VJJA-SF	400.00	1	-31.0	-45.3	
514014 SULBPH4	400.00	514026 VJJA-SF	400.00*	514026 VJJA-SF	400.00*	2	-31.0	-45.3	
514014 SSI-BPH4	400.00	514026 VJJA-SF	400.00*	514026 VJJA-SF	400.00*	2	-31.0	-45.3	
514023 MAHABUBA4	420.00*	514133 UVVRNU	400.00	514133 UVVRNU	400.00	1	69.7	-16.6	
514023 MAHABUBA4	400.00*	514133 UVVRNU	400.00	514133 UVVRNU	400.00	2	69.7	-16.6	
514052 MALKRHA	400.00	514030 VJJA-TV	400.00*	514030 VJJA-TV	400.00*	2	-194.9	-23.9	
514063 SURPET4	400.00	514030 VJJA-TV	400.00*	514030 VJJA-TV	400.00*	1	-63.9	34.2	
514060 SURPET4	400.00*	514111 KYROTA40	400.00	514111 KYROTA40	400.00	1	-213.7	-54.3	
514060 SURPET4	400.00*	514111 KYROTA40	400.00	514111 KYROTA40	400.00	2	-213.7	-54.3	
514101 MAHEWRI	400.00	514013 KUANSCL4	400.00	514013 KUANSCL4	400.00	1	87.4	-83.9	
514115 ASUPAGA	400.00	514016 VJJA-SF	400.00*	514016 VJJA-SF	400.00*	2	-192.0	159.2	
514051 HYDR_809	765.00*	514026 VJJA-SF	765.00	514026 VJJA-SF	765.00	1	62.4	-35.4	
514051 HYDR_810	765.00*	514026 VJJA-SF	765.00	514026 VJJA-SF	765.00	2	62.4	-35.4	
514078 WARUBOO	765.00*	514099 GEM-A06	765.05	514099 GEM-A06	765.05	1	9.3	-34.6	
514078 WARUBOO	765.00*	514099 GEM-A06	765.05	514099 GEM-A06	765.05	2	9.3	-34.6	
TOTAL FROM ZONE	51 TO ZONE	50					-200.1	-153.5	

TO ZONE	52 KARNATAKA	X--- FROM ZONE BUS	X---X BASKV	X---- TO ZONE BUS	X---X BASKV	CRT	MW	MVAR
X--- FROM ZONE	37 IPP	BUS# X-- NAME	--X BASKV	BUS# X-- NAME	--X BASKV	400.00	-85.5	8.3
512003 NSAG	220.00*	522003 RAIC	220.00	522003 RAIC	220.00	1	-85.5	8.3
514014 JURLPRKR	220.00*	522003 RAIC	220.00	522003 RAIC	220.00	2	-274.5	45.9
514014 JURLPRKR	220.00*	522003 RAIC	220.00	522003 RAIC	220.00	1	-274.5	45.9
514023 MAHABUBA	400.00*	522003 RAIC	400.00	522003 RAIC	400.00	1	-445.6	52.4
TOTAL FROM ZONE	51 TO ZONE	52						

## PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS(R)E

MON, APR 27 2015 12:11

ZONE TOTALS

IN MH/MVAR

	FROM	AT ZONE	BUSES	TO IND	TO IND	TO	TO	TO LINE	FROM	TO	TO TIE	TO TIES	-NET INTERCHANGE-
X-- ZONE - -X	GENE- RATION	FROM IND	GENERA-TN	MOTORS	LOAD	TO BUS	GNF BUS	SHUNT DEVICES	SHUNT	CHARGING	LOSSES	LINES	+ LOADS
51	13260.0	0.0	0.0	15716.4	0.0	0.0	0.0	0.0	0.0	597.2	-3053.6	-3053.6	
TELANGANA	1476.7	0.0	0.0	5165.7	-196.9	0.0	3368.1	12657.2	6576.3	-779.3	-779.3		
58	*	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
TIE-LOAD	*	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
COLUMN TOTALS	13260.0	0.0	0.0	15716.4	0.0	0.0	0.0	0.0	597.2	-3053.6	-3053.6		
TOTALS	1476.7	0.0	0.0	5165.7	-196.9	0.0	3368.1	12657.2	6576.3	-779.3	-779.3		

OUTPUT FOR ZONE 51 [TELANGANA ]  
 SUBSYSTEM LOADING CHECK (INCLUDED: TRANSFORMERS) (EXCLUDED: LINES; BREAKERS AND SWITCHES)  
 MVA LOADINGS ABOVE 60.0 % OF RATING SET A:

X----- FROM BUS -----X	X----- TO BUS -----X	BUS#	X-- NAME	--X BASKV	AREA	BUS#	X-- NAME	--X BASKV	AREA	CKT	LOADING	RATING	PERCENT
511001 RSTP	132.00	5	514001 RSTP		400.00*	5	1	595.3	400.0	148.8			
512001 RMGD	220.00	5	514001 RSTP		400.00*	5	1	635.5	815.9	78.8			
512002 HYDR	220.00	5	514002 HYDR		400.00*	5	1	1342.1	1445.0	93.4			
512012 HYDAP2	220.00	5	514012 HYDR-AP4		400.00*	5	1	1266.5	1260.0	100.5			
512022 GAJWEL2	220.00	5	514022 GAJWEL4		400.00*	5	1	1102.4	630.0	175.0			
512022 GAJWEL2	220.00	5	514022 GAJWEL4		400.00*	5	2	551.2	315.0	175.0			
512023 MEHBOBNG	220.00	5	514023 MAHABUB4		400.00*	5	1	639.7	630.0	101.5			
512051 MAILRM	220.00	5	514051 MAILARM4		400.00*	5	1	1091.6	945.0	115.5			
512052 MALKARAM	220.00	5	514052 MALKARM4		400.00*	5	1	1054.5	945.0	111.6			
512060 SURYAPET2	220.00	5	514060 SURYPET4		400.00*	5	1	606.5	630.0	95.3			
512079 WRNG	220.00	5	514079 WARN4		400.00*	5	1	1124.5	1130.0	99.5			
512100 NARSAPUR2	220.00	5	514100 NARSAPUR		400.00*	5	1	378.7	315.0	120.2			
512100 NARSAPUR2	220.00	5	514100 NARSAPUR		400.00*	5	2	378.7	315.0	120.2			
512131 MANIKONDA2	220.00	5	514131 MANIKONDA		400.00*	5	1	211.5	315.0	67.2			
512131 MANIKONDA2	220.00	5	514131 MANIKONDA		400.00*	5	2	211.5	315.0	67.2			
512152 DINDI	220.00	5	514152 DINDI		400.00*	5	1	371.5	500.0	74.3			
512152 DINDI	220.00	5	514152 DINDI		400.00*	5	2	371.5	500.0	74.3			
512152 DINDI	220.00	5	514152 DINDI		400.00*	5	3	371.5	500.0	74.3			
512160 PARIGI-LI	220.00	5	514164 PARIGI		400.00*	5	1	277.6	315.0	88.1			
512160 PARIGI-LI	220.00	5	514164 PARIGI		400.00*	5	2	277.6	315.0	88.1			

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E      MON, APR 27 2015 12:49  
 AREA TOTALS  
 IN MW/MVAR

X--- AREA ---X	FROM -----AT AREA BUSES-----	TO	-NET INTERCHANGE-
	GNS- FROM IND TO IND TO BUS GNE BUS	TO LINE, CHARGING	TO TIE LINES
	GENERATION MOTORS LOAD SHUNT DEVICES	FROM LOSSES	+ LOADS
1 NORTH	42687.3 0.0 0.0 65153.7 0.0 0.0 2.3 0.0 2720.8 -25189.5 -25189.5 0.0	0.0 21893.8 72253.2 31297.3 2986.4 2986.4	
2 NORTHEAST	-6414.1 0.0 0.0 16520.1 -6853.4 0.0 0.0 0.0 97.3 892.2 882.1 0.0		
3 WEST	4149.4 0.0 0.0 3159.0 0.0 0.0 0.0 0.0 646.4 -45.6 -47.7	0.0 1380.3 5129.3	
4 EAST	-870.6 0.0 0.0 956.3 1321.4 0.0 0.0 0.0 3660.1 17128.7 17128.7 0.0		
5 SOUTH	85060.7 0.0 0.0 64271.9 0.0 0.0 0.0 0.0 50435.2 -4696.0 -4696.0	50059.0 100802.9	
6 BHUTAN	-5014.7 0.0 0.0 9396.1 -9406.1 0.0 0.0 0.0 1763.2 -16095.3 -16095.3 -6200.0		
7 BAUGLADESH	49792.9 0.0 0.0 25959.8 0.0 0.0 203.5 0.0 1033.2 22596.3 22606.4 0.0	0.0 8873.4 31890.6 12974.8 -1058.5 -1056.5	
COLUMN TOTALS	2422959.5 0.0 0.0 232459.1 0.0 0.0 205.8 0.0 9294.6 0.0 0.0 0.0	96600.6 268375.1 119069.2 0.0 0.0 -6200.0	
TOTALS	-15816.2 0.0 0.0 48952.7 -12663.6 0.0 0.0 0.0 103.1 107.1 -48.0 -48.0		

OUTPUT FOR ZONE 51 (TELANGANA )  
SUBSYSTEM LOADING CHECK (INCLUDED: LINES) (EXCLUDED: BREAKERS AND SWITCHES; TRANSFORMERS)

CURRENT LOADINGS ABOVE 100.0 % OF RATING SET A:

X-----	FROM BUS	X-----	TO BUS	X-----
BUS#	X-- NAME --X	AREA	BUS# X-- NAME --X	AREA
				CRT
514021	DICHPALA4	400.00*	5 514061	NIZAMABAD
514021	DICHPALA4	400.00*	5 514061	NTZAMABAD
514023	MAHABUB4	400.00	5 514171	MADARAM
514023	MAHABUB4	400.00	5 514171	MADARAM
514023	MAHABUB4	400.00	5 524003	RAIC
514101	MAHESWRM	400.00	5 514104	MAHESH-TS
514101	MAHESWRM	400.00	5 514104	MAHESH-TS

PSS(R) E-33.4.0 ASCC SHORT CIRCUIT CURRENTS

MON, APR 27 2015 12:

OUTPUT FOR ZONE 51 [TELANGANA]

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/-0 SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS NOT APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

X----- BUS -----X		THREE PHASE FAULT /I+/ AN(I+)	X---LG FAULT---X /3I0/ AN(I+)
514001 [RSTP]	400.00] AMP	38445.6 -86.91	38081.4 -87.05
514002 [HYDR]	400.00] AMP	35113.2 -85.73	19164.4 -79.00
514003 [NSAG]	400.00] AMP	33778.3 -85.41	16939.4 -77.97
514004 [KHAM]	400.00] AMP	44093.3 -86.55	26821.3 -81.18
514009 [CHAND-SR]	400.00] AMP	6473.1 -85.17	4009.8 -78.88
514011 [SSLBPH4]	400.00] AMP	21416.9 -86.28	18500.5 -85.78
514012 [HYDR-AP4]	400.00] AMP	26096.5 -85.77	13765.9 -78.91
514020 [RAM-PVT4]	400.00] AMP	26917.3 -86.19	21132.1 -82.50
514021 [DICHPAL4]	400.00] AMP	37007.7 -86.85	16740.9 -79.69
514022 [GAJWEL4]	400.00] AMP	32376.8 -85.86	18370.6 -79.69
514023 [MAHABUB4]	400.00] AMP	35466.9 -86.41	16949.7 -79.78
514029 [KAKTIA-G]	400.00] AMP	28538.9 -86.66	23848.5 -86.31
514031 [SINGARENI]	400.00] AMP	21449.7 -87.80	22236.0 -87.95
514049 [KOTH-IV]	400.00] AMP	15802.6 -85.97	12832.7 -84.72
514051 [MAILARM4]	400.00] AMP	32724.7 -85.91	15980.2 -79.32
514052 [MALKARM4]	400.00] AMP	22501.6 -85.81	11142.6 -78.49
514060 [SURYPET4]	400.00] AMP	31078.4 -86.43	16124.4 -80.26
514061 [NIZAMABAD]	400.00] AMP	35372.5 -87.17	14477.5 -79.13
514062 [NIRMAL]	400.00] AMP	20699.3 -86.23	11475.5 -80.46
514078 [WARANGAL NEW400.00]	AMP	38374.7 -87.53	17122.4 -80.46
514079 [WARN4]	400.00] AMP	38851.1 -87.20	19102.9 -80.61
514080 [KOTH-VII]	400.00] AMP	29321.6 -87.56	20587.5 -85.25
514095 [BOMMANAPALLY400.00]	AMP	39824.9 -87.43	26465.6 -83.58
514100 [NARSAPUR]	400.00] AMP	33019.7 -85.84	16759.3 -79.32
514101 [MAHESWRM]	400.00] AMP	52530.3 -87.08	21452.4 -79.17
514104 [MAHESH-TS]	400.00] AMP	51749.9 -86.91	21796.0 -79.25
514105 [RAMADAGU]	400.00] AMP	30239.8 -86.46	17373.5 -80.63
514106 [TIPPAPUR]	400.00] AMP	33390.6 -86.28	19625.4 -80.76
514107 [CHOPPADANDI]	400.00] AMP	28210.2 -86.29	16105.5 -80.46
514108 [MYDARAM]	400.00] AMP	21363.0 -86.53	11738.1 -80.27
514131 [MANIKONDA]	400.00] AMP	22375.5 -86.28	11113.4 -79.51
514134 [MANUGURU]	400.00] AMP	21903.5 -88.06	17261.5 -87.08
514135 [ASUPAKA]	400.00] AMP	7545.2 -84.92	4175.9 -79.43
514152 [DINDI]	400.00] AMP	15988.8 -86.09	6530.3 -79.39
514164 [PARIGI]	400.00] AMP	19240.1 -86.44	8579.4 -79.19
514165 [JANAGAON]	400.00] AMP	29386.5 -86.56	15767.6 -80.30
514169 [DAMARCHARLA]	400.00] AMP	50407.0 -88.45	47230.2 -88.56
514170 [CHOUTTUPPAL]	400.00] AMP	12606.0 -85.95	5824.8 -79.64
514171 [MADARAM]	400.00] AMP	19340.1 -86.54	9105.0 -79.47
514172 [NANCHRLAKOTA400.00]	AMP	17938.3 -86.51	8251.3 -79.33
518051 [HYDR_800]	765.00] AMP	33275.5 -87.79	1907.0 -77.10
518062 [NIZAMABAD]	765.00] AMP	23241.6 -87.57	1584.2 -77.08
518079 [WARN800]	765.00] AMP	30293.9 -87.69	1987.3 -77.20

## PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS(R)E

MON, APR 27 2015 13:01  
 AREA TIE LINE  
 INTERCHANGE

FROM AREA	5	SOUTH	TO AREA	3	WEST	X---X	X-----TO AREA BUS	----X	CKT	MW	MVAR	
			X--- FROM AREA BUS	--X	BASKV	X-- NAME --X	BUS# X-- NAME --X	BASKV		251.6	TWO	TRM DC "11"
			X-- BUS#	X-- NAME	--X				2DC	-497.0	251.6	TWO TRM DC "12"
			514009	CHAMPSR	400.00*	374007	BHADRA	400.00	2DC	-497.0	251.6	TWO TRM DC "12"
			514009	CHAMPSR	400.00*	374007	BHADRA	400.00	2DC	-497.0	251.6	TWO TRM DC "12"
			544016	PUGALUR-NEW	400.00*	314029	RAIGARH_POOL	400.00	2DC	-1906.8	789.1	TWO TRM DC "34"
			544016	PUGALUR-NEW	400.00*	314029	RAIGARH_POOL	400.00	2DC	-1908.8	789.1	TWO TRM DC "34"
			518029	DUMY_BU	765.00	378040	SHOLAPUR-PG	765.00*	4	-2196.3	-69.9	
			518062	NTZAMABAD	765.00*	378021	WARDHA	765.00	1	-1071.0	46.9	
			518062	NTZAMABAD	765.00*	378021	WARDHA	765.00	2	-1071.0	46.9	
			518079	WARNBHO	765.00	378091	WARORA_POOL	765.00*	1	-1039.0	143.4	
			518079	WARNBHO	765.00	378091	WARORA_POOL	765.00*	2	-1039.0	143.4	
			524015	NARDR-NW	400.00*	374050	KOLHAPURPG	400.00	1	596.4	5.7	
			524015	NARDR-NW	400.00*	374050	KOLHAPURPG	400.00	2	596.4	5.7	
			TOTAL	FROM AREA		5	TO AREA	3		-10035.1	2403.4	
TO AREA	4	EAST	X---X	X-----TO AREA BUS	----X	CKT	MW	MVAR				
X--- FROM AREA BUS	--X	BASKV	BUS# X-- NAME --X	BASKV								
BUS#	X-- NAME	--X	BASKV									
524011	KOLAR	400.00	424019	TALCHER	400.00*	2DC	-1004.8	-413.1	TWO	TRM DC "10"		
514010	GAZU-SR	400.00*	424009	GAZUWAKA_ER	400.00	2DC	-323.2	175.5	TWO	TRM DC "13"		
514010	GAZU-SR	400.00*	424009	GAZUWAKA_ER	400.00	2DC	-323.2	175.5	TWO	TRM DC "14"		
524011	KOLAR	400.00	424019	TALCHER	400.00*	2DC	-1004.8	-413.1	TWO	TRM DC "9"		
518091	SRI_POOL	765.00	428014	ANGUL	765.00*	1	-1680.1	50.5				
518091	SRI_POOL	765.00	428014	ANGUL	765.00*	2	-1680.1	50.5				
TOTAL	FROM AREA	5	TO AREA	4			6016.3	-374.3				
TOTAL	FROM AREA	5	SOUTH				-16051.4	2029.2				

## PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)

MON, AFR 27 2015 12:45  
 AREA TIE LINE  
 INTERCHANGE

FROM AREA 5 &gt; SOUTH

TO AREA 3 WEST

X---X FROM-AREA BUS	X---X TO AREA BUS	CKT	MW	MVAR
BUS# X-- NAME --X BASKV	BUS# X-- NAME --X BASKV	2DC	-497.0	251.6 TWO TRM DC "11"
514009 CHAND-SR	400.00*	374007 BHADRA	400.00	251.6 TWO TRM DC "12"
514009 CHAND-SR	400.00*	374007 BHADRA	400.00	251.6 TWO TRM DC "12"
544016 EUGALUR-NEW	400.00*	314029 RAIGARH_POOL	400.00	2DC 2795.9 1304.1 TWO TRM DC "33"
544016 EUGALUR-NEW	400.00*	314029 RAIGARH_POOL	400.00	2DC 2795.9 1304.1 TWO TRM DC "34"
518029 DAMY_BU	765.00	378040 SHOLAPUR-PG	765.00*	4 -1902.8 -19.0
518062 NTZAMABAD	765.00*	378021 MARDHA	765.00	1 -860.4 8.2
518062 NTZAMABAD	765.00*	378021 MARDHA	765.00	1 -860.4 8.2
518079 WARN800		374091 WARORA_POOL	765.00*	1 -817.1 157.5
518079 WARN800	765.00	379091 WARORA_POOL	765.00*	2 -817.1 157.5
524015 NADR-NW	400.00*	374050 KOLHAPURPG	400.00	1 683.0 17.9
524015 NADR-NW	400.00*	374050 KOLHAPURPG	400.00	2 683.0 17.9
TOTAL FROM AREA 5 TO AREA 3	3		-10477.5	3459.7

TOTAL FROM AREA

5 SOUTH

TO AREA 4 EAST

X---X FROM AREA BUS	X---X TO AREA BUS	CKT	MW	MVAR
BUS# X-- NAME --X BASKV	BUS# X-- NAME --X BASKV	2DC	-1004.8	-413.1 TWO TRM DC "10"
524011 KOLAR	400.00	424019 TALCHER	400.00*	323.2 175.5 TWO TRM DC "13"
514010 GAZU_SR	400.00*	424099 GAZUWAKA-ER	400.00	2DC 223.2 175.5 TWO TRM DC "14"
514010 GAZU_SR	400.00*	424099 GAZUWAKA-ER	400.00	2DC 223.2 175.5 TWO TRM DC "14"
524011 KOLAR	400.00	424019 TALCHER	400.00*	2DC -1004.8 -413.1 TWO TRM DC "9"
518051 SRL_POOL	765.00	428014 ANGUL	765.00*	1 -1480.9 108.4
518091 SRT_POOL	765.00	428014 ANGUL	765.00*	2 1480.9 108.4
TOTAL FROM AREA 5 TO AREA 4	4		-5617.8	-258.4
TOTAL FROM AREA	5	SOUTH	-16095.3	3201.2

PTI INTERACTIVE POWER SYSTEM SIMULATOR--FSS (R)E  
MON APR 27 2015 12:51  
ZONE TOTALS  
IN MW/MVAR

		TO LINE LOADS	NET INTERCHANGE
		FROM TIE LINES	TO TIE LINES
X-- ZONE	-X		
50 ANDHRA	13230.8 462.9	0.0 0.0	0.0 0.0
51 TELANGANA	12265.0 -1302.0	0.0 0.0	0.0 0.0
52 KARNATAKA	12359.9 -1924.2	0.0 0.0	0.0 0.0
53 KERALA	1644.9 276.4	0.0 0.0	0.0 0.0
54 TAMILNAD	19733.7 389.9	0.0 0.0	0.0 0.0
55 CENTRAL	0.0 0.0	0.0 0.0	0.0 0.0
56 TN-WIND	-80.0 30.0	0.0 0.0	0.0 0.0
57 PONR	-6.8 0.0	0.0 0.0	0.0 0.0
58 TEL-LOAD	0.0 0.0	0.0 0.0	0.0 0.0
COLUMNS	59264.3 -2183.8	0.0 0.0	0.0 0.0
TOTALS	1882.8	13324.1	56674.1

FROM ZONE	5.1	TELANGANA						
TO ZONE	5.0	ANDHRA						
X---- FROM ZONE BUS	---X	X---- TO ZONE BUS						
BUS# X-- NAME --X	BASKV	BUS# X-- NAME --X						
512003 NSAG	220.00*	512005 VTJA	220.00	1	16.9	=13.9	MMW	MVAR
512003 NSAG	220.00*	512005 VTJA	220.00	2	16.9	=13.9	MMW	MVAR
512003 NSAG	220.00	512005 VTJA	220.00*	1	30.4	1.7	CRT	MMW
512003 NSAG	220.00	512005 VTJA	220.00*	2	30.4	1.7	CRT	MVAR
512003 NSAG	220.00	512005 VTJA	220.00*	3	30.4	1.7	CRT	MVAR
512049 KOTH	220.00*	512005 VTJA	220.00	1	37.4	=14.0	CRT	MMW
512049 KOTH	220.00*	512050 LJSRBU	220.00	2	-120.9	22.1	CRT	MVAR
512049 KOTH	220.00*	512050 LJSRBU	220.00	2	-97.9	13.9	CRT	MMW
512060 SURYAPET2	220.00*	512035 CHILAKAL	220.00	1	31.2	5.6	CRT	MVAR
512106 WANFRTHY	220.00*	512103 BRAHMKTR	220.00	2	60.0	71.5	CRT	MMW
512152 DINDI	220.00*	512073 SRIS	220.00*	1	-66.5	-7.8	CRT	MVAR
512152 DINDI	220.00*	512073 SRIS	220.00	2	-66.5	-7.8	CRT	MMW
512174 HUZURBANAGAP	220.00*	512035 CHILAKAL	220.00	1	-56.8	29.4	CRT	MVAR
514903 NSAG	400.00*	514998 FSC-3	400.00*	1	-56.1	51.0	CRT	MMW
514903 NSAG	400.00*	514998 FSC-3	400.00*	2	-41.0	-72.9	CRT	MVAR
514903 NSAG	400.00*	514999 FSC-4	400.00	1	-41.0	72.9	CRT	MMW
514904 KHAK	400.00*	514005 VTJA	400.00	1	172.0	35.6	CRT	MVAR
514911 SSLBPH4	400.00*	514016 LIZPOOL	400.00*	1	-262.8	64.6	CRT	MMW
514911 SSLBPH4	400.00*	514013 KURNool4	400.00	1	-158.8	-126.3	CRT	MVAR
514911 SSLBPH4	400.00*	514026 VLTJ-AP	400.00	1	-52.9	-86.9	CRT	MMW
514911 SSLBPH4	400.00*	514026 VLTJ-AP	400.00	2	-53.1	-32.4	CRT	MVAR
514923 MAHABUBA4	400.00*	514133 ORVEND	400.00	1	-11.0	175.1	CRT	MMW
514923 MAHABUBA4	400.00*	514133 ORVEND	400.00	2	-11.0	-175.1	CRT	MVAR
514952 MALKARMA4	400.00	514030 VIJTP-IV	400.00*	1	-303.1	15.2	CRT	MMW
514960 SURYPET4	400.00	514030 VIJTP-IV	400.00*	1	-220.9	62.9	CRT	MVAR
514960 SURYPET4	400.00*	514111 KVROTA40	400.00	1	-347.2	-9.1	CRT	MMW
514960 SURYPET4	400.00*	514111 KVROTA40	400.00	2	-347.2	9.1	CRT	MVAR
514961 MAHESWARI	400.00*	514013 KURNool4	400.00	1	-206.0	41.0	CRT	MMW
514975 ASUFEKA	400.00	514016 VIZPOOL	400.00*	1	-337.8	59.6	CRT	MVAR
518051 HYDR-800	765.00*	518028 KURIBHOO	765.00	1	-358.7	-255.6	CRT	MMW
518051 HYDR-800	765.00*	518028 KURIBHOO	765.00	2	-358.7	-255.6	CRT	MVAR
518079 WARM800	765.00*	518029 CPETABOO	765.00	1	-172.3	31.0	CRT	MMW
518079 WARM800	765.00*	518029 CPETABOO	765.00	2	-172.3	-31.0	CRT	MVAR
TOTAL FROM ZONE	51	TO ZONE	5C		-3721.3	-1527.6		

TO ZONE 5.2 KARIMPATRA  
 X---- FROM ZONE BUS ---X  
 BUS# X-- NAME --X  
 512019 JURLPRK 220.00\* 522003 RATC 220.00 1 -497.5 4.1  
 512019 JURLPRK 220.00\* 522003 RATC 220.00 2 -47.5 4.1  
 512023 MAHABUBA4 400.00\* 522003 RATC 400.00 1 -896.2 56.9  
 TOTAL FROM ZONE 51 TO ZONE 52

## PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(RIVE)

MON, APR 27 2015 12:50

ZONE TOTALS

FROM -----AT ZONE BUSSES-----

TO IND TO IND TO BUS GNE BUS TO LINE FROM

GENE- FROM IND MOTORS LOAD SHUNT DEVICES SHUNT CHARGING

TO TIE LINES LOSSES TO TIE LINES + LOADS

X - ZONE --X RATION GENERATN

51	12265.0	0.0	0.0	20879.7	0.0	0.0	0.0	0.0	426.8	-9041.5	-4392.5
TELANGAMA	-1302.0	0.0	0.0	4239.8	-1296.1	0.0	3358.9	12637.1	5680.6	-628.1	334.2
58	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TEL-LOAD	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	962.3
COLUMN TOTALS	12265.0	0.0	0.0	20879.7	0.0	0.0	0.0	0.0	426.8	-9041.5	-4390.0
TOTALS	-1302.0	0.0	0.0	4239.8	-1296.1	0.0	3358.9	12637.1	5680.6	-628.1	334.2

OUTPUT FOR ZONE 51 (TELANGANA )  
 SUBSYSTEM LOADING CHECK (INCLUDED: TRANSFORMERS) (EXCLUDED: LINES, BREAKERS AND SWITCHES)  
 MVA LOADINGS ABOVE - 60.0 % OF RATING SET A:

X-----	FROM BUS	X-----X	TO BUS	X-----X								
BUS#	X-- NAME	--X BASKV	AREA	BUS#	X-- NAME	--X BASKV	AREA	CKT	LOADING	RATING	PERCENT	
511001	RSTP	132.00	5	514001	RSTP	400.00*	5	1	549.0	400.0	137.2	
512001	RGD	220.00	5	514001	RSTP	400.00*	5	1	623.1	815.0	76.5	
512002	HYDR	220.00	5	514002	HYDR	400.00*	5	1	1251.3	1445.0	86.6	
512012	HYDAP2	220.00	5	514012	HYDR_AP4	400.00*	5	1	1546.4	1260.0	122.7	
512022	GAJWELL2	220.00	5	514022	GAJWELA	400.00*	5	1	850.5	630.0	135.0	
512022	GAJWELL2	220.00	5	514022	GAJWELA	400.00*	5	2	376.3	315.0	119.5	
512051	MATLRM	220.00	5	514051	MATLARMA	400.00*	5	1	997.9	945.0	105.6	
512052	MALKARAM	220.00	5	514052	MALKARMA	400.00*	5	1	1017.4	945.0	107.7	
512060	SURYAPET2	220.00	5	514060	SURYPET4	400.00*	5	1	536.5	630.0	85.2	
512079	WRNG	220.00	5	514079	WARN4	400.00*	5	1	1120.4	1130.0	99.1	
512100	NARSAPUR2	220.00	5	514100	NARSAPUR	400.00*	5	1	442.0	315.0	140.3	
512100	NARSAPUR2	220.00	5	514100	NARSAPUR	400.00*	5	2	442.0	315.0	140.3	
512131	MANIKONDA2	220.00	5	514131	MANIKONDA	400.00*	5	1	200.8	315.0	63.7	
512131	MANIKONDA2	220.00	5	514131	MANIKONDA	400.00*	5	2	200.8	315.0	63.7	
512160	PARIGI-LI	220.00	5	514164	PARIGI	400.00*	5	1	190.9	315.0	60.6	
512160	PARTIGI-LI	220.00	5	514164	PARIGI	400.00*	5	2	190.9	315.0	60.6	
514101	MAHESMRM	400.00	5	518051	HYDR_800	765.00*	5	1	2208.4	3000.0	73.6	

PTI INTERACTIVE POWER SYSTEM SIMULATOR - PSS(E)  
 MON, APR 27 2015 14:38  
 AREA TOTALS  
 IN MW/MVAR

X-- AREA --X	FROM GEN-- FROM RATION GENERATN	TO IND MOTORS	BUSES	TO LOAD	TO BUS SHUNT	GMF BUS DEVICES	TC TO LINE/ CHARGING	FROM LOSSES	-NET INTERCHANGE-		DESIRED NET TMT
									TO TIE	TO TIES + LOADS	
1 NORTH	42687.3	0.0	0.0	65153.7	0.0	0.0	2.3	0.0	2683.5	-25152.2	0.0
	-6615.1	0.0	0.0	16520.1	-6695.4	0.0	21917.7	72301.3	30892.8	3051.0	3051.0
2 NORTHEAST	4148.4	0.0	0.0	3159.0	0.0	0.0	0.0	0.0	97.3	892.2	882.1
	571.4	0.0	0.0	956.3	1321.4	0.0	0.0	0.0	-46.4	-46.4	-48.4
3 WEST	85060.7	0.0	0.0	64271.9	0.0	0.0	50197.1	101025.3	50135.4	-4841.9	0.0
	-5439.8	0.0	0.0	9396.1	-9301.1	0.0	0.0	0.0	0.0	21048.0	-1092.5
4 EAST	48231.9	0.0	0.0	25959.8	0.0	0.0	203.2	0.0	1031.0	21037.9	-1084.5
	-1529.8	0.0	0.0	5201.9	4687.8	0.0	8890.1	31921.5	12706.4	-14595.7	-6200.0
5 SOUTH	51990.7	0.0	0.0	65091.7	0.0	0.0	0.0	0.0	1494.7	-14595.7	3319.3
	1178.4	0.0	0.0	19016.2	983.8	0.0	14466.4	58393.0	19428.9	3319.3	0.0
6 BHUTAN	2005.9	0.0	0.0	318.3	0.0	0.0	0.0	0.0	10.4	1677.2	1677.2
	-142.5	0.0	0.0	114.5	53.9	0.0	56.3	248.7	221.1	-339.6	0.0
7 BANGLADESH	0.0	0.0	0.0	1000.0	0.0	0.0	0.0	0.0	9.6	-1009.6	-1009.6
COLUMN TOTALS	234124.9	0.0	0.0	224954.4	0.0	0.0	205.5	0.0	8965.0	0.0	0.0
TOTALS	15777.3	0.0	0.0	51255.0	-8949.5	0.0	96907.9	269126.3	114138.0	0.0	-6200.0

## OUTPUT FOR ZONE 51 [TELANGANA ]

## OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS NOT APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

X----- BUS -----X			THREE PHASE FAULT /I+/	X---LG FAULT---X
			AN(I+)	/3IO/ AN(I+)
514001	[RSTP 400.00]	AMP	38086.7	-86.95 38710.3 -86.88
514002	[HYDR 400.00]	AMP	34304.0	-85.79 23420.6 -80.90
514003	[NSAG 400.00]	AMP	33428.4	-85.46 23819.7 -82.54
514004	[KHAM 400.00]	AMP	43562.3	-86.59 32110.6 -82.99
514009	[CHAND-SR 400.00]	AMP	6462.9	-85.18 4016.4 -78.84
514011	[SSLBPH4 400.00]	AMP	21302.3	-86.31 18965.0 -85.55
514012	[HYDR-AP4 400.00]	AMP	25726.6	-85.81 17968.0 -81.46
514020	[RAM-BVT4 400.00]	AMP	26734.8	-86.23 21373.1 -82.38
514021	[DICHEPAL4 400.00]	AMP	36474.4	-86.89 25409.6 -81.78
514022	[GAJWEL4 400.00]	AMP	31649.5	-85.91 20672.4 -80.33
514023	[MAHABUB4 400.00]	AMP	34462.1	-86.44 22990.2 -82.04
514029	[AKTIA-G 400.00]	AMP	28218.9	-86.69 25419.8 -85.74
514031	[SINGARENI 400.00]	AMP	21329.9	-87.82 22543.4 -87.85
514049	[KOTH-IV 400.00]	AMP	15745.9	-85.99 13133.5 -84.67
514051	[MAILARM4 400.00]	AMP	31909.1	-85.97 21236.2 -80.95
514052	[MALKARM4 400.00]	AMP	22222.3	-85.84 15560.4 -81.82
514060	[SURYPET4 400.00]	AMP	30787.1	-86.46 20541.4 -82.19
514061	[NIZAMABAD 400.00]	AMP	34929.1	-87.20 24188.6 -82.10
514062	[NIRMAL 400.00]	AMP	20553.6	-86.26 14163.3 -81.53
514078	[WARANGAL NEW400.00]	AMP	37959.9	-87.55 28744.0 -83.55
514079	[WARN4 400.00]	AMP	38409.8	-87.23 29204.5 -83.20
514080	[KOTH-VII 400.00]	AMP	29076.9	-87.59 22057.5 -85.87
514095	[BOMMANAPALLY400.00]	AMP	39298.1	-87.46 29195.7 -84.88
514100	[NARSAPUR 400.00]	AMP	32273.0	-85.90 21435.3 -80.61
514101	[MAHESWRM 400.00]	AMP	49611.5	-87.11 35777.6 -83.04
514104	[MAHESH-TS 400.00]	AMP	48536.0	-86.92 34563.6 -82.71
514105	[RAMADAGU 400.00]	AMP	29665.8	-86.49 20178.2 -81.59
514106	[TIFFAPUR 400.00]	AMP	32250.8	-86.29 21702.9 -81.17
514107	[CHOPPADANDI 400.00]	AMP	27610.5	-86.32 18295.5 -81.19
514108	[MYDARAM 400.00]	AMP	21074.9	-86.55 13661.7 -81.79
514131	[MANIKONDA 400.00]	AMP	22032.6	-86.32 13907.6 -81.59
514134	[MANUGURU 400.00]	AMP	21817.3	-88.07 17901.5 -87.30
514135	[ASUPAKA 400.00]	AMP	7535.2	-84.93 4485.5 -78.08
514152	[DINDI 400.00]	AMP	14286.6	-85.94 10064.5 -83.08
514164	[PARIGI 400.00]	AMP	18857.9	-86.46 11955.7 -82.31
514165	[JANAGAON 400.00]	AMP	27384.4	-86.53 17956.4 -82.44
514169	[DAMARCHARLA 400.00]	AMP	29493.1	-87.35 25807.2 -86.81
514170	[CHOUTTUPPAL 400.00]	AMP	11217.2	-85.79 7413.2 -82.54
514171	[MADARAM 400.00]	AMP	19001.7	-86.55 11907.4 -82.22
514172	[NANCHRLAKOTA400.00]	AMP	17624.1	-86.52 11037.8 -82.26
518051	[HYDR_800 765.00]	AMP	32434.8	-87.78 21316.3 -82.69
518062	[NIZAMABAD 765.00]	AMP	22991.9	-87.58 14249.5 -81.67
518079	[WARN800 765.00]	AMP	29888.6	-87.70 19159.7 -82.30

7 2015 14:40  
AREA TIE LINE  
INTERCHANGE

## PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R) E

MON, APR 27 2015 14:59

AREA TIE LINE  
INTERCHANGE

FROM AREA	5	SOUTH	TO AREA	3	WEST	X--- FROM AREA BUS ---X	X--- TO AREA BUS ---X	CRT	MW	MVAR	
						BUS# X-- NAME --X	BUS# X-- NAME --X				"11"
524019			CHAND-SR	400.00*	374007	BHADRA	400.00	2DC	-497.0	251.6	TWO TRM DC
514009			CHAID-SR	400.00*	374007	BHADRA	400.00	2DC	-497.0	251.6	TWO TRM DC
544016			PUGALUR_NEW	400.00*	314029	RAIGARH_POOL	400.00	2DC	-1908.8	789.1	TWO TRM DC
544016			PUGALUR_NEW	400.00*	314029	RAIGARH_POOL	400.00	2DC	-1908.8	789.1	TWO TRM DC
518029			DUMY_BU	765.00	378040	SHOLAPUR-PG	765.00*	4	-2062.3	-25.5	"34"
518052			NITZAMABAD	765.00*	378021	WARDHA	765.00	1	-798.6	48.5	
518052			NITZAMABAD	765.00*	378021	WARDHA	765.00	2	-798.6	48.5	
518079			WARN800	765.00	378091	WARORA_POOL	765.00*	1	-797.8	143.8	
518079			WARN800	765.00	378091	WARORA_POOL	765.00*	2	-797.8	143.8	
524015			NARDR-NW	400.00*	374050	KOLHAPURPG	400.00	1	558.4	-1.5	
524015			NARDR-NW	400.00*	374050	KOLHAPURPG	400.00	2	558.4	-1.5	
TOTAL FROM AREA	5	SOUTH	5 TO AREA	3					-8950.0	2437.6	
TO AREA	4	EAST	X--- FROM AREA BUS ---X	X--- TO AREA BUS ---X	CRT	MW	MVAR				
			BUS# X-- NAME --X	BUS# X-- NAME --X							
524011			KOLAR	400.00	424019	TAICHER	400.00*	2DC	-1004.8	-478.4	TWO TRM DC
514010			GAZU_SR	400.00*	424099	GAZUWAKA-ER	400.00	2DC	-323.2	175.5	TWO TRM DC
514010			GAZU_SR	400.00*	424099	GAZUWAKA-ER	400.00	2DC	-323.2	175.5	TWO TRM DC
524011			KOLAR	400.00	424019	TAICHER	400.00*	2DC	-1004.8	-478.4	TWO TRM DC
518091			SRI_POOL	765.00	428014	ANGUL	765.00*	1	-1482.7	112.7	
518091			SRI_POOL	765.00	428014	ANGUL	765.00*	2	-1482.7	112.7	
TOTAL FROM AREA	5	SOUTH	4						5621.5	-380.5	
TOTAL FROM AREA	5	SOUTH							-14571.5	2057.1	



## INTERACTIVE POWER SYSTEM SIMULATOR—PSS(R)E

MON APR 27 2015 14:41

ZONE TIE LINE  
INTERCHANGE

FROM ZONE 51 TELANGANA

TO ZONE 37

IPR -

X--- FROM ZONE BUS ---X  
BUS# X-- NAME --X BASKVX-- NAME --X BASKV  
CKT MW MVAR  
400.00\* 374007 BHADRA 400.00 2DC -497.0 251.6 TWO TRM DC "11"  
400.00\* 374007 BHADRA 400.00 2TC -497.0 251.6 TWO TRM DC "12"514009 CHAND SR 400.00\* 374007 BHADRA 400.00 2DC -580.2 28.3  
518062 NIZAMBAD 765.00\* 378021 WARUA 765.00 1 -580.2 28.3518062 NIZAMBAD 765.00\* 378021 WARUA 765.00 1 -572.0 161.1  
518079 WARUBO 765.00 378091 WARORA POOL 765.00\* 1 -572.0 161.1765.00\* 2 -572.0 161.1  
TOTAL FROM ZONE 51 TO ZONE 37 -3298.3 882.0X--- TO ZONE BUS ---X  
BUS# X-- NAME --X BASKVX-- NAME --X BASKV  
CKT MW MVAR  
220.00\* 512005 VIJA 220.00 1 20.7 -15.4  
220.00\* 512005 VIJA 220.00 2 20.7 -15.4  
220.00\* 512073 SRIS 220.00\* 1 49.9 -2.8  
220.00\* 512073 SRIS 220.00\* 2 49.9 -2.8  
220.00\* 512073 SRIS 220.00\* 3 49.9 -2.8  
220.00\* 512005 VIJA 220.00 1 73.1 -19.7  
220.00\* 512050 LISLAU 220.00 1 -109.4 18.3  
220.00\* 512050 LISLAU 220.00 2 -88.6 10.8  
220.00\* 512035 CHILAKAL 220.00 1 38.1 8.4  
220.00\* 512035 CHILAKAL 220.00 2 39.7 70.9  
220.00\* 512103 BRAHMTR 220.00 1 11.9 70.9  
220.00\* 512103 BRAHMTR 220.00 2 -69.6 49.5  
220.00\* 512152 DINDI 220.00\* 512073 SRIS 220.00 1 -69.6 49.5  
512174 HUZURANAGAR 220.00\* 5122035 CHILAKAL 220.00 1 -20.9 22.6  
512043 KOTH 220.00\* 512050 LISLAU 220.00 2 -88.6 10.8  
512060 SURYAPET2 220.00\* 512035 CHILAKAL 220.00 1 38.1 8.4  
512066 WANFETTY 220.00\* 512103 BRAHMTR 220.00 2 39.7 70.9  
512152 DTNT 220.00\* 512103 BRAHMTR 220.00 1 11.9 70.9  
512152 DINDI 220.00\* 512073 SRIS 220.00 2 -69.6 49.5  
512174 HUZURANAGAR 220.00\* 5122035 CHILAKAL 220.00 1 -20.9 22.6  
514003 NSAG 400.00\* 514938 FSC-3 400.00 1 146.3 -71.6  
514003 NSAG 400.00\* 514939 FSC-4 400.00 1 146.3 -71.6  
514004 SHAK 400.00\* 514905 VJJK 400.00 1 -35.6 -35.3  
514004 SHAK 400.00\* 514916 VJZFOOL 400.00 1 -238.1 87.4  
514011 GSIBP4 400.00\* 514913 KURBOGLA 400.00 1 293.4 -214.4  
514011 GSIBP4 400.00\* 514926 VTJ-TF 400.00 1 -20.5 -116.9  
514011 GSIBP4 400.00\* 514906 VTJ-TF 400.00 1 -20.7 -2.8  
514011 GSIBP4 400.00\* 514913 KURBOGLA 400.00 1 -238.1 87.4  
514023 MAHABUBA 400.00\* 514133 UVRKND 400.00 1 293.4 -214.4  
514023 MAHABUBA 400.00\* 514930 VIJTP-IV 400.00\* 1 -213.6 48.3  
514052 MALKARM4 400.00 514930 VIJTP-IV 400.00\* 1 -129.6 78.6  
514060 SURPET4 400.00 514911 RVKOTA4G 400.00 1 -288.3 -6.2  
514060 SURPET4 400.00\* 514911 RVKOTA4G 400.00 1 -46.1 -145.8  
514060 SURPET4 400.00\* 514911 RVKOTA4G 400.00 1 -46.1 -145.8  
514101 MAHEENM 400.00\* 514913 KURMOOLA 400.00 2 46.1 -145.8  
514135 ASUAKA 400.00 514916 VJZFOOL 400.00\* 1 -23.0 -3.4  
518051 HYDR\_800 765.00\* 518028 KUR1300 765.00 1 -311.5 117.2  
518051 HYDR\_800 765.00\* 518028 KUR1300 765.00 1 -45.7 -225.9  
518079 WARUBO 765.00\* 518093 CPSA200 765.00 1 -45.7 -225.9  
518079 WARUBO 765.00\* 518093 CPSA200 765.00 1 101.9 -362.9  
518079 WARUBO 765.00\* 518093 CPSA200 765.00 2 -101.9 -362.9  
TOTAL FROM ZONE 51 TO ZONE 50 -1140.5 -1447.2

TO ZONE 52 KARNATAKA

X--- FROM ZONE BUS ---X

BUS# X-- NAME --X BASKV

X-- NAME --X BASKV  
CKT MW MVAR

400.00\* 514013 KURMOOLA 400.00 1 12.6 26.8

400.00\* 514015 VJZFOOL 400.00\* 1 12.6 26.8

400.00\* 514016 VJZFOOL 400.

## PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E

MON, APR 27 2015 14:39

ZONE TOTALS

IN MW/MVAR

		FROM -----AT ZONE BUSES-----		TO		TO LINE CHARGING		-NET INTERCHANGE-	
X-- ZONE	--X RATION	GENE- FROM TID	TO IND	TO BUS	GNE BUS	SHUNT DEVICES	FROM LOSSES	TO TIE LINES	TO TIES + LOADS
51 TELANGANA	-2015.8	9858.0	0.0	0.0	14375.0	0.0	0.0	245.5	-4762.4 -2571.4
			0.0	0.0	4192.7	711.1	0.0	3108.6	-348.1 290.9
58 TEL LOAD	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0 -2191.0
COLUMN	9858.0	0.0	0.0	14375.0	0.0	0.0	245.5	-4762.4 -4762.4	
TOTALS	-2015.8	0.0	0.0	4192.7	711.1	0.0	3108.6	-348.1 -348.1	

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E      MON, APR 27 2015 14:43

OUTPUT FOR ZONE 51 [TELANGANA ]

SUBSYSTEM LOADING CHECK (INCLUDED: TRANSFORMERS) (EXCLUDED: LINES; BREAKERS AND SWITCHES)  
MVA LOADINGS ABOVE 60.0 % OF RATING SET A:

X----- FROM BUS -----X				X----- TO BUS -----X							
BUS#	X-- NAME	AREA	BUS#	X-- NAME	AREA	CKT	LOADING	RATING	PERCENT		
511001	RSTP	132.00	5	514001	RSTP	400.00*	5	1	419.1	400.0	104.8
512001	RMGD	220.00	5	514001	RSTP	400.00*	5	1	538.5	815.0	66.1
512002	HYDR	220.00*	5	514002	HYDR	400.00	5	1	1006.0	1445.0	69.6
512012	HYDAP2	220.00	5	514012	HYDR-AP4	400.00*	5	1	1234.5	1260.0	98.0
512022	GAJWEL2	220.00	5	514022	GAJWEL4	400.00*	5	1	579.3	630.0	91.9
512022	GAJWEL2	220.00	5	514022	GAJWEL4	400.00*	5	2	289.6	315.0	91.9
512023	MEHBOBNG	220.00	5	514023	MAHABUB4	400.00*	5	1	394.7	630.0	62.6
512051	MAILRM	220.00	5	514051	MAILARM4	400.00*	5	1	669.0	945.0	70.8
512052	MALKARAM	220.00	5	514052	MALKARM4	400.00*	5	1	794.7	945.0	84.1
512060	SURYAPET2	220.00	5	514060	SURYPET4	400.00*	5	1	409.1	630.0	64.9
512079	WRNG	220.00	5	514079	WARN4	400.00*	5	4	785.2	1130.0	69.5
512100	NARSAPUR2	220.00	5	514100	NARSAPUR	400.00*	5	1	342.0	315.0	108.6
512100	NARSAPUR2	220.00	5	514100	NARSAFUR	400.00*	5	2	342.0	315.0	108.6
512160	PARIGI-LI	220.00	5	514164	PARIGI	400.00*	5	1	228.5	315.0	72.5
512160	PARIGI-LI	220.00	5	514164	PARIGI	400.00*	5	2	228.5	315.0	72.5

## New generating Evacuation Schemes and possible connectivity to LI Loads

For the base case of load flows, the agriculture load growth of 8% and other then agriculture load growth of 12% are considered from the year 2014-15. The existing Lift Irrigation Load of 2240MW is considered for the year 2018-19 and 5513MW Lift Irrigation load is considered for the year 2021-22. The details of Load and Generation balance considered for the studies are as follows:

In MW

	2018-19		2021-22	
	Maximum Thermal Condition	Maximum Hydel Condition	Maximum Thermal Condition	Maximum Hydel Condition
Generation Availability	12286	10934	19796	16471
Projected Demand	12435	14675	16127	21640
LGB	-149	-3741	3669	-5169

Based on the above LGB, the load flows were conducted. The scheme wise details are as follows:

### **A) MANUGURU (4 X 270 MW) Power Evacuation Scheme:**

#### i) Connectivity details:

- Manuguru TSGenco Plant Switchyard to Proposed 400/220kV Bommanapalli SS with Quad Moose Dc Line – about 80 kms.
- From Proposed 400/220kV Bommanapalli SS to Existing 400/220 kV Khammam (PGCIL) SS with Quad Moose Dc Line – about 50 kms.

### **B) KTPS VII(1 x 800 MW) Power Evacuation Scheme:**

#### i) Connectivity details:

- KTPS Stage VII Switchyard to Proposed 400/220/132 kV Bommanapalli SS by Quad Moose Dc Line – about 25 kms.
- From Proposed 400/220/132 kV Bommanapalli SS to Upcoming 400/220/132 kV Suryapet SS by Quad Moose Dc Line – about 125 kms.
- From Proposed 400/220/132 kV Bommanapalli SS to Proposed 400/220 kV Jangaon SS by Quad Moose Dc Line – about 120 kms.

- From Proposed 400/220/132 kV Jangaon SS to Proposed 400 kV Tippapur LI SS(Considered under Pranahita Chevella Scheme approved in 37<sup>th</sup> Standing Committee meeting) by Quad Moose Dc Line – about 70 kms.
  - From Proposed 400/220/132 kV Bommanapalli SS to Proposed 220/132 kV Kallur SS by Single Moose Dc Line – about 70 kms.
  - From Proposed 400/220 kV Jangaon SS to Upcoming 220/132 kV Jangaon SS by Single Moose Dc Line – about 15 kms.
  - From Proposed 400/220 kV Jangaon SS to Existing 220/132 kV Husnabad SS by Single Moose Dc Line – about 60 kms.
  - From Proposed 400/220 kV Jangaon SS to Existing 220/132 kV Bhongiri SS by Single Moose Dc Line – about 70 kms.
- ii) The proposed new substations for both Manuguru and KTPS VII:
- 400/220 kV Bommanapalli SS with 2 x 315 MVA
  - 400/220 kV Jangaon SS with 3 x 500 MVA
  - 220/132 kV Kallur SS with 3 x 50 MVA
  - 220/132 kV Husnabad SS with 2 x 80 MVA

### C) Damaracherla (2 x600 + 4 x 800 MW) Power Evacuation Scheme:

- i) Connectivity details:
- Proposed Damaracherla Switchyard to Proposed 400/220/132 kV Choutuppal SS by Quad Moose Dc Line – about 150 kms.
  - Proposed Damaracherla Switchyard to Proposed 400/220kV DindiSS by Quad Moose Dc Line – about 140 kms.
  - Proposed Damaracherla Switchyard to Proposed 400/220 kV Maheswaram (TSTRANSCO) SS by Quad Moose Dc Line – about 155kms.
  - Proposed Damaracherla Switchyard to Proposed 400/220kV Jangaon SS by Quad Moose Dc Line – about 155 kms.
  - From Proposed 400/220/132 kV Choutuppal SS to Upcoming 220/33 kV Hayatnagar SS by Single Moose Dc Line – about 50 kms.

ii) The proposed new substations:

- 400/220 kV Dindi SS with 3 x 500 MVA
- 400/220 kV Choutuppal SS with 3 x500 MVA

**D) Palamur-Ranagareddy Lift Irrigation Scheme with 2548 MW Load.**

i) Connectivity details:

- Proposed 400/220kV Maheswaram (TSTRANSCO) SS to Existing 400/220kV Veltoor SS by Quad Moose Dc Line – about 137 kms.
- Proposed 400/220kV Maheswaram (TSTRANSCO) SS to Proposed 400 Parigi LI SS by Quad Moose Dc Line – about 120 kms.
- Existing 400/220 kV Veltoor SS to Proposed 400 kV Madaram LI SS by Quad Moose Dc Line – about 78 kms.
- Proposed 400 kV Madaram (Dhanwada Mandal) LI SS to Proposed 400 kV Nancharlakota LI SS by Quad Moose Dc Line – about 54 kms.
- Proposed 400 kV Nancharlakota LI SS to Proposed 400 kV Parigi LI SS by Quad Moose Dc Line – about 42 kms.

ii) The proposed new substations:

- 400 kV Madaram LI SS.
- 400 kV Nancharlakota LI SS
- 400 kV Parigi SS

**6. Observations:**

As per the loadflows, it is observed that by giving connectivity from Bommanapalli to Surayapet and Janagaon in addition to Khammam(PGCIL), the entire power of Manuguru Generating Station and KTPS can be utilised within the Telangana State.

In the 765KV Wardha – Nizamabad – Hyderabad scheme, the connectivity between Maheshwarm (PGCIL) to Maheshwarm (TSTRANSCO), Nizamabad (PGCIL) to Dichpalli (TSTRANSCO) is to be with Quad Moose DC line instead of Twin Moose DC line, which was envisaged earlier.

The proposed LILO of 2 circuits of 400KV Gajwel – Mailaram (Shankarpalli) at the proposed 400/220KV Narsapur SS with Twin Moose DC Line instead of direct connectivity form 400KV Gajwel SS, which was envisaged earlier in Singareni evacuation scheme as per the directions of Electricity regulatory commission .

Load flows also indicate the change in the conductor configuration from twin moose to Quad moose for 400kV DC line to proposed Nirmal SS for singareni evacuation scheme by considering all the three units (2x600 MW+ 1x800 MW)