

I/1920/2018 | 972-973



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत प्रणाली योजना एवं मूल्यांकन-I प्रभाग

Power System Planning & Appraisal-I Division

To,
Green Infra Wind Energy Limited
5th Floor, Tower C, Building No. 8,
DLF Cyber city, Gurugram-122002
Haryana

Subject: Prior approval of the Government under Section 68(1) of the Electricity Act, 2003 to M/s **Green Infra Wind Energy Limited (GIWEL)** for the transmission scheme "Connectivity system to M/s Green Infra Wind Energy Limited for 300 MW wind farms in Kutch, Gujarat" - reg.

Ref: GIWEL letter no. GIWEL/CEA/2018-19/S-68/S-III/July/02 dated 07.08.2018

Sir / Madam,

GIWEL vide letter mentioned above has sought prior approval of Government of India under Section 68(1) of Electricity Act, 2003, in favor of M/s Green Infra Wind Energy Limited for the transmission scheme "Connectivity system of 300 MW wind farms in Kutch, Gujarat", with following scope of work:

- i. Green Infra Wind Energy Limited (GIWEL-Roha)- Bhuj PS 220kV S/c line on D/c tower (with minimum capacity of 300 MW) along with associated bays at Bhuj PS and generation switchyard.
 - ii. Route length is approx. 63 km, out of which 60 km will be S/c line on D/c tower and balance 3 km will be S/c line on M/c tower (4 circuits) towards the entry of Bhuj Pooling Substation.
2. The scope of work has been agreed in the 28th meeting of Western Region constituents regarding connectivity/LTA applications held on 12.07.2018 for the grant of Stage II connectivity to M/s Green Infra Wind Energy Limited.
 3. Central Electricity Authority, Government of India, conveys prior approval of the Government under Section 68(1) of Electricity Act, 2003 to M/s Green Infra Wind Energy Limited for the following overhead transmission line covered under the scheme:

I/1920/2018

- (i) Green Infra Wind Energy Limited (GIWEL-Roha)- Bhuj PS 220kV S/c line (with minimum capacity of 300 MW)*

* Route length is approx. 63 km, out of which 60 km will be S/c line on D/c tower and balance 3 km will be S/c line on M/c tower (4 circuits) towards the entry of Bhuj Pooling Substation.

4. This approval is subject to compliance of
- The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
 - CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
5. The approval is also subject to the following conditions:
- The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
 - Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
 - The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,



(पी. सी. कुरील / P.C. Kureel)

सचिव / Secretary, के.वि.प्रा / CEA

प्रति लिपि / Copy to -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi