

1/2237/2018(1) 1054-1055



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत प्रणाली योजना एवं मूल्यांकन-I प्रभाग

Power System Planning &amp; Appraisal-I Division

To,  
Alfanar Energy Private Limited,  
4<sup>th</sup> Floor, 419-424 JMD Megapolis,  
Sector-48, Sohana Road,  
Gurugram, Haryana – 122002

**विषय :** विद्युत अधिनियम, 2003 की धारा 68(1) के तहत **M/s Alfanar Energy Private Limited (AEPL) को पारेषण योजना** "Connectivity System for 300 MW wind farms in Kotda Madh, Kutch, Gujarat to M/s Alfanar Energy Private Limited" के लिये सरकार का पूर्व अनुमोदन – सम्बंधित

**Subject:** Prior approval of the Government under Section 68(1) of the Electricity Act, 2003 to **M/s Alfanar Energy Private Limited (AEPL)** for the transmission scheme "Connectivity System for 300 MW wind farms in Kotda Madh, Kutch, Gujarat to M/s Alfanar Energy Private Limited" - reg.

**Reference:**

- AEPL's letter no. CEA-PS-11-23(20)/1/2018-PSPA dated 10.08.2018
- AEPL's letter no. AE052-TranchellI-2018044 dated 28.08.2018

Sir / Madam,


Reference is invited to the AEPL's letter dated 10.08.2018, seeking prior approval of Government of India under Section 68(1) of Electricity Act, 2003, in favor of M/s Alfanar Energy Private Limited (AEPL) for the transmission scheme "Connectivity System for 300 MW wind farms in Kotda Madh, Kutch, Gujarat to M/s Alfanar Energy Private Limited", with following scope of work:

- Alfanar Energy Private Limited (AEPL-Kotda Madh) – Bhuj PS 220 kV S/C line (with minimum capacity of 300 MW) along with associated bays at Bhuj PS and generation pooling station.
- The above scope of work has been agreed for the grant of Stage II connectivity to M/s Alfanar Energy Private Limited (AEPL) in the 28<sup>th</sup> meeting of WR constituents regarding connectivity & Long Term Access applications in Western Region held on 12.07.2018.

I/2237/2018(1)

- 3 Central Electricity Authority, Government of India, conveys prior approval of the Government under Section 68(1) of Electricity Act, 2003 to M/s Alfanar Energy Private Limited for the following overhead transmission line covered under the scheme:
- i. Alfanar Energy Private Limited (AEPL) generation pooling station at Kotda Madh – Bhuj PS 220 kV S/C line (with minimum capacity of 300 MW)\*
- \*Route length of the line is approximately 65.3 km, which includes three sections (Section I, II, and III from generation pooling station towards Bhuj PS). Section I (17 km) would be S/C line on S/C towers, section II (46 km) would be S/C line on D/C towers, section III (2.3 km) would be S/C line on M/C towers (4 circuits).
- 4 This approval is subject to compliance of
- a) The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
- b) CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
- 5 The approval is also subject to the following conditions:
- (i) The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
- (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
- (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,

  
 (पी. सी. कुरील / P.C. Kureel)

सचिव / Secretary, के.वि.प्रा / CEA

प्रति लिपि / Copy to -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi