

I/4112/2019

11691-1692



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत प्रणाली योजना एवं मूल्यांकन-I प्रभाग

Power System Planning & Appraisal-I Division

सेवा में / To,

Shri Monil Mathur

M/s Toramba Renewable Energy Private Ltd.

D.No.5/154, Uma Housing Cooperative Society

Juni Mill Compound,

Solapur (MH) – 413 001

विषय : विद्युत अधिनियम, 2003 की धारा 68(1) के तहत M/s Toramba Renewable Energy Private Limited (TREPL) को पारेषण योजना "Connectivity system to M/s Toramba Renewable Energy Private Limited for its proposed 300 MW wind farms in Horti, Osmanabad" के लिये भारत सरकार का पूर्व अनुमोदन – सम्बंधित

Sub: Prior approval of the Government of India under section 68(1) of the Electricity Act, 2003 to M/s Toramba Renewable Energy Private Limited (TREPL) for the transmission scheme "Connectivity system to M/s Toramba Renewable Energy Private Limited for its proposed 300 MW wind farms in Horti, Osmanabad"- reg.

संदर्भ /Reference:

- (i) TREPL letter no. TREPL/18-19/CEA/058 dated 10.10.2018
- (ii) TREPL letter dated 02.02.2019
- (iii) TREPL letter no. TREPL/18-19/CEA/112 dated 04.02.2019
- (iv) TREPL letter no. TREPL/18-19/113 dated 07.02.2019

Sir,

Reference is invited to the above mentioned letters, seeking prior approval of Government of India under Section 68(1) of Electricity Act, 2003, in favor of M/s Toramba Renewable Energy Private Limited for the transmission scheme "Connectivity system to M/s Toramba Renewable Energy Private Limited for its proposed 300 MW wind farms in Horti, Osmanabad" with following scope of work:

- (i) Toramba P.S.-Solapur (PG) 400 kV S/c line (with minimum capacity of at least 900 MW at nominal voltage) *
* Line length is approx. 50.84 km which would be implemented on D/c towers with Triple Snow Bird conductor.

2. The above transmission scheme with its specified scope of work, has been agreed in 1st meeting of Western Region Standing Committee on Transmission (WRSCT) held on 05.09.2018 and 29th meeting of WR Constituents regarding

I/4112/2019

Connectivity & Long-Term Access applications in Western Region held on 17.08.2018.

3. CEA conveys the prior approval of Government under Section 68(1) of Electricity Act, 2003 to M/s Toramba Renewable Energy Private Limited for the following overhead line under the transmission scheme "Connectivity system to M/s Toramba Renewable Energy Private Limited for its proposed 300 MW wind farms in Horti, Osmanabad":
- (i) Toramba P.S.-Solapur (PG) 400 kV S/c line (with minimum capacity of at least 900 MW at nominal voltage) *
- * Length of the transmission line is approx. 50.84 km which is to be implemented on D/c towers with Triple Snow Bird conductor.
4. This approval is subject to compliance of
- a) The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
- b) CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
5. The approval is also subject to the following conditions:
- (i) The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
- (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
- (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,

Ym i r
22/2/2019

(पी. सी. कुरील / P.C. Kureel)

सचिव / Secretary, के.वि.प्रा / CEA

प्रति लिपि / Copy to -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi