

I/4976/2019

/1228-1229.



भारत सरकार  
**Government of India**  
 विद्युत मंत्रालय  
**Ministry of Power**  
 केन्द्रीय विद्युत प्राधिकरण  
**Central Electricity Authority**  
 विद्युत प्रणाली योजना एवं मूल्यांकन-I प्रभाग  
**Power System Planning & Appraisal-I Division**

सेवा में / To,

Chief Executive Officer,  
 REC Transmission Projects Company Limited (RECTPCL),  
 ECE House, 3<sup>rd</sup> floor, Annexe-II, 28A, K G Marg,  
 New Delhi-110001

**विषय :** विद्युत अधिनियम, 2003 की धारा 68(1) के तहत "WRSS XXI (A) ट्रांसको लिमिटेड", RECTPCL के एसपीवी को पारेषण योजना "Western Region Strengthening Scheme – 21 (WRSS-21) Part-A – Transmission system Strengthening for relieving overloadings observed in Gujarat Intra-State System due to RE injections in Bhuj PS" के लिये भारत सरकार का पूर्व अनुमोदन - सम्बंधित

**Sub:** Prior approval of the Government of India under section 68(1) of the Electricity Act, 2003 for the Transmission project - "Western Region Strengthening Scheme – 21 (WRSS-21) Part-A – Transmission system Strengthening for relieving overloadings observed in Gujarat Intra-State System due to RE injections in Bhuj PS" in favour of " WRSS XXI (A) Transco Limited" , the SPV of REC Transmission Projects Company Limited (RECTPCL)-reg

**संदर्भ/Reference:** RECTPCL letter no. RECTPCL/RfP/Bhuj PS/2018-19/1654 dated 29.03.2019

Sir/Madam,

Reference is invited to the above mentioned letter of RECTPCL, seeking prior approval of Government of India under Section 68(1) of Electricity Act, 2003, in favour of " WRSS XXI (A) Transco Limited ", SPV of RECTPCL for implementation of the transmission scheme – "Western Region Strengthening Scheme – 21 (WRSS-21) Part-A – Transmission system Strengthening for relieving overloadings observed in Gujarat Intra-State System due to RE injections in Bhuj PS", with following scope of works:

I/4976/2019

Sl. No.	Scope of the Transmission Scheme
	<p>Establishment of 2x1500 MVA, 765/400 kV Lakadia PS with 765 kV (1x330MVAR) &amp; 400 kV (1x125 MVAR) bus reactor</p> <ul style="list-style-type: none"> <li>• 2x1500MVA, 765/400 kV</li> <li>• 400 kV ICT bay-2</li> <li>• 765 kV ICT bay-2</li> <li>• 400 kV line bay-4</li> <li>• 765 kV line bay-2</li> <li>• 1x330 MVar, 765 kV</li> <li>• 1x125 MVar, 420 kV</li> <li>• 765 kV Reactor bay- 1</li> <li>• 400 kV Reactor bay -1</li> </ul> <p><u>Future provisions:</u> Space for 765/400 kV ICTs along with bays: 2 nos. 400/220 kV ICTs along with bays : 8 nos. 765 kV line bays: 4 nos. 400 kV line bays: 6 nos. 220 kV line bays: 16 nos 765 kV bus reactor along with bays : 1 no 400 kV bus reactor along with bays: 1 no</p>
	LILO of Bhachau – EPGL 400 kV D/c (triple) line at Lakadia PS
	Bhuj PS – Lakadia PS 765 kV D/c line
	2 nos of 765 kV bays at Bhuj PS for Bhuj PS – Lakadia PS 765 kV D/c line

2. The above mentioned scope of works have been deliberated and agreed in the 1<sup>st</sup> meeting of Western Region Standing Committee on Transmission (WRST) held on 05.09.2018 at New Delhi. Subsequently, in the 3<sup>rd</sup> meeting of the Empowered Committee on transmission (ECT) held on 21.12.2018, the above scheme was recommended to be taken up through Tariff Based Competitive Bidding. MoP has appointed M/s REC Transmission Projects Company Limited (RECTPCL) as Bid Process Coordinator (BPC) for the above scheme vide Gazette notification dated 01.02.2019.

3. CEA conveys the prior approval of the Government of India under section 68 (1) of the Electricity Act, 2003 to “ M/s WRSS XXI (A) Transco Limited” the SPV of REC Transmission Projects Company Limited (RECTPCL) for the installation of the following overhead line under the transmission scheme “**Western Region**


I/4976/2019

**Strengthening Scheme – 21 (WRSS-21) Part-A – Transmission system Strengthening for relieving overloadings observed in Gujarat Intra-State System due to RE injections in Bhuj PS” :**

Sl. No.	Scope of the Transmission Scheme	Line Length (Approx.)
1.	LILO of Bhachau – EPGL 400 kV D/c (triple) line at Lakadia PS	10 km
2.	Bhuj PS – Lakadia PS 765 kV D/c line	100 km

4. This approval is subject to compliance of
- The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
  - CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
5. The approval is also subject to the following conditions:
- The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
  - Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
  - The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,

  
17/5/2019

(पी. सी. कुरील / P.C. Kureel)

सचिव / Secretary, के. वि. प्रा. / CEA  
सचिव / Secretary  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
नई दिल्ली / New Delhi

प्रति लिपि / Copy to - Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhavan, New Delhi

